


232.3
78CO



cost comparison of windmill and engine pumps

by L. Marchesini and S.F. Postma

December 1978



STEERING COMMITTEE ON WIND-ENERGY FOR DEVELOPING COUNTRIES
(Stuurgroep Wind-energie Ontwikkelingslanden)

P.O. BOX 85 / AMERSFOORT / THE NETHERLANDS

International Reference Centre
for Community Water Supply

232.3-78CO

1006
232.3
7800

COST COMPARISON OF WINDMILL AND ENGINE PUMPS

By L. Marchesini and S.F. Postma

1987
International Reference Centre
for Community Water Supply

SWD Steering Committee for Windenergy in Developing Countries
P.O. Box 85/Amersfoort/The Netherlands
Tel. 33/689111 cable dehave Amersfoort, telex 79348 dhv nl

PUBLICATION SWD 77 – 2

This publication was realized under the auspices of the Steering Committee on Wind-energy for Developing Countries S.W.D., by DHV, Consulting Engineers, Amersfoort.

The S.W.D. is financed by the Netherlands Ministry for Development Cooperation and is staffed by:

the Eindhoven University of Technology,
the Twente University of Technology,
the Netherlands Organization for Applied Scientific Research, and
DHV, Consulting Engineers, Amersfoort

and collaborates with other interested parties.

The S.W.D. tries to help governments, institutes and private parties in the Third World, with their efforts to use wind-energy and in general to promote the interest for wind-energy in Third World Countries.

CONTENTS	PAGE
SUMMARY	8
1. SUMMARY OF THE IRRIGATION EXAMPLE	9
1.1. Introduction	9
1.2. Size of Windmill and Reservoir	9
1.3. Break-even Analysis	9
2. GENERAL MODEL	12
2.1. Introduction	12
2.2. The Model	12
2.3. Sizing-Problems	15
2.3.1. introduction	15
2.3.2. available energy from windmill pump set	16
2.3.3. required energy for water lifting	17
2.3.4. windmill diameter	17
2.3.5. reservoir capacity	18
2.4. Sensitivity Analysis	18
2.4.1. investment level and lifetime	18
2.4.2. operation and maintenance	18
2.4.3. interest rate	18
3. CALCULATION EXAMPLE	19
3.1. Introduction	19
3.2. Basic Data and Assumptions	19
3.2.1. data on windspeed and distribution	19
3.2.2. water requirements	19
3.2.3. groundwater depth and pumping head	20
3.2.4. efficiency	21
3.3. Determination of Windmill Diameter	21
3.4. Determination of Reservoir Capacity	22
3.5. Considerations on the Calculation Example	25
3.5.1. introduction	25
3.5.2. the influence of wind speed distribution and pumping head on the size of the windmill	25
3.5.3. the windmill diameter	27
3.5.4. the relation windmill diameter to reservoir capacity	27
3.5.5. the capacity of the reservoir	28
3.5.6. conclusion	32
3.6. Break-even Analysis	33
3.7. Economic Comparison	34
3.8. Sensitivity Analysis on the Break-even Prices of Energy	37

CONTINUATION	PAGE
3.8.1. introduction	37
3.8.2. sensitivity to variation of investment in windmill pump set	37
3.8.3. sensitivity to variation of technical life time of the windmill pump set	40
3.8.4. sensitivity to variation of maintenance costs of the windmill pump set	40
3.8.5. sensitivity to variation of interest rate	50

List of tables

- Table S.1. Windmill/reservoir combinations supplying water with the same reliability as the motor pump sets
- Table S.2. Cost elements of the windmill alternatives and the motor pump sets
- Table S.3. Break-even water volumes of windmill alternatives
- Table 2.1. Form for cost comparison of water pumping by windmills and other engines
- Table 3.1. Windspeed distribution as registered for month 1, 1976 at Hambantota (Sri Lanka)
- Table 3.2. Monthly water requirements of 1 hectare of crops
- Table 3.3. Calculation of the required windmill diameter
- Table 3.4. Daily useful wind distribution for the critical month
- Table 3.5. Calculation method required reservoir
- Table 3.6. Simplified daily useful windspeed distribution alternatives
- Table 3.7. Relation windspeed distribution to pumping head and required windmill diameter
- Table 3.8. Considerations on required reservoir and windmill diameter
- Table 3.9. The base situation
- Table 3.10. Base situation annual costs
- Table 3.11. Base situation break-even prices for energy
- Table 3.12. Break-even water volumes (base situation)
- Table 3.13. Investigated alternatives
- Table 3.14. Break-even prices as a function of investment level
- Table 3.15. Break-even water volumes, windmill pump set US \$ 1400

- Table 3.16. Influence of investment level and technical life time of the windmill pump set on the break-even prices for energy
- Table 3.17. Influence of windmill pump set maintenance costs, technical life time and investment level on the break-even prices for energy
- Table 3.18. Break-even water volumes as a function of investment and maintenance costs
- Table 3.19. Influence of the interest rate on the break-even prices for energy

List of figures

- Fig. 1 Relation break-even price for energy to outflow
- Fig. 2 Relation windmill diameter to required reservoir capacity
- Fig. 3 Relation break-even prices to annual useful outflow, base situation
- Fig. 4 Break-even price sensitivity for investment level windmill pump set
- Fig. 5 Diesel break-even prices as a function of investment level and technical life time windmill pump set at various useful annual outflows
- Fig. 6 Petrol break-even prices as a function of investment level and technical life time windmill pump set at various useful annual outflows
- Fig. 7 Electricity break-even prices as a function of investment level and technical life time windmill pump set at various useful annual outflows
- Fig. 8 Diesel break-even prices as a function of operation and maintenance cost windmill pump set
- Fig. 9 Petrol break-even prices as a function of operation and maintenance costs windmill pump set
- Fig. 10 Electricity break-even prices as a function of operation and maintenance costs wind mill pump set
- Fig. 11 Break-even prices of energy as a function of interest rate

Symbols and abbreviations

A_{CE}	=	annual cost of conventional engine
A_{WM}	=	annual costs of windmill
CE	=	conventional engine
C_p	=	power coefficient of windrotor
D	=	diameter of windrotor (m)
E	=	energy (wh or kWh)
F	=	annuity factor
g	=	gravitational constant (9.81 m/s ²)
H	=	pumping head
I_{CE}	=	investment of conventional engine
I_{WM}	=	investment of windmill
i	=	rate of interest
n	=	number of years lifetime
$O + M$	=	operation and maintenance
P	=	power (W)
q	=	outflow of water (m ³ /s)
Q	=	total outflow of water (m ³)
W_d	=	windspeed duration (hours)
WM	=	windmill
η_p	=	efficiency of pump
η_t	=	efficiency of transmission
ρ	=	density of air (≈ 1.25 kg/m ³)

conversion

factor = 1 US\$ = Dfl 2.20 /Feb. 1978)

SUMMARY

In this paper a method is given to compare the costs of irrigation with windmills and with conventional engines (diesel, petrol engines or electric motors).

The method results in graphs of break-even prices for fuel or electricity as a function of the annual quantity of irrigation water required. The choice of a windmill then is economically justified if the local prices for fuel or electricity are higher than the break-even prices.

The necessary calculations of the output of windmills on the basis of windregime data are explained. They are demonstrated in an example with wind data from Hambantota in Sri Lanka.

In this example also the sensitivity of variations of different parameters is analyzed.

For the hasty reader a summary of this example and some of its main conclusions are given below.

1. SUMMARY OF THE IRRIGATION EXAMPLE

1.1. Introduction

In the example it is assumed that one hectare of crops in Hambantota (Sri Lanka) must be irrigated from a shallow well with a pumping head of 13 meters. The annual water requirements are estimated at 9500 m³. The peak demand is supposed to be 1 l/sec (86.4 m³ per dag) continuously during one month.

1.2. Size of Windmill and Reservoir

Pumping water with a windmill pump set requires a windmill of sufficient diameter and a reservoir to overcome windless days. The sizing of the windmill in the example is based on wind data as registered in Hambantota (Sri Lanka). During the critical month useful windspeeds from 3.5-12.5 meter per second prevailed some 50% of the time. It is shown that a windmill with a diameter of 2.2 m produces just sufficient water in the critical month and requires a relatively large reservoir. Table S.1. shows that somewhat larger diameters greatly reduce the required reservoir capacity.

Table S.1. Windmill/reservoir combinations supplying water with the same reliability as the motor pump sets.

Diameter (m)	Reservoir (m ³)	Potential Annual Outflow (m ³)
2.2	161.1	22,600
3.0	74.1	42,700
3.5	40.4	57,200

Note: calculated for Hambantota in Sri Lanka.

Though the optimum combination of sizes for the windmill and the reservoir was not investigated the example suggests that it may be wise to install a larger windmill in order to reduce the dimensions of the reservoir and the costs involved.

1.3. Break-even analysis

The question whether a windmill is economically justified when compared to conventional motors is analyzed by the calculation of break-even curves between the windmill and other power sources. Break-even analysis is a technique for analyzing the relationships among fixed costs and variable costs at various levels of output. Until the break-even point is reached for a certain outflow the windmill operates at a loss. After the break-even point each additional unit of water produced by the windmill represents a profit.

The investment as well as the costs of operation and maintenance of the different conventional motor pump sets and of some representative windmill pump sets are given in table S.2.

Table S.2. Cost elements of the windmill alternatives and the motor pump sets

Cost elements	Unit	Windmill pump sets			Conventional motor pumpsets		
		I	II	III	Diesel	Petrol	Electric
Investment	US \$	2800	1400	700	1170	515	655
Life time	years	25	25	10	$\frac{20}{pQ}$	$\frac{7}{pQ}$	$\frac{10}{pQ}$
Energy costs	US \$	-	-	-	$\frac{23}{pQ}$	$\frac{15}{pQ}$	$\frac{17}{pQ}$
O & M	%	5	10	15	5	5	5

Note: p = price per litre of fuel or per kWh
 Q = outflow in m³
 the numbers 23, 15, 17 indicate the quantity of water (in m³) that can be pumped in practice with one liter of fuel or 1 kWh of electricity.

Windmill pumpsets including reservoirs may cost between US \$ 700 and US \$ 2800 depending on design, quality, etc. Figures I, II and III do not correspond to rotor diameters.

To calculate the annual cost of capital an interest rate of 10% is used. It is noted that the investments of the windmill pump sets vary largely. It is assumed that the cheaper the windmill the more expensive (in % of investment) it's operation and maintenance. However, little is known of these relationships and therefore more alternatives are investigated in the report.

The break-even volumes to justify the installation of a windmill pump set of the 4 alternatives are indicated in table S.3; the fuel prices are US \$ 0.58/l for petrol, US \$ 0.25/l for diesel and US \$ 0.075/kWh for electricity.

Table S.3. Break-even water volumes of windmill alternatives
windmill pumpsets become attractive when more water than
the break even volumes has to be pumped.

(m³/annum)

Conventional alternative	Windmill pumpsets		
	I \$ 2800	II \$ 1400	III \$ 700
Petrol	9,900	5,100	2,700
Diesel	23,200	9,000	2,100
Electric	69,900	35,000	17,900

The following conclusions emerge from this table:

For a small scale irrigation project in Hambantota with an annual water demand of 9500 m³ windmills are nearly always cheaper than petrol pump sets. Only the \$ 2800 windmill is slightly more expansive than the petrol set.

The higher break-even volumes of diesel pumpsets indicate that they are cheaper than petrol sets. However the \$ 1400 and \$ 700 type windmills are cheaper (per m³ water pumped) than the diesels.

The still higher break-even values of electric pumpsets indicate that electricity in this case is cheaper than all three windmill alternatives. Windmills only become attractive when more water is needed than the break-even volumes.

It is noted that these conclusions are drawn on the basis of certain energy prices and are valuable only for a specific (and moderately favourable) windspeed distribution. The break-even curves and the simplified formulas in this paper allow the comparison of windmill and conventional power sources for different wind and price information.

2. GENERAL MODEL

2.1. Introduction

This paper tries to find an answer to the question of the attractiveness of windmill pump sets compared with their most probable substitutes such as conventional engine driven pump sets.

It compares the cost of energy generated by windmills and conventional prime movers like diesel, petrol and electric engines.

The comparison is executed according to a model which allows to compare investments and recurring annual costs on a single basis.

The model takes into account water supply for irrigation on a small scale as this application is most frequent in developing countries.

Political considerations as well as sociological, cultural and strategical ones, which in practice can heavily influence the decision making process as to what type of pump set should be installed, are not taken into account.

The choice criterion according to which decisions are taken is given by the break-even price for fuel. Break-even analysis is basically a technique for analyzing the relationships between fixed costs and variable costs. Until the break-even point is reached at the intersection of the total cost lines of engine driven pump sets and the windmill pump set, the latter operates at a loss. After the break-even point, each unit of water produced by the windmill represents a profit. The break-even price of fuel at the required outflow rate is compared with the market price for fuel. In case the break-even price which results from the calculation is lower than the market price for fuel, the application of a windmill pump set can be considered favourable.

It should be realised, that the outcome of the comparative analysis depends for an important part on the prevailing wind conditions on the one hand, as well as on the local prices for fuel and the useful annual outflow of the pump set on the other hand.

2.2. The Model

The model is limited to the comparison of those aspects that necessarily differ between windmill and other power source driven pump sets (see table 2.1.).

Costs related to the construction of the well and piping system to reach the land to be irrigated are left out of the investigation as these costs are the same for all sources of power.

It is noted that some items are applicable only to the windmill, e.g., tower construction and reservoir. The reservoir is included to allow for comparison of the windmill pump set with conventional engine driven pump sets at the same level of confidence with a view to water supply.

Table 2.1. Form for cost comparison of water pumping by windmills and other engines

A.	Windmill (WM)	Investment	Annual Costs
	windmill + tower
	pump
	reservoir
	installation
	operation and maintenance	(N.A.)
	Total	I_{WM}	A_{WM}
B.	Conventional Engine (CE)	Investment	Annual Costs (without fuel costs)
	prime mover
	pump
	installation
	operation and maintenance	(N.A.)
	Total	I_{CE}	A_{CE}
C.	Calculated useful quantity of irrigation water:	m ³
	Local price of petrol	
	diesel oil	
	electricity	

In order to make investments with different life time comparable to annual costs like operation and maintenance, the investments are converted into an annual equivalent, the so called annuity. This annual equivalent includes depreciation and interest and is obtained by means of annuity factors, which can be calculated by the following formula: In annex .. one finds some annuity tables.

It will be clear that windmills are economically attractive if its annual costs are lower than the annual costs of the conventional engine

included its fuel costs:

$$A_{WM} < A_{CE} + A_{fuel}$$

in which:

$$A_{fuel} = \frac{\text{price of 1 liter fuel}}{\text{outflow per liter fuel}} \times \text{annual quantity}$$

In the break-even analysis the price of 1 liter of fuel is calculated for which the annual costs of windmills and of conventional engines are equal:

or: $A_{WM} = A_{CE} + A_{fuel}$

$$\text{price of 1 liter fuel} = (A_{WM} - A_{CE}) \times \frac{\text{outflow per liter fuel}}{\text{total annual quantity}}$$

$$F = \frac{i(1+i)^n}{(1+i)^n - 1}$$

in which

F = annuity factor

i = interest


n = technical life time (years)

The resulting p_{fuel} is the break-even price of one liter of fuel. In case of electric pump set the break-even price is given per kWh.

Fig. 1 shows the general shape of a curve resulting from the described break-even analysis.

This presentation is a useful yardstick to determine whether the windmill pump set has an advantage over conventional engine driven pump sets at the running prices for energy.

FIG. 1 RELATION BREAK-EVEN PRICE FOR ENERGY TO OUTFLOW



It is noted however that different windspeed regimes result in different break-even curves as they influence the required size of the windmill diameter, windmill tower construction and reservoir capacity and thus the required investments.

2.3. Sizing-Problems

2.3.1. introduction

Before an economic comparison can be made the windmill and the conventional pump sets should be sized according to water requirements. This problem may be solved by taking the water availability of a well as the basis.

In case the availability of water does not form a constraint, the size of the area to be irrigated and the water requirement of the crops may be taken as a starting point. In the calculation example it is assumed that the (shallow) well has enough capacity to irrigate one hectare of land.

2.3.2. available energy from windmill pump set

The power produced by a windmill pump set depends on wind speed, windmill diameter and the efficiency in combination with a pump, as defined by the following formula:

$$P = \frac{1}{2} \rho v^3 \frac{\pi}{4} D^2 C_p \eta_t \eta_p \quad (W)$$

P = available (mechanical) power	(W)
ρ = density of air	(kg/m ³)
V = windspeed	(m/s)
D = diameter of windrotor	(m)
C _p = power coefficient of windrotor	(-)
η_t = efficiency of transmission	(-)
η_p = efficiency of pump	(-)

For each windspeed interval the corresponding power can be calculated by taking the average windspeed of the interval:

V = 3.5 m/s for the interval between 3 and 4 m/s, etc.

The energy generated by the windmill can be calculated for each interval by multiplying the power found above with the duration of that interval, i.e. the number of hours that the wind had a speed within the interval:

$$E = P \cdot W_d \quad (Wh) \quad (2)$$

in which:

$$E = \text{energy} \quad (Wh)$$

$$P = \text{power} \quad (W)$$

$$W_d = \text{windspeedduration (hours)}$$

The total energy generated is the sum of all fractions generated at each interval:

$$\sum_{V=a}^{V=z} \frac{1}{2} \rho \cdot v^3 \cdot \frac{\pi}{4} \cdot D^2 \cdot C_p \cdot \eta_t \cdot \eta_p \cdot W_d \quad (Wh) \quad (3)$$

in which a and z are respectively the lower and upper wind speed limits between which the windmill operates.

2.3.3. required energy for water lifting

The energy required to lift the water depends on the pumping head, the required quantity of water to be pumped and the gravitation according to the following formula, in which the mass of water is assumed at 1 gram/cm³:

$$E_R = \frac{Q \cdot g \cdot H}{3.6} \quad (\text{Wh}) \quad (4)$$

in which:

E_R = Energy required (Wh)
 Q = quantity of water (m³)
 g = 9.81 (m/sec²)
 H = head (m)

The required power to be installed is calculated according to:

$$P_R = q \cdot g \cdot H \quad (\text{W}) \quad (5)$$

in which:

P_R = power required (W)
 q = outflow rate (l/sec)
 g = 9,81 (m/sec²)
 H = head (m)

2.3.4. windmill diameter

The windmill pump set should be able to meet water requirements during any month given the wind distribution.

Therefore the windmill should be sized bearing in mind that for every month the following equation should at least be fulfilled:

$$\begin{array}{l} \text{Total energy required} \\ \text{for water lifting} \\ \text{(in Wh)} \end{array} = \begin{array}{l} \text{Total energy available} \\ \text{for water lifting} \\ \text{(in Wh)} \end{array} \quad (6)$$

Given a fixed wind distribution, pumping head, air density and windmill pump set efficiencies this means that according to formula (4) and formula (3) the windmill diameter can be calculated by solving D from the equation.

The calculation of the diameter should be executed for each month on the hand of the corresponding water requirement and wind distribution data.

The calculations result in various diameters of which the largest should be taken.

2.3.5. reservoir capacity

The energy available for pumping purposes generated by a windmill pump set depends on the wind speed and its duration and is therefore not firm.

In order to be comparable to pumping with conventional engine driven sets the windmill pump set should include a reservoir to overcome calm days.

The dimension of the reservoir is based on the water requirements and the daily wind fluctuations during the critical month, which is the month in which the diameter required by the windmill to fulfill water demand under the given wind regime is set at its maximum value. Other criteria such as equalisation of marginal costs (for windmill diameter increase and risk of crop failure) and marginal benefits (deriving from the reduction in reservoir capacity) are considered, but not worked out in detail as this would require laborious information on cropping patterns, crop response to water gifts and on market prices (all items which are beyond the scope of this paper).

2.4. Sensitivity Analysis

2.4.1. investment level and life time

Prices of windmill pump sets may vary considerably from one country to another. Also the probable technical life time of different designs and construction methods is largely unknown. Therefore sensitivity to variation in investment and life time should be tested.

2.4.2. operation and maintenance

Costs of maintenance are estimated on a percentage basis of the investment. Presently no reliable data are available on these costs for windmill pump sets. Therefore the influence of variation of these costs is also tested.

2.4.3. interest rate

The basic interest rate to be included in the economic comparison among technical alternatives is generally taken as the opportunity cost of capital. As this can vary in different countries because of marginal investment opportunities (national economic point of view) or market rate for interest (private point of view), the influence of deviation from this basic interest rate will also be evaluated.

3. CALCULATION EXAMPLE

3.1. Introduction

The calculation example is based on the elaboration of a small scale irrigation project. The data concerning windspeed and their distribution are taken from windspeed records registered in Hambantota (Sri Lanka) over a period of one year (July 1975 - June 1976).

The prices of conventional pump sets refer to those prevailing in The Netherlands. The life time of the various engines is estimated on the basis of practical experience.

The cost of a windmill pump set varies considerably with the materials used, the costing procedure and the design.

The relation between the investment level of windmill pump sets and the technical life time as well as the operation and maintenance costs is unknown.

However assumptions are made on these subjects.

3.2. Basic Data and Assumptions

3.2.1. data on windspeed and distribution

In table 3.1. an example of the windspeed data underlying the calculation is given for one month.

3.2.2. water requirements

As the model will be applied to small scale irrigation of agricultural crops it is assumed that water will be taken from a shallow well. The water that can be pumped from this well is assumed to be sufficient for the irrigation of 1 ha of crops. The peak requirement of these crops is set at 1 liter/second during 24 hours for one month, equivalent to 8.6 mm/day. The resulting water requirement of the peakmonth and assumptions on requirements during the other months of the growing season are indicated in table 3.2. (the requirements refer to 1 crop a year).

Table 3.2. Monthly water requirements of 1 hectare of crops (m³)

Month	March	April	May	June	July	August	Sept	Year Total
	535	1036	1607	2592	1607	1607	518	9502

3.2.3. groundwater depth and pumping head

The average groundwater level in the shallow well is assumed to be at 13 meters below surface. The head for the conventional engine driven pump sets therefore is 13 meters. For the windmill pump sets 15 m is taken in view of the waterdepth in the reservoir.

3.2.4. efficiency

 According to formula (3) only part of the wind energy can be transformed by the windmill and used for pumping purposes. The coefficients which influence the available power and energy are indicated in formula (1) and (3); they are the air density factor (ρ), the power coefficient (C_p) of the windmill rotor and the pumping and transmission efficiencies (resp. η_p and η_t). Though the values of these items vary from place to place (and should be measured on the spot for exact calculations) this paper takes into account the following figures:

$$\begin{aligned} C_p \times \eta_p \times \eta_t &= 0.16 \\ \rho_{\text{air}} &= 1.250 \\ \pi &= 3.14 \end{aligned}$$

Formula (1) therefore can be reduced to:

$$P = 0.078 v^3 D^2 \quad (\text{w}) \quad (8)$$

Formula (3) can be reduced to:

$$E = \sum P \cdot w_d = \sum 0.078 v^2 D^2 w_d \quad (\text{Wh}) \quad (9)$$

3.3. Determination of the Windmill Diameter

The windmill should be sized in such a way that the monthly available energy at least meets the monthly required energy for lifting water. The windmill diameter can be calculated by solving D from the following equation

$$\begin{array}{l} \text{Energy required} \\ \text{for water lifting} \\ \text{(in Wh)} \end{array} = \begin{array}{l} \text{Energy available for} \\ \text{water lifting} \\ \text{(in Wh)} \end{array}$$

or

$$\frac{Q \times 9.81 \times 15}{3.6} = \sum_{V=a}^{V=z} 0.078 v^3 D^2 w_d \quad (10)^{\text{H}}$$

$$\text{H) } D = \sqrt{\frac{Q \cdot 40.87}{\sum 0.078 v^3 w_d}}$$

or

$$Q = 0.0019 \sum_{V=a}^{V=z} v^3 w_d D^2 \quad (\text{m}^3) \quad (11)$$

In principle the diameter must be calculated for each month using the monthly water requirement and wind speed distribution data.

The results of the calculation are shown in the following table.

Table 3.3. Calculation of Required Windmill Diameter

Month	Energy available (kWh)	Required water (m ³)	Energy required (kWh)	Resulting diameter (meter)
1	14.36 x D ²	-	-	-
2	11.15 x D ²	-	-	-
3	5.35 x D ²	535	21.87	2.02
4	8.69 x D ²	1036	42.35	2.20
5	25.75 x D ²	1607	65.69	1.60
6	29.90 x D ²	2592	105.95	1.88
7	18.44 x D ²	1607	65.69	1.89
8	21.15 x D ²	1607	65.69	1.76
9	20.11 x D ²	518	21.17	1.02
10	18.90 x D ²	-	-	-
11	7.87 x D ²	-	-	-
12	9.22 x D ²	-	-	-
Total	190.89 x D ²	9502	388.41	

Potential water supply: approx 22600 m³ (based on a diameter of 2.2 m)

=====

It follows from table 3.3. that in order to meet monthly water requirements at any time the windmill diameter should be set at 2.20 meter (the windmill diameter as calculated for month 4).

Introduction of this diameter in the total energy available equation shows that the potential water supply by the windmill pumpset largely exceeds the required annual volume of 9502 m³. The total annual potential water supply (assuming the capacity of the well is no constraint) is about 22600 m³.

3.4. Determination of the Reservoir Capacity

The calculation of the reservoir capacity is based on daily wind distribution data of month 4, as shown in table 3.4.

Table 3.4. Daily useful wind speed distribution for the critical month (month 4)

Day	Hours									
	average windspeed (m/s)									
	3.5	4.5	5.5	6.5	7.5	8.5	9.5	10.5	11.5	12.5
1	1	1	2	1	-	-	1	1	-	-
2	3	2	-	-	-	-	1	-	1	-
3	7	1	-	-	-	-	-	-	-	-
4	6	1	4	-	-	-	-	-	-	-
5	6	1	-	1	4	-	-	-	-	-
6	4	3	1	1	-	1	-	-	-	-
7	1	-	-	-	2	-	-	-	-	-
8	2	2	1	-	-	1	-	-	-	-
9	-	2	2	-	1	2	1	-	-	1
10	3	1	2	1	1	1	-	-	-	-
11	1	2	1	-	1	6	1	2	-	-
12	-	4	-	5	2	2	2	1	1	-
13	2	1	3	-	3	4	1	-	2	-
14	4	3	-	1	1	3	1	3	-	-
15	1	4	3	-	3	2	3	1	-	-
16	1	1	5	1	2	1	-	-	-	-
17	4	1	2	1	3	1	-	-	-	-
18	7	3	1	3	-	-	1	-	-	-
19	1	2	-	2	3	1	-	-	-	-
20	3	-	3	2	1	-	-	-	-	-
21	4	2	2	2	1	-	1	-	-	-
22	3	4	1	1	-	-	-	1	-	1
23	2	3	-	-	-	-	-	-	-	-
24	-	3	-	-	1	-	-	-	-	-
25	1	4	2	4	2	1	-	-	-	1
26	-	1	1	1	-	-	-	-	-	-
27	1	3	3	1	-	1	3	1	1	-
28	-	2	2	1	4	2	2	2	-	1
29	2	7	1	2	-	5	1	-	-	-
30	1	5	7	4	1	1	-	-	-	1
Σ	71	69	49	35	36	35	17	12	5	5

From these data the daily energy delivered by a 2.2 m windmill pump set (and thus the quantity of water) can be calculated.

The results of the calculation are shown in table 3.5.

Column (I) shows the quantity of water available, column (II) indicates the required quantity of water.

It can be seen that the daily water production is sometimes larger and sometimes less than the quantities required. The differences should be balanced by a reservoir.

Table 3.5. Calculation method required reservoir

day	(I)	(II)	(III)=	(IV)	(V)	(VI)	
	Daily energy available (kWh)	Daily quantity of water supplied (m3)	Daily quantity of water required (m3)	Daily surplus (m3)	Accumulated daily surplus (m3)	Reservoir stored water Res.cap. 158.1 m3 Res.cap. 161.1 m3	
1	1.06	25.9	34.5	- 8.6	- 8.6	149.5	152.5
2	1.05	25.7	34.5	- 8.8	- 17.4	140.7	143.7
3	0.18	4.4	34.5	-30.1	- 47.5	110.6	113.6
4	0.42	10.3	34.5	-24.2	- 71.7	86.4	89.4
5	0.91	22.3	34.5	-12.2	- 83.9	74.2	77.2
6	0.59	14.4	34.5	-20.1	-104.0	54.1	57.1
7	0.37	9.1	34.5	-25.4	-129.4	28.7	31.7
8	0.40	9.8	34.5	-24.7	-154.1	4.0	7.0
9	1.92	46.9	34.5	+12.4	-141.7	16.4	19.4
10	0.74	18.1	34.5	-16.4	-158.1	0	3
11	2.50	61.1	34.5	+26.6	-131.5	26.6	29.6
12	3.15	77.0	34.5	+42.5	- 89.0	69.1	72.1
13	3.18	77.8	34.5	+43.3	- 45.7	112.4	115.4
14	2.81	68.7	34.5	+34.2	- 11.5	146.6	149.6
15	2.74	67.0	34.5	+32.5	+ 21.0	158.1	161.1
16	1.06	25.9	34.5	- 8.6	+ 12.4	149.5	152.5
17	1.07	26.2	34.5	- 8.3	+ 4.1	141.2	144.2
18	0.95	23.2	34.5	-11.3	- 7.2	129.9	132.9
19	1.04	25.4	34.5	- 9.1	- 16.3	120.8	123.8
20	0.64	15.7	34.5	-18.8	- 35.1	102.0	105.0
21	0.66	16.1	34.5	-18.4	- 53.5	83.6	86.6
22	1.57	38.4	34.5	+ 3.9	- 49.6	87.5	90.5
23	0.17	4.2	34.5	-30.3	- 79.9	57.2	60.2
24	0.29	7.1	34.5	-27.4	-107.3	29.8	32.8
25	1.28	31.3	34.5	- 3.2	-110.5	26.6	29.6
26	0.20	4.9	34.5	-29.6	-140.1	0(-3)	0
27	2.67	65.3	34.5	+30.8	-109.3	30.8	33.8
28	3.71	90.7	34.5	+56.2	- 53.1	87.0	90.0
29	2.07	50.6	34.5	+16.1	- 37.0	103.1	106.1
30	2.22	54.3	34.5	+19.8	- 17.2	122.9	125.9
Total	41.6	1017.8	1036			(-3)	(0)

Notes: (I) Calculated by solving Q from the equation (11) with D = 2.2

(II) Total in month 4 (critical month, see Table 3.3.) divided by 30 days, and thus $\frac{1036}{30} = 34.53$ m3

- (III) Daily surplus: Quantity of water supplied (I) - Quantity of water required (II)
- (IV) Cumulation of daily surpluses as given in column (III)
- (V) Reservoir stored quantity of water is based on a start with a full reservoir, dimensioned as given by the minimum figure in column (IV)
- (VI) Reservoir stored based on col. V, increased in capacity with 3 cubic meters

Rounding of windspeeds to the nearest half resulted in an error of one percent in the energy available and thus in the quantities delivered.

The capacity of the reservoir is determined by trial and error along the following steps.

First take the largest cumulated deficit (table 3.5. col. IV: 158.1 m³ in day 10) and calculate the reservoir operations starting with a reservoir completely filled up (col. V).

The calculation shows that there still is a deficit (shown by the figure in brackets) of 3 m³ in day 26 which should be avoided in order to make the windmill pump set strictly comparable to conventional engine driven pump sets. Therefore the capacity of the reservoir should be increased with 3 m³ to 161.1 m³.

3.5. Considerations on the Calculation Example

3.5.1. introduction

In the following paragraphs simplified examples of various

- windspeed distributions
- pumping heads

are given in order to demonstrate the influence on the calculations assuming a daily water requirement of 86.4 m³ in the peak month (2592 m² in month 6, see table 3.3).

Furthermore some considerations on the sizing problem, as executed on the basis of the Hambantota windspeed data, are worked out with special attention to the sizing of the windmill diameter and the reservoir (par. 3.5.3. to 3.5.5.).

3.5.2. the influence of windspeed distribution and pumping head on the size of the windmill

In the following examples it is assumed that useful windspeeds prevail during 12 hours a day, so 50% of the time. Table 3.6. indicates 3 simplified examples of windspeed distributions (1), (2) and (3).

Table 3.6. Simplified daily useful windspeed distribution alternatives

Windspeed duration (hours/day)	Windspeed distribution (m/s)		
	(1)	(2)	(3)
4	3.5	4.5	5.5
4	4.5	5.5	6.5
4	5.5	6.5	7.5
Average useful wind-speed	4.5	5.5	6.5

Introduction of the water quantity, the windspeeds and their duration into the equation:

$$\text{Energy required} = \text{Energy delivered}$$

$$\text{or, } 0.235 \times H = \sum 0.079 \times V^3 \times W_d \times D^2$$

in which H stands for pumping head, V for windspeed, W_d for windspeed duration and D for diameter. This results in the daily energy available (kWh) and the required windmill diameters for 3 different pumping heads as indicated in table 3.7.

Table 3.7. Relation windspeed distribution to pumping head and required windmill diameter (based on a water demand of 86.4 m³/day)

		Windspeed distribution		
		(1)	(2)	(3)
Available energy (kWh) ¹⁾ :		$0.0949 D^2$	$0.1682 D^2$	$0.2727 D^2$
pumping head (H in meters)	Required energy (kWh) ¹⁾	Required diameter (m)		
15 m	3.525	6.10	4.58	3.60
10 m	2.350	4.98	3.74	2.94
5 m	1.175	3.53	2.65	2.08

1) Daily energy

It is noted that the diameters for 15, 10 and 5 m pumping head are related to each other by the square root of the ratio of the pumping heads.

For instance, pumping from 10 in stead of 5 m depth requires twice as much energy resulting in a windmill diameter of $\sqrt{2}$ times larger. The available energy has the same relation, e.g., the energy under the windspeed distribution as prevailing under alternative 1 to alternative 2 increases from $0,0949 D^2$ to $0,1682 D^2$, or by a factor 1.77. The diameter capable to deliver the same amount of energy under windspeed distribution 2 can be obtained by dividing the one as resulting from the windspeed distribution 1 by $\sqrt{1.77}$ or 1.33.

3.5.3. the windmill diameter

The sizing of the windmill was discussed in paragraph 3.3. The calculation resulted in a windmill diameter of 2.2 m given the specific environmental circumstances (windspeed distribution, pumping head of 15 m).

Despite this calculation it is reasonable to assume that manufacturers who produce windmills on a large (industrial) scale standardize their products.

In the following the operation of a windmill of 3.0 m and 3.5 m diameter is evaluated and compared to the windmill with a diameter of 2.2 m.

Table 3.8., part I, column (I) to (VI) shows the energy available for pumping purposes and the quantities of water pumped.

It is worth noting that once the complete calculation is executed for a specific windmill diameter the corresponding figures for other diameters can be found by multiplication of the calculated figures with the ratio of the squares of the windmill diameters.

For the windmill with a rotor of 3.5 m diameter the multiplication factor, taking the figures of the 2.2 m windmill as the base, showed to be $(3.5)^2/(2.2)^2$ or 2.53.

An increase in windmill diameter from 2.2 m to respectively 3.0 m and 3.5 m results in a considerable increase in water supply as shown by the total figures in table 3.8, part I (page 27).

3.5.4. the relation windmill diameter to reservoir capacity

The calculation of the reservoir capacity required by the windmill pump set system in order to supply water with the same level of confidence as the conventional engine driven pump sets was shown in paragraph 3.4. for a windmill with a rotor diameter of 2.2 m (reservoir of 161.3 m³).

The reservoir can be calculated according to the same procedure for the windmills with rotor diameters of 3,0 m and 3.5 m.

Based on the intermediate results of table 3.8., part II, part III shows the reservoir as required in these latter cases (col. II and col. III) as well as the reservoir required for the 2.2 m windmill (col. I).

It can be seen that increasing the windmill diameter from 2.2 m to 3.0 m and 3.5 m has a reducing effect on the required reservoir. The reservoir decreases from 161.1 m³ to respectively 74.1 m³ and 40.4 m³. It is quite possible that this will reduce the total cost of windmill plus reservoir.

3.5.5. the capacity of the reservoir

In the calculation example of paragraph 3.4. a 2.2. m windmill pump set requires a reservoir of 161.1 m³. If the reservoir would be reduced to 80 m³ without increasing the windmill diameter a deficiency of 107.1 m³ will occur. A reservoir of 40 m³ causes a deficiency of 176.0 m³ (see Table 3.8., part III, column IV and V).

These deficiencies are calculated as follows:

- irrigation takes place twice a month; this implies 15 plots, irrigated at intervals of 15 days
- when the reservoir fails, part of the area cannot be irrigated, the crop will fail and further irrigation after 15 days is not worthwhile. Hence, the water requirement is reduced by the part of the area that fails in the first half of the month

In case the reservoir is reduced to 80 m³ a deficiency of 107.1 m³ occurs (table 3.8., part III, col. IV). This may result in damage to the crop. The damage may be estimated by determining the area reduction on the basis of deficiencies in water supply during the first irrigation (the first 15 days of the month). The water requirements for the second half of the month must be reduced accordingly. The area reduction as a result of deficiency in first irrigation is of $(3.9 + 20.1 + 25.4 + 24.7)/34.5 \times 1/15$ or about 14% of the area irrigated.

An additional reduction in cropped area is caused by a deficiency in water supply on the 26th day, being 29.0 m³. This deficit which occurs during the second irrigation period can cause a crop loss of at maximum $29/34.5 \times 1/15$ or 6% of the area irrigated. The total area reduction due to a decrease of the reservoir capacity from 161.1 m³ to 80 m³ is therefore 14% + 6% = 20% of the cropped area.

In case of a reservoir of 40 m³ (table 3.8., part III, col. (V)) the water deficiency during the first half of the month is 118.1 m³, which causes a reduction in cropped area of $118.1/34.5 \times 1/15$ or 23%. A further reduction caused by insufficient second watering reduces the crop area once more by at maximum $(1.7 + 27.4 + 28.8)/34.5 \times 1/15$ or some 11%.

The total maximum area reduction in this case is 23% + 11% = 34% of the cropped area.

Table 3.8. (Part I) Consideration on required reservoir and windmill diameter

	Energy available for pumping water (kWh)			Quantity of water supplied (m ³)			Quantity of water requir- ed (m ³)
	(I)	(II)	(III)	(IV)	(V)	(VI)	(VII)
day	D= 2.2 m	D= 3.0 m	D= 3.5 m	D= 2.2 m	D= 3.0 m	D= 3.5 m	
1	1.06	1.97	2.68	25.9	49.0	65.6	34.5
2	1.05	1.95	2.65	25.7	48.6	65.1	34.5
3	0.18	0.33	0.45	4.4	8.3	11.1	34.5
4	0.42	0.78	1.84	10.3	19.5	26.1	34.5
5	0.91	1.69	2.30	22.3	42.2	56.4	34.5
6	0.59	1.12	1.52	14.4	27.2	36.5	34.5
7	0.37	0.70	0.95	9.1	17.2	23.0	34.5
8	0.40	0.76	1.03	9.8	18.5	24.8	34.5
9	1.92	3.63	4.94	46.9	88.6	118.7	34.5
10	0.74	1.40	1.90	18.1	34.2	45.8	34.5
11	2.50	4.73	6.43	61.1	115.5	154.6	34.5
12	3.15	5.95	8.09	77.0	145.5	194.9	34.5
13	3.18	6.01	8.17	77.8	147.0	196.9	34.5
14	2.81	5.31	7.22	68.7	129.8	173.9	34.5
15	2.74	5.18	7.04	67.0	126.6	169.6	34.5
16	1.06	2.00	2.72	25.9	49.0	65.6	34.5
17	1.07	2.02	2.75	26.2	49.5	65.6	34.5
18	0.95	1.80	2.45	23.2	43.9	58.7	34.5
19	1.04	1.97	2.68	25.4	48.0	64.3	34.5
20	0.64	1.21	1.65	15.7	29.7	39.7	34.5
21	0.66	1.25	1.70	16.1	30.4	40.8	34.5
22	1.57	2.97	4.04	38.4	72.6	97.2	34.5
23	0.17	0.32	0.44	4.2	7.9	10.6	34.5
24	0.29	0.55	0.75	7.1	13.4	18.0	34.5
25	1.28	2.42	3.29	31.3	59.2	77.2	34.5
26	0.20	0.38	0.52	4.9	9.3	12.4	34.5
27	2.67	5.05	6.87	65.3	123.4	165.3	34.5
28	3.71	7.01	9.53	9.7	171.4	229.6	34.5
29	2.07	3.91	5.35	50.6	95.6	128.1	34.5
30	2.22	4.20	5.71	54.3	102.6	137.4	34.5
Total volume month 4				1017.8	1923.6	2575.5	1036
Total annual volume				22600	42700	57200	9506

Table 3.8. (Part II)

day	Daily surpluses (m ³)			Cumulated daily surpluses (m ³)		
	(I)	(II)	(III)	(IV)	(V)	(VI)
	D= 2.2 m	D= 3.0 m	D= 3.5 m	D= 2.2 m	D= 3.0 m	D= 3.5 m
1	- 8.6	+ 14.5	+ 31.1	- 8.6	+ 14.5	+ 31.1
2	- 8.8	+ 14.1	+ 30.6	- 17.1	+ 28.6	+ 61.7
3	-30.1	- 26.2	- 23.4	- 47.5	+ 2.4	+ 38.3
4	-24.2	- 15.0	- 8.4	- 71.7	- 12.6	+ 29.9
5	-12.2	+ 7.7	+ 21.9	- 83.9	- 4.9	+ 51.8
6	-20.1	- 7.3	+ 2.0	-104.0	- 12.2	+ 53.8
7	-25.4	- 17.3	- 11.5	-129.4	- 29.5	+ 42.3
8	-24.7	- 16.0	- 9.7	- 154.1	- 45.5	+ 32.6
9	+12.4	+ 54.1	+ 84.2	-141.7	+ 8.6	+ 136.8
10	-16.4	- 0.3	+ 11.3	-158.1	+ 8.3	+ 128.1
11	+26.6	+ 81.0	+120.1	-131.5	+ 89.3	+ 248.2
12	+42.5	+111.0	+160.4	- 89.0	+200.3	+ 408.6
13	+43.3	+112.5	+162.4	- 45.7	+312.8	+ 571.0
14	+34.2	+ 95.3	+139.4	- 11.5	+408.1	+ 710.4
15	+32.5	+ 92.1	+135.1	+ 21.0	+500.2	+ 845.5
16	- 8.6	+ 14.5	+ 31.1	+ 12.4	+514.7	+ 876.6
17	- 8.3	+ 15.0	+ 31.1	+ 4.1	+529.7	+ 907.7
18	-11.3	+ 9.4	+ 24.5	- 7.2	+539.1	+ 932.2
19	- 9.1	+ 13.5	+ 29.8	- 16.3	+552.6	+ 962.0
20	-18.8	- 4.8	+ 5.2	- 35.1	+547.8	+ 967.2
21	-18.4	- 4.1	+ 6.3	- 53.5	+543.7	+ 973.5
22	+ 3.9	+ 38.1	+ 62.7	- 49.6	+581.8	+1036.2
23	-30.3	- 26.6	- 23.9	- 97.9	+555.2	+1012.3
24	-27.4	- 21.1	- 16.5	- 107.3	+534.1	+ 995.8
25	- 3.2	+ 24.7	+ 44.7	- 110.5	+509.4	+1040.5
26	-29.6	- 25.2	- 22.1	- 140.1	+484.2	+1018.4
27	+30.8	+ 88.9	+130.8	+ 109.3	+573.1	+1149.2
28	+56.2	+136.9	+195.1	- 53.1	+710.0	+1344.3
29	+16.1	+ 61.1	+ 93.6	- 37.0	+771.1	+1437.9
30	+19.8	+ 68.1	+102.9	- 17.2	+839.2	+1540.8

Table 3.8. (Part III)

Reservoir stored water

Day	(I)	(II)	(III)	(IV)	(V)
	D = 2.2 m Res. cap. = 161.1 m ³	D = 3.0 m Res. cap. = 74.1 m ³	D = 3.5 m Res. cap. = 40.4 m ³	D = 2.2 m Res. cap. = 80 m ³	D = 2.2 m Res. cap. = 40 m ³
1	152.5	74.1	39.7	71.4	31.4
2	143.7	74.1	40.4	71.4	31.4
3	113.6	47.9	17.0	32.5	0(-7.5)
4	89.4	32.9	8.6	8.3	0(-24.2)
5	77.2	40.6	30.5	0(-3.9)	0(-12.2)
6	57.1	33.3	32.5	0(-20.1)	0(-20.1)
7	31.7	16.0	21.0	0(-25.4)	0(-25.4)
8	7	0	11.3	0(-24.7)	0(-24.7)
9	19.4	54.1	40.4	12.4	12.4
10	3	53.8	40.4	0(-4.0)	0(-4.0)
11	29.6	74.1	40.4	26.6	26.6
12	72.1	74.1	40.4	69.1	40.0
13	15.4	74.1	40.4	80.0	40.0
14	149.6	74.1	40.4	80.0	40.0
15	161.1	74.1	40.4	80.0	40.0
16	152.5	74.1	40.4	80.0	31.4
17	144.2	74.1	40.4	71.4	23.1
18	132.9	74.1	40.4	63.1	19.3
19	123.8	74.1	40.4	51.8	26.9
20	105.0	69.3	40.4	46.6	23.0
21	86.6	85.2	40.4	44.0	24.7
22	90.5	74.1	40.4	30.9	28.6
23	60.2	47.5	16.5	34.1	0(-1.7)
24	32.8	26.4	0	3.8	0(-27.4)
25	35.6	51.1	40.7	0.6	+ 0.8
26	0	25.9	18.6	0(-29.0)	0(-28.8)
27	33.8	74	40.7	30.8	30.8
28	90	74.1	40.7	80.0	40.0
29	106.1	74.1	40.7	80.0	40.0
30	125.9	74.1	40.7	80.0	40.0
Total deficit (0)	(0)	(0)	(0)	(-107.1)	(-176.0)


3.5.6. conclusion

Once the windspeed distribution and pumping head are known the sizing of the windmill diameter cannot be seen separately from the sizing of the reservoir.

The approach of minimising the windmill diameter after which the matching reservoir is calculated does not necessarily result in the least cost alternative. Reductions in the investment level of the windmill may well be offset by the increase in investment required by the reservoir.

The calculation example showed the following relation between windmill diameter and reservoir capacity.

FIG. 2 RELATION WINDMILL DIAMETER TO RESERVOIR CAPACITY



Note: Figure not general applicable.
(Based on Hambantota wind data)

The least-cost combination of the windmill and the reservoir which supplies water at a same level of confidence as the conventional engine driven pump sets can be calculated by trial and error.

The windmill diameter may be increased as long as the additional total costs for the windmill are offset by the total additional savings resulting from the smaller reservoir (the totals refer to annual figures).

Once the windmill/reservoir combination as calculated above has been established a further reduction of the reservoir may be allowed. It is obvious that this implies the risk of water deficiency, resulting in crop damage. The reduction however is allowed as long as the total additional savings in construction costs for the reservoir are larger than the total net-income foregone resulting from crop damage.

3.6. Break-even analysis

The base situation for the different pump sets is defined by the following table:

Table 3.9. The base situation

	windmill pump set	diesel pump set	petrol pump set	electric pump set
power	0.38 ¹⁾ kW	3.5 hp	3 hp	1.20 kW
investment level (US \$)	2800	1170	515	655
life time (years)	25	20	7	10
interest rate	10%	10%	10%	10%
operation and maintenance	5%	5%	5%	5%
energy costs (US \$)	-	$\frac{pQ}{23}$ ²⁾	$\frac{pQ}{15}$ ²⁾	$\frac{pQ}{17}$ ²⁾

- notes: 1) power of the windmill is calculated at a windspeed of 10 m/s, windmill diameter 2.2 m
 2) p stands for price of fuel.
 Q stands for total annual useful outflow.
 In case of the diesel pump set and the petrol pump set the price is given per liter. In case of the electric pump set the price is given per kWh.
 The numbers 23, 15 and 17 stand for the quantity of water which can be pumped with 1 liter of fuel (diesel and petrol) or with one kilowatthour from a depth of 13 meters.

The investment levels represent the totals of the relevant parts of the water supply system alternative. The investments required by the water distribution system as well as the drilling costs are excluded from these figures.

In case of the windmill driven pump sets the investment figure includes the construction of a reservoir. Little consistency exists in the costing methods which are applied for windmills. Construction methods vary considerably from one place to another (from labour intensive to capital intensive).

The analysis is limited to global investment levels without going into detail of the components of the system considered, such as the windmill, the windmill tower, the pump and the reservoir.

The investments required by the windmill pump sets as well as the conventional engine driven sets and their technical life time is fixed after consulting manufacturers, dealers and documentation.

The technical life time of different designs and construction methods is largely unknown for windmill pump sets. In the analysis of the base situation the life time of 25 years is taken into account.

Energy costs are a function of outflow and pumping head and of course apply only to the conventional engine driven pump sets. The operation under partial load conditions is taken into account in the calculations of the fuel consumption rates.

The interest rate is set at 10%, the annual operation and maintenance costs of the base situation are set at 5% of the investment level.

3.7. Economic Comparison

The attractiveness of a windmill pump set as compared to a conventional motor driven pump set is warranted from an economic point of view when the windmill pump set's total annual costs are offset by savings of fuel.

The following table shows the annual cost data to calculate the break-even prices at various outflows.

Table 3.10. Annual costs of the Base situation
(Q = annual outflow in m³) (US\$)

	windmill pump set	diesel pump set	petrol pump set	electric pump set
Annuity	308	137	106	107
O + M	140	59	26	33
Energy	-	$\frac{pQ}{23}$	$\frac{pQ}{15}$	$\frac{pQ}{17}$

The resulting break-even prices are shown in table 3.11. and in figure 3.

FIG. 3 RELATION BREAK-EVEN PRICES TO ANNUAL USEFUL OUTFLOW (BASE SITUATION)




Table 3.11. Base situation
Break-even prices for energy

useful annual outflow (m ³)	diesel (US\$ cts/l)	petrol (US\$ cts/l)	electricity (US\$ cts/kWh)
2000	292	238	264
5000	117	95	105
10000	58	48	53
15000	39	32	35
20000	29	24	26
25000	23	19	21
30000	19	16	18
35000	17	14	15

Introduction of the prevailing prices of energy shows the minimum annual water production that renders the use of the windmill profitable.

Introduction of the prevailing energy prices (1978) in The Netherlands shows that the windmill as defined by the base situation becomes attractive starting from the following water quantities:

Table 3.12. Break-even water volumes (base situation)

	fuel price (US\$ cts/liter) (US\$ cts/kWh)	water quantity (m ³ /annum)
petrol	48	9,900
diesel	25	23,200
electricity	7.5	69,900

The conclusion that follows from Table 3.11. is that the windmill pump set of the base situation is not an attractive proposition for small scale irrigation with one crop per year (required water: 9502 m³/annum) in countries with energy prices similar to those in The Netherlands. The potential water production of the windmill is much larger (22,600 m³/annum), but still below the break-even quantity of the diesel pump set and the electric pump set.

However, when volumes of more than 40,000 m³/annum are required a larger windmill would be attractive compared to the diesel pump set. For instance a 3 meter diameter windmill. The volume of 69,900 cannot be attained by windmills of 3.5 m. An electric pump set therefore must be considered always more economic to operate at an electricity price of 7.5 US \$ cts/kWh than any windmill (unless the diameter of the windmill is further increased).

The influence of a possible lower investment level together with a shorter technical life time and higher maintenance costs is investigated in the following chapter.

3.8. Sensitivity analysis on the break even prices of energy

3.8.1. introduction

The windmill pump set of the base situation was assumed to require an investment of US\$ 2800, to last 25 years and have annual maintenance and operation costs of 5% of the investment with an interest rate of 10%. It was shown for this base situation that the costs are such that the useful outflow rate should be rather high to be economically attractive. It may be quite possible however that less expensive windmills with a shorter life time may change the balance in favour of the windmill pump set.

In order to analyse the sensitivity of the break-even prices a calculation is executed for the cases indicated in table 3.13.

Table 3.13. Investigated alternatives

Item	Base situation	Investigated alternatives		
Investment (US\$)	2800	2800	1400	700
life time (years)	25	5-25	5-20	5-20
maintenance	5%	5%	5-10%	5-20%
interest	10%	6-14%	6-14%	6-14%

The items to which the interest rate is added are analysed separately. For the investment level and life time combinations have been considered. The conventional power sources are similar to those of the base situation.

3.8.2. sensitivity to variation of investment in the windmill

pump set

The investment required by the windmill pump set has been reduced from US\$ 2800 to respectively US\$ 1400 and US\$ 700. It is clear that these important reductions have considerable influence on the economic attractiveness of the windmill as a power source. The resulting break-even prices of respectively diesel, petrol and electricity at the various outflow rates are given in table 3.14.

Table 3.14. Break even prices as a function of investment level
(technical life time windmill pump set 25 years, interest
rate of 10%)

Useful annual outflow (m3)	Break-even price Diesel (US\$ cts/l)		Break-even price Petrol (US\$ cts/l)		Break-even price Electricity (US\$ cts/kWh)	
	Windmill pump set investmentlevel US\$ 2800 US\$ 1400		Windmill pump set investmentlevel US\$ 2800 US\$ 1400		Windmill pump set investmentlevel US\$2800 US\$ 1400	
2000	292	33	238	69	264	72
5000	117	13	95	28	105	29
10000	58	7	48	14	53	14
15000	39	4	32	9	35	10
20000	29	3	24	7	26	7
25000	23	3	19	6	21	6
30000	19	2	16	5	18	5
35000	17	2	14	4	15	4

It follows from these break-even prices that the cheaper windmill alternatives become of economic interest at much lower outflows than the expensive ones. This can be seen also in figure 4 where the 1400 and the 700 dollar windmill alternatives are compared to the base situation.

Table 3.15. Break-even water volumes, windmill pump set US \$ 1400
(5% O + M, lifetime windmill 25 years)

	fuel price (US \$ cts/liter) (US \$ cts/kWh)	water quantity (m3/annum)
petrol	48	2800
diesel	25	3250
electricity	7.5	20.000

The conclusion from table 3.15. is that the windmill pump set of US \$ 1400 is an attractive alternative to petrol and diesel engine driven pump sets when applied to small scale irrigation with one crop per year (required water: 9502 m3/annum) in countries with energy prices as indicated in the table. In case almost the total annual potential volume can be applied usefully (e.g. the 22600 m3 delivered by a windmill pump set of 2.2 m diameter) the windmill is also an attractive alternative to the electric engine driven pump set.

FIG. 4 BREAK-EVEN PRICE SENSITIVITY FOR INVESTMENT LEVEL
 WINDMILL PUMP SET (EXPECTED TECHNICAL LIFE TIME WINDMILL PUMP SET 25 YEARS,
 INTEREST RATE 10%, MAINTENANCE 5%)




Figure 4 shows negative break-even curves in case the investment of the windmill pump set drops to a level of US\$ 700. This means that this windmill pump set is always preferable to its conventional engine driven alternatives. This is caused by the fact that for the US\$ 700 windmill pump set the sum of the fixed annual costs (= annuity) and the variable costs of operation and maintenance 5% of the investment is less than the sum of the same items for the conventional engine driven pump sets. Even if the fuel price drops to zero the windmill pump set remains more attractive from an economic point of view. The negative break-even price for fuel indicates that the fixed costs advantage of the windmills is a bonus on top of the fuel savings.

It is noted that the assumed life time of the cheaper windmill in this comparison is maintained at 25 years. This may be considered too optimistic and therefore the influence of shorter technical life times of the windmill pump set is analysed in paragraph 3.8.3.

3.8.3. sensitivity to variation of technical life time of the windmill pump sets

A relation is assumed to exist between the investment level and the life time of a windmill pump set. The construction of the 2800 dollar windmill pump set of the base situation may warrant a 25 years life time, while a 700 dollar windmill may last considerably shorter. Break-even prices are calculated for the three investment levels at various life times in Table 3.16.

The influence of life time variation on the economic attractiveness of windmill pump set by means of a break-even price analysis at the running prices for fuel in The Netherlands is clearly shown by the thick line "stair case" in Table 3.16.

Not all combinations of investment level and life time are relevant.

A selection of realistic combinations is presented in figures 5, 6 and 7, assuming a positive relation between the investment level and life time of the windmill pump set.

It follows from these figures that operation of the cheaper windmills remains favourable, even when considering relatively short technical life times.

3.8.4. Sensitivity to variation of maintenance costs

For the base situation maintenance and operation costs (excluding fuel costs) were estimated at 5% of the required investment. The influence of increasing the maintenance of the windmill pump set to 10% and more of the investment while keeping the maintenance costs of the conventional engine driven pump sets at the same level is shown in table 3.17.

It follows from this table that the windmill pump sets of US \$ 1400 and US \$ 700 constitute interesting alternatives even with high levels of operation and maintenance costs. In case of the 700 dollar windmill pump set quadrupling of maintenance costs may be allowed, provided that by doing so a life time of 25 years can be attained.

Table 3.16


Influence of investment level and technical lifetime of the windmill pump set on the break - even prices for energy

(interest rate 10%).

Annual useful outflow (m ³)	Diesel (US \$ cts/l)												Petrol (US \$ Cts/l)												Electricity (US \$ Cts/KWh)																			
	investment windmill pump set												investment windmill pump set												investment windmill pump set																			
	US \$ 2800				US \$ 1400				US \$ 700				US \$ 2800				US \$ 1400				US \$ 700				US \$ 2800				US \$ 1400				US \$ 700											
	lifetime				lifetime				lifetime				lifetime				lifetime				lifetime				lifetime				lifetime															
	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20	25	5	10	15	20
2.000	788	461	362	316	292	282	118	69	40	29	neg	neg	neg	561	348	284	254	238	231	125	92	77	66	13	neg	neg	630	388	315	281	264	256	135	99	82	69	9	neg	neg					
5.000	315	184	145	127	117	113	47	28	18	12	neg	neg	neg	224	139	113	101	95	92	50	37	31	26	5	neg	neg	252	155	126	113	105	102	54	39	35	28	3	neg	neg					
10.000	158	92	72	63	58	56	24	14	9	6	neg	neg	neg	112	70	57	51	48	46	25	18	15	13	3	neg	neg	126	78	63	56	53	51	27	20	16	14	2	neg	neg					
15.000	105	61	48	42	39	38	16	9	6	4	neg	neg	neg	75	46	38	34	32	31	17	12	10	9	2	neg	neg	84	52	42	38	35	34	18	13	11	9	1	neg	neg					
20.000	79	45	35	32	29	28	12	7	5	3	neg	neg	neg	56	35	28	25	24	23	12	9	8	7	1	neg	neg	63	39	32	28	26	25	14	10	8	7	1	neg	neg					
25.000	63	37	29	25	23	23	9	6	4	2	neg	neg	neg	45	28	23	20	19	18	10	7	6	5	1	neg	neg	50	31	25	23	21	20	11	8	7	5	1	neg	neg					
30.000	53	31	24	21	19	19	8	5	3	2	neg	neg	neg	37	23	19	17	16	15	8	6	5	4	1	neg	neg	42	26	21	19	18	17	9	7	5	5	1	neg	neg					
35.000	45	25	21	18	17	16	7	4	3	2	neg	neg	neg	32	20	16	15	14	13	7	5	4	4	1	neg	neg	36	22	18	16	15	14	8	6	5	4	1	neg	neg					


1. Negative break-even prices indicate that the windmill pump set is always preferable to the other energy sources.
2. The "staircase" line indicates the break-even volumes at prevailing energy prices (1978).
3. Lifetime referring to technical lifetime of windmill pump set.

FIG. 5 DIESEL BREAK-EVEN PRICES AS A FUNCTION OF INVESTMENT LEVEL AND TECHNICAL LIFE TIME OF THE WINDMILL PUMP SET AT VARIOUS USEFUL ANNUAL OUTFLOWS




- 5 : Technical lifetime windmill pump set
- Investment windmill pump set \$ 2800,-
- · - · - Investment windmill pump set \$ 1400,-
- - - - Investment windmill pump set \$ 700,-

FIG. 6 PETROL BREAK-EVEN PRICES AS A FUNCTION OF INVESTMENT LEVEL AND TECHNICAL LIFE TIME OF THE WINDMILL PUMP SET AT VARIOUS USEFUL ANNUAL OUTFLOWS



5 : Technical lifetime windmill pump set
 — Investment windmill pump set \$ 2800,-
 - - - Investment windmill pump set \$ 1400,-
 - · - Investment windmill pump set \$ 700,-

FIG. 7 ELECTRICITY BREAK-EVEN PRICES AS A FUNCTION OF INVESTMENT LEVEL AND TECHNICAL LIFE TIME OF THE WINDMILL PUMP SET AT VARIOUS USEFUL ANNUAL OUTFLOWS



5 : Technical lifetime windmill pump set

— Investment windmill pump set \$ 2800,—

- · - Investment windmill pump set \$ 1400,—

- - - Investment windmill pump set \$ 700,—

Table 3.17 Influence of windmill pump set maintenance costs, technical lifetime and investment level on the break-even prices for energy (interest rate 10%) :

Annual useful outflow (m ³)	US \$ 2800			US \$ 1400									US \$ 700												Investment windmill pump set			
	25 years			25 years						10 years			25 years						10 years			5 years			Technical lifetime windmill pump set			
	5% O+M			5% O+M			10% O+M			10% O+M			5% O+M			10% O+M			20% O+M			10% O+M			5% O+M			O + M level
	D ¹	P ²	E ³	D	P	E	D	P	E	D	P	E	D	P	E	D	P	E	D	P	E	D	P	E	D	P	E	
2.000	292	238	264	32	69	71	113	122	131	198	177	194	neg	neg	neg	neg	neg	6	24	64	65	neg	39	37	28	66	68	
5.000	117	95	105	13	28	29	45	49	52	79	71	78	neg	neg	neg	neg	neg	3	10	26	26	neg	16	15	11	26	27	
10.000	58	48	53	7	14	15	23	25	26	40	35	39	neg	neg	neg	neg	neg	2	5	13	13	neg	8	7	6	13	14	
15.000	39	32	35	4	9	10	15	16	17	26	24	26	neg	neg	neg	neg	neg	2	3	9	9	neg	5	5	4	9	9	
20.000	29	24	26	3	7	8	12	12	13	20	18	19	neg	neg	neg	neg	neg	1	3	7	7	neg	4	4	3	7	7	
25.000	23	19	21	3	6	6	9	10	10	16	14	16	neg	neg	neg	neg	neg	1	2	5	5	neg	3	3	2	5	5	
30.000	19	16	18	3	5	5	8	8	9	13	12	13	neg	neg	neg	neg	neg	1	1	5	4	neg	3	2	2	4	5	
35.000	17	14	15	2	4	4	7	7	7	11	10	11	neg	neg	neg	neg	neg	1	1	4	4	neg	2	2	2	4	4	

Note: ¹) D= diesel (US \$cts/l)
²) P= petrol (US \$cts/l)
³) E= electricity (US \$cts/kWh)

Introducing the energy prices in figures 8, 9 and 10 results in the corresponding annual useful outflows required to break-even.

For the energy prices as prevailing in The Netherlands the results are shown in table 3.18.

Table 3.18. Break-even water volumes as a function of investment and maintenance costs

	US \$ cts/liter US \$ cts/kWh	Windmill pump set		
		US \$ 2800	US \$ 1400	US \$ 700
		O + M = 5% (25 years)	O + M = 10% (25 years)	O + M = 20% (25 years)
Petrol	48	9,900	5,500	2,500
Diesel	25	23,200	8,900	1,700
Electricity	7.5	69,900	> 35,000	20,500

In 4 out of the 9 combinations the use of windmill pump sets (annual water demand: 9,502 m³) is profitable.

In case all the potential water of the 2.2 m windmill can be applied (e.g. for the irrigation of 3 crops/year) the desirability of installing windmills increases to 5 out of 9 combinations.

Finally, if the potential water production of a 3 meter windmill could really be used (42,700 m³/annum) the windmill would be preferable to all alternatives.

FIG. 8 DIESEL BREAK-EVEN PRICES AS A FUNCTION OF OPERATION AND MAINTENANCE COSTS OF THE WINDMILL PUMP SET




FIG. 9 PETROL BREAK-EVEN PRICES AS A FUNCTION OF OPERATION AND MAINTENANCE COSTS OF THE WINDMILL PUMP SET





FIG. 10 ELECTRICITY BREAK-EVEN PRICES AS A FUNCTION OF OPERATION AND MAINTENANCE COSTS OF THE WINDMILL PUMP SET



3.8.5. sensitivity to variation of interest rate

The economic analysis took into account an interest rate of 10% per annum in order to calculate the cost of capital. It may be considered that this interest rate is too high as a government might decide to provide credit on soft terms, for instance 6% per annum.

It is also possible that no credit is available at 10% interest and that a farmer who wants to install a windmill will have to pay a higher interest rate, for instance 14%.

The influence of a variation of the interest rate on the break-even prices for energy is analysed in table 3.19.


Table 3.19. Influence of the interest rate on the break-even prices for energy

Useful annual outflow (m3)	Break-even price								
	Diesel (US \$ xts/l)			Petrol (US \$ cts/l)			Electricity (US \$ cts/kWh)		
	interest rate			interest rate			interest rate		
	6	10	14	6	10	14	6	10	14
2000	229	292	363	182	238	303	202	264	332
5000	92	117	145	73	95	121	81	105	133
10000	46	58	73	36	48	60	41	53	66
15000	31	39	48	24	32	40	27	35	44
20000	23	29	36	18	24	30	20	26	33
25000	18	23	29	15	19	24	16	21	27
30000	15	19	24	12	16	20	14	18	22
35000	13	17	21	10	14	17	12	15	19

Note: all pump sets are defined as in the base situation

It follows from this table that variation of the interest rate has a relatively small influence on the feasibility of the windmill pump set. This is due to the fact that the variation of the interest rate was taken into account for the investment in the windmill as well as for the alternative sources of power. The influence of interest variation amounts to some 25% (plus or minus) as compared to the base situation. See also figure 11.

FIG. 11 BREAK-EVEN PRICES OF ENERGY AS A FUNCTION OF INTEREST RATE



— Outflow : 10000 m³
 - - - Outflow : 35000 m³

Annuity factors to convert an investment into an annual equivalent including interest

lifetime in years	6%	8%	10%	12%
1	1.0600	1.0800	1.1000	1.1200
2	0.5454	0.5608	0.5762	0.5917
3	0.3741	0.3880	0.4021	0.4163
4	0.2886	0.3019	0.3155	0.3292
5	0.2374	0.2505	0.2638	0.2774
6	0.2034	0.2163	0.2296	0.2432
7	0.1791	0.1921	0.2054	0.2191
8	0.1610	0.1740	0.1874	0.2013
9	0.1470	0.1601	0.1736	0.1877
10	0.1359	0.1490	0.1627	0.1770
15	0.1030	0.1168	0.1315	0.1468
20	0.0872	0.1019	0.1175	0.1339
25	0.0782	0.0937	0.1102	0.1275
30	0.0726	0.0888	0.1061	0.1241
40	0.0665	0.0839	0.1023	0.1213
50	0.0634	0.0817	0.1009	0.1204

Errata:

page

- 3 Add: 3.8.6. Annuity factors (page 52)
- 8 line 7: change "a" into "or" and "alectricity" into "electricity".
line 11: change "examppte" into "example".
- 10. Add: (at the end of the note) over a head of 13 m.
- 16. Change the formula into:
$$P = \frac{1}{2} \rho v^3 \frac{\pi}{4} D^2 C_p \eta_t \eta_p \quad (W)$$

$$\frac{V=z}{\Sigma} \frac{1}{2} \rho \cdot v^3 \cdot \frac{\pi}{4} \cdot D^2 \cdot C_p \cdot \eta_t \cdot \eta_p \cdot W_d \quad (Wh)$$

$$V=a$$
- 32 Add: (beside figure) "scale"
- 33 Add: (at the top of the page) "3.8.6."