

Unihydro Limited

P. O. Box CT1954
Cantonments, Accra
Tel: 022-410497/8
Fax: 022-410497
Email: unihydro@ghana.com

OYIBI-AMRAHIA AREA FEASIBILITY REPORT

FEASIBILITY STUDIES FOR RURAL PIPED WATER SUPPLY SCHEMES IN GREATER ACCRA REGION (2003)

FINAL REPORT PREPARED FOR

REGIONAL DIRECTOR

COMMUNITY WATER & SANITATION AGENCY

GREATER ACCRA REGION

P.O. BOX 884

ACHIMOTA, ACCRA¹


MARCH 2003

¹UNIHYDRO ACCRA OFFICE: No.3 HOS/20, COMMUNITY 20, ACCRA ABATTOIR ROAD



[Handwritten signature]
19/05

*Water Supply
Engineers*

*Pls by study &
Comments. Discuss
with Water Supply
Advisor & Consultants
and move it to
detailed design &
tender 824 GHAC03.1934P*



UNIHYDRO Limited
WATER INDUSTRY SERVICES, PRODUCTS & SUPPLIES



P.O Box CT1954
Cantonments
Accra, GHANA
Tel:022 410497/8
Fax:022 410497

ATTENTION: Mr. Edem Asimah

15 May 2003

Regional Director
Community Water & Sanitation Agency
Greater Accra Region
P.O. Box 884, Achimota

Dear Sir:

Submission of Final Feasibility Reports
Feasibility Studies, Design, Tendering & Construction Supervision of Rural Piped
Water Supply Schemes in Greater Accra Region

We refer to the contract agreement for feasibility studies in Oyibi-Kpone Seduase-Amrahia and Ashalaja proposed supply areas, and wish to submit our final report on feasibility studies for the following prime communities:

- ◆ Oyibi-Amrahia Supply Area
- ◆ Ashalaja Supply Area

Thanks for your usual co-operation.

For and on behalf of Unihydro Limited

Samuel Asare
Project Engineer

TABLE OF CONTENTS

| | Page |
|--|------|
| 1 INTRODUCTION..... | 1 |
| 1.1 Project Background..... | 1 |
| 1.2 Scope of Feasibility Studies..... | 1 |
| 2 OYIBI/AMRAHIA SUPPLY AREA..... | 2 |
| 2.1 Proposed List of Communities..... | 2 |
| 3 SOCIO-ECONOMIC SURVEY..... | 4 |
| 3.1 Methodology for Socio-Economic Study..... | 5 |
| 3.1.1 Data Collection..... | 6 |
| 3.2 Socio Economic Assessment..... | 7 |
| 3.2.1 Location..... | 7 |
| 3.2.2 Socio-Economic Aspects..... | 8 |
| 3.2.3 Demographic Characteristics..... | 8 |
| 3.2.4 Community Infrastructure..... | 10 |
| 3.2.5 Economic Activities..... | 12 |
| 3.2.6 Local Organization and Fund Raising Activities..... | 14 |
| 3.2.7 Willingness and Ability to Pay..... | 15 |
| 3.2.7.1 Indicator of willingness to pay..... | 15 |
| 3.2.8 Socio-Economic Justification..... | 19 |
| 4 TECHNICAL FEASIBILITY..... | 21 |
| 4.1 Existing Water Supply Situation..... | 22 |
| 4.2 Sustainable Yield Estimate for Oyibi Borehole & Old Saasabi Boreholes..... | 23 |
| 4.2.1 Theoretical Background..... | 23 |
| 4.2.2 Efficiency & Sustainable Yield Status of the Boreholes..... | 24 |
| 4.3 Water Quality Assessment..... | 27 |
| 4.3.1 Results of Laboratory Analyses..... | 27 |
| 4.3.2 Perception and Acceptability of Borehole Water for Mechanization..... | 28 |
| 4.3.3 Acceptability of Borehole Sources for Mechanization..... | 30 |
| 4.4 Water Need Assessment OYIBI-AMRAHIA AREA..... | 31 |
| 4.4.1 Population Forecast..... | 32 |
| 4.4.2 Water Demand Computation..... | 33 |
| 4.4.3 Existing Facilities in Supply Area..... | 34 |
| 4.4.4 Computation of Water Demand..... | 35 |
| 4.4.5 Borehole Source Data..... | 36 |
| 4.4.6 Actual Water Supply Coverage..... | 37 |
| 4.4.7 Feasible Technology Options for Water Supply..... | 38 |

Barcode 19348
Location 824 GHAC03

| | | |
|---------|---|----|
| 4.4.7.1 | Technology Option A: Boreholes with India Mark 2 Hand Pumps..... | 38 |
| 4.4.7.2 | Subsidy Threshold for Boreholes Fitted with Hand pump..... | 39 |
| 4.4.7.3 | Cost Estimate for Boreholes installed with Hand pumps option..... | 40 |
| 4.4.7.4 | Financing of Project-Borehole fitted with Hand pumps..... | 41 |
| 4.4.8.1 | Technology Option B: Piped System based on Mechanized Borehole..... | 42 |
| 4.4.8.2 | Hydraulic Analysis..... | 42 |
| 4.4.8.3 | Service Reservoir..... | 44 |
| 4.4.8.4 | Standpipes..... | 44 |
| 4.5 | Conceptual Design..... | 48 |
| 4.5.1 | Piped System based on Mechanized Borehole..... | 48 |
| 4.5.2 | Cost Estimate for Pipe Scheme..... | 48 |
| 4.5.2.1 | Provisional Capital Investment Cost..... | 48 |
| 4.5.3 | Annual Operation and Maintenance Cost..... | 52 |
| 4.5.4 | Cost Recovery Estimation: Water Tariff Calculation..... | 53 |
| 4.5.5 | Financing of Project- Borehole Mechanization..... | 54 |
| 4.5.6 | The summary of Cost of Technology Options..... | 55 |
| 4.5.7 | Management Options..... | 57 |
| 4.5.7.1 | The Possible Management Options..... | 57 |
| 4.5.7.2 | Community Management..... | 57 |
| 4.5.7.3 | Delegation to a Private Entity..... | 58 |
| 4.5.7.4 | Problem to be Tackled in the case of Community Management System..... | 60 |
| 4.5.7.5 | Advantages and Disadvantages of Private Management System..... | 60 |
| 4.5.7.6 | Contractual Management..... | 61 |
| 4.5.6.1 | The Advantages Concerning the Contractual Relations..... | 61 |
| 4.5.7.7 | Advantages Concerning the Sharing of Responsibilities..... | 62 |
| 4.5.7.8 | Advantages Concerning the Financial Management and Protection of Funds..... | 63 |
| 4.5.7.9 | Management Training..... | 63 |
| 4.5.8 | Recommendations on Management Option..... | 64 |
| 5 | FINDINGS AND RECOMMENDATIONS..... | 65 |
| 5.1 | Socio-Economic Feasibility..... | 65 |
| 5.2 | Technical Feasibility..... | 65 |
| 5.3 | Recommendations..... | 66 |

LISTS OF ANNEXES

| | |
|----------|--|
| ANNEX 1 | Socio-economic Survey Data |
| ANNEX 2 | Pumping Test and Safe Yield Data |
| ANNEX 3 | Water Quality Results |
| ANNEX 4: | Hydraulic Analysis Results for the Transmission Network... |

TABLES

| | | |
|------------|--|----|
| Table 13.1 | Population Forecast For Oyibi-Amrahia Area..... | 33 |
| Table 13.2 | Existing Facilities- Institutions Water Source..... | 35 |
| Table 13.3 | Computation of water demand | 36 |
| Table 13.4 | Summary of Borehole Yield Test and Results..... | 37 |
| Table 13.5 | Cost Estimation of Boreholes..... | 40 |
| Table 13.6 | Subsidy Threshold for Borehole..... | 40 |
| Table 13.7 | Sharing of community contribution towards Borehole with Hand pump construction..... | 41 |
| Table 13.8 | Results of Transmission Network Analysis..... | 43 |
| Table 13.9 | Computation of Service Reservoir..... | 44 |

1 INTRODUCTION

1.1 Project Background

The Greater Accra Region Community Water and Sanitation Programme is implementing the construction of water supply and sanitation facilities in the Ga, Tema, Dangme East and Dangme West Districts under joint funding by the Government of Ghana and the Government of Denmark (Danida).

During the Year 2002 Rural Water Supply Component Drilling Programme several high yielding boreholes were constructed in some communities in Ga district and Tema Municipality. In order to collect borehole discharge data for preliminary decision making regarding the promotion of rural piped water supply schemes based on mechanized or production boreholes the drilling contractor was tasked to undertake long duration pumping tests of five selected high yielding boreholes.

The Community Water and Sanitation Programme, now wishes to determine the optimum usage of the five selected high yielding boreholes, with the view to utilizing them as sources for small rural piped water supply schemes in clusters of communities located around these boreholes. The five main target communities are as follows:

- ◆ Kweiman Area - Ga District (with 1 borehole)
- ◆ Habitat Area - Ga District (with 2 boreholes)
- ◆ Ashalaja Area - Ga District (with 1 borehole)
- ◆ Oyibi Area - Tema District (with 1 borehole)
- ◆ Kpone Seduase - Tema District (with 1 borehole)

The proposed beneficiary communities are mainly rural farming communities with very low level of infra-structural development and standard of living of its inhabitants.

The Community Water and Sanitation Programme, Greater Accra Region, therefore engaged Unihydro Limited to undertake feasibility studies, design and construction supervision of the proposed project.

1.2 Scope of Feasibility Study Phase

The scope of studies to be carried out as part of the feasibility study phase is as follows:

- (i) Field visits to the communities to carry out extended pumping tests on the proposed high-yielding boreholes. During this exercise, the perception of the people on the water quality should be assessed and the GPS co-ordinates of the boreholes and the communities should also be recorded.
- (ii) Carry out detailed interpretation of the results from the extended pumping test with recommendations on the sustainable production or safe yield levels.

- ◆ Proximity to a production borehole with potential for rural piped supplies
- ◆ General indication of interest in having improved water supplies
- ◆ Social relations between the surrounding communities

For instance, Adamorobe is close to Kpone Seduase but was not considered since there is serious land litigation between the people of Kpone Seduase and Adamorobe. Also Adamorobe falls within the Eastern region. Goten is also closer to Kpone Seduase than Amrahia but was not considered because it has a successful borehole fitted with handpump with yield enough for its population.

All the communities near Old Saasabi like Bawaleshie and its cluster communities are also connected to the Dodowa Water supply system and hence were not considered for this project.

3

SOCIO-ECONOMIC SURVEY

3.1 METHODOLOGY FOR SOCIO-ECONOMIC STUDY

The study applied social and economic methodologies. The socio-economic study was executed through the application of multi-dimensional community participatory techniques, which are itemized below:

- Community fora and meetings.
- Household sample survey: Three percent of the total population was randomly sampled and interviewed.
- Specific field investigation.
- Guided transient walk.
- Survey questionnaires on community profiles.
- Direct visual observations
- Household interviews and institutional surveys.

The study thus used multi-dimensional approach to collect data. The interviewers administered the questionnaires.

The target groups selected for the detailed interview were people in the various economic groups. The interview conducted on their economic activities determined their ability and willingness to pay for improved potable water supplies.

The household interview was administered on randomly selected people - three percent of the total population in each community. The interview method makes available precise and detailed information, which supplements what had been provided in the community profile questionnaires. This is because private and personal information that could not be provided on survey questionnaires could be acquired through in-depth interviews.

3.1.1 Data Collection

In collecting data, the investigators and other assistants who were well trained and had prior knowledge in research, administered the survey questionnaires. The interviews were conducted in the local language Ga.

The questionnaire used by the GARCWSP for collecting community information and socio-economic data was reviewed and detailed interview guides added.

Community meetings were held and the people briefed about the study. During these meetings, the survey questionnaires were administered and community information.

Socio-economic information collected:

Present at the meetings were the following:

- ◆ Chiefs, women's leaders and their elders.
- ◆ WATSAN Committee Members
- ◆ Unit Committee members.
- ◆ Assemblymen.
- ◆ Community Workers (Teachers, nurses, caretakers and retired public servants).
- ◆ Opinion leaders.

The following information was collected during household interviews:

- ◆ Economic Activities.
- ◆ Income Level.
- ◆ Expenditure.
- ◆ Ability and Willingness to pay for water.
- ◆ Perception and Acceptability of borehole water for mechanization into pipe system.

To complement data collection efforts of the multi-disciplinary survey team, the technical and the socio-economic studies were undertaken concurrently within a period of three weeks.

All completed questionnaires were coded and edited the day after the interviews for omissions, inconsistencies and mistakes to be corrected. The data was later computerised and tables and statistical functions (where necessary) obtained for analysis by the investigators. All data collection activities were carried out concurrently so as to ensure comprehensive and well-integrated information on the communities.

3.2 SOCIO-ECONOMIC ASSESSMENT

3.2.1 Location

The selected communities for this study are located in Tema district. The communities are located at 0.5km to 6.5km from the main Dodowa road. Oyibi is the nearest (0.5km) whilst Adigon is the furthest (6.5km). Some however are located along the main road and these include the Good News College/Seminary, Valley View University, Malejor and the Amrahia communities. The communities are all concentrated except Adigon, which is a settler and animal rearing community with houses widely dispersed from each other.

These communities are basically rural and homogeneous, made up mainly of people of Ga descent. However, members of Adigon are settlers from Ada while Oyibi also has quarters with residents who hale from different tribes other than Ga. The main languages spoken are Ga, and Twi, though members of some of the communities speak Ada and Ewe well.

3.2.2 Socio-Economic Aspects

(a) Community Leadership

The table below represents the names of the various political leaders as identified by the community representatives.

Table 1: Community Leaders

| Community | Chief | Linguist | Women's Leader |
|-----------------------------|--------------------|----------------------|---------------------------|
| Oyibi | Nii Boketty Bottey | Stephen A. Boquave | Naa Bottey Otiyie (queen) |
| Old Saasabi | Nii Ashitety Amarh | Henry Tettey Adjetey | Victoria Amarh (leader) |
| Kpone Seduase | Nii Nuetty Akpoo I | James Tettey | Akpo Yomo |
| Adigon | Nii Okoh Mensah | John Mantey | Naa Awo (leader) |
| Good News College/ Seminary | - | - | - |
| Valley View Univ. | - | - | - |
| Malejor | Nii Atta Boye | - | - |
| Amrahia | Nii Okoh | - | - |

3.2.3 Demographic Characteristics

(a) Population Distribution

The sex distribution in the communities are presented in Table 2 below:

Table 2: Sex Distribution in the Communities

| Particulars | Oyibi | Old Saasabi | Adigon | Kpone Seduase | Good News Co/Seminary | Valley View University | Malejor | Amrahia | Total |
|-------------|-------|-------------|--------|---------------|-----------------------|------------------------|---------|---------|-------|
| Male (M) | 1176 | 227 | 56 | 227 | 41 | 662 | 70 | 558 | 3017 |
| Female (F) | 1224 | 236 | 59 | 236 | 19 | 298 | 80 | 572 | 2724 |
| Total | 2400 | 463 | 115 | 463 | 60 | 960 | 150 | 1,130 | 5741 |

Reference 2002 Census Population Distribution Rates.

The female population is higher than the male in all the six communities. The male to female ratio is approximately 49:51 of the total population. Based on the household interviews the average number of persons per household ranges between 4 -5. The trend differed in the two institutions where male populations are just about double that of females.

(b) Settlement Types

The communities are classified into three categories of settlement types based on the Community Water and Sanitation Agency (CWSA) guidelines and an institutional category as follows:

- ◆ Rural: Population of 75-2000
- ◆ Peri-Urban: Population of 2001-5000
- ◆ Urban: Population of 5000 and above
- ◆ Institutions

Table 3: Population and Settlement Types

| Community | Population | Settlement Type |
|------------------------|------------|-----------------|
| Oyibi | 2400 | Peri-Urban |
| Old Saasabi | 463 | Rural |
| Kpone Seduase | 463 | Rural |
| Good News Co/Seminary | 60 | Institution |
| Valley View University | 920 | Institution |
| Malejor | 150 | Rural |
| Amrahia | 1,130 | Rural |
| Adigon | 115 | Rural |

About 75% of the communities are rural with poor infrastructure base while only one. Oyibi can be described as peri-urban based on the Community Water and Sanitation Guidelines.

3.2.4 Community Infrastructure

Based on the survey carried out, the following facilities were identified in the various communities.

Table 4: Community Facilities

| Community | Hlth Inst. | Sch | Water | Makt | Rd | Post Office | Elec-tricity | Church | Police Station |
|---------------|------------|-----|-------|------|-----|-------------|--------------|--------|----------------|
| Oyibi | Nil | Yes | Yes | Nil | Yes | Nil | Yes | Yes | Nil |
| Old Saasabi | Nil | Nil | Yes | Nil | Yes | Nil | Nil | Yes | Nil |
| Kpone Seduase | Nil | Yes | Yes | Nil | Yes | Nil | Nil | Yes | Nil |
| Good News Co | Nil | Yes | Yes | Nil | Yes | Nil | Yes | Yes | Nil |
| Valley View | Nil | Yes | Yes | Nil | Yes | Nil | Yes | Yes | Nil |
| Malejor | Nil | Nil | Yes | Nil | Yes | Nil | Nil | Yes | Nil |
| Amrahia | Nil | Yes | Yes | Nil | Yes | Nil | Yes | Yes | Nil |
| Adigon | Nil | Yes | Yes | Nil | Yes | Nil | Nil | Nil | Nil |

There are no communal latrines in Adigon, Malejor and Amrahia hence the people defecate in the surrounding bushes, however there are few private/household latrines in the Malejor and Amrahia communities. Old Saasabi and Kpone Seduase have public latrines while Oyibi has both public and private household latrines. The two institutions: Good News and Valley View University, in addition to Malejor and Amrahia communities are located on the main Dodowa road while the rest are also accessible by feeder roads.

The main sources of water supply are Boreholes, streams, ponds, dams, tanker services and occasionally rain harvest. All the boreholes drilled at Adigon were dry hence the people depend solely on dams, which they share with animals. Oyibi and Old Saasabi and Kpone Seduase have high yielding borehole. And these sources serve as the main source of water to the people. The two institutions, Malejor and Amrahia communities depend on tanker services for drinking water supply.

None of the communities has a health post or a police station; they mostly depend on the facilities at Dodowa and Adenta.

Oyibi. Amrahia and the two institutions are connected to the national grid while Adigon has not erected poles. Meanwhile Old Saasabi. Kpone Seduase and Malejor have erected poles but the installation of the physical infrastructure for the power supply is on-going.

Oyibi. Kpone Seduase. Malejor. Amrahia and Adigon have schools while Old Saasabi depends on the educational facilities at Oyibi. Below is the breakdown of educational facilities available in the four communities and the available population data at the time of the survey.

Table 5: Community Schools and their Populations

| Community | Population | JSS | Prim | Kindergarten | College/Uni v |
|-------------------|------------|-----|------|--------------|------------------|
| Oyibi | 80 250 100 | Yes | Yes | Yes | - |
| Kpone Seduase | - | Yes | Yes | Yes | - |
| Good News College | 50 | Nil | Nil | Nil | Yes |
| Valley View Univ. | 920 | Nil | Nil | Nil | Yes |
| Malejor | 15 | Nil | Nil | Yes | - |
| Amrahia | - | Yes | Yes | Yes | - |
| Adigon | 53 18 | Nil | Yes | Yes | - |

(a) Type of Houses

The houses in these communities are a combination of mud with thatch roofs and cement blocks with aluminium sheet roofs. Most of the houses at Adigon are made from mud, which may be due to the fact that they are settlers while Oyibi. Kpone Seduase. Old Saasabi. and Malejor have a combination of the two types of houses. In addition Oyibi has a quarters built by a private developer, which is situated about 600m away from the main community. Part of Amrahia and the quarters at Oyibi have modern structured houses built with cement and roofed with tiles or iron sheet.

(b) Space Availability for New Projects

There is enough space within the communities for the construction of both individual household and communal water supply and sanitation facilities without any problems.

The chiefs and elders in all the communities have agreed to make land available for the purposes of putting up reservoirs and standpipes.

However, the Community Water and Sanitation Agency should obtain permission from the Ghana High Way Authority so as to enable the contractor cut across roads when the need arises.

3.2.5 Economic Activities

The predominant occupation for both men and women are trading and farming. Women do trading, dressmaking and also provide services such as hair dressing as supplementary occupations. Some buy the farm products from the men for sale at Dodowa and Madina markets. Some men also serve as consultants for land sales, masons/foremen at building sites, carpenters and drivers as supplementary activities.

Out of the six communities under study, four (Oyibi, Kpone Seduase, Adigon and Old Saasabi) have been selected for detailed surveys on the economic activities available and studies on the ability and willingness of the community people to pay for water. Malejor, Amrahia and the two institutions currently depend on tanker services at a very high cost, hence one can comfortably presume that they will be willing and can afford to pay for water. However, the people's acceptability of the borehole source for mechanization into pipe system was carried out on all the communities in the coverage area. The following are findings made on the detailed household survey.

Table 6: Occupational Distribution

| Occupation | Oyibi | | Old Saasabi | | Adigon | | Kpone Seduase | |
|----------------------|-------|------|-------------|------|--------|-----|---------------|------|
| | No | % | No | % | No | % | No | % |
| Farming | 5 | 6.9 | 7 | 46.7 | 3 | 30 | 2 | 14.3 |
| Trading | 16 | 22.2 | 3 | 20.0 | 1 | 10 | 4 | 29 |
| Civ/Pub Servants | 10 | 13.9 | 0 | 0.0 | 1 | 10 | 0 | 0 |
| Farming trading | 14 | 19.4 | 5 | 33.3 | 2 | 20 | 3 | 21.4 |
| Beautician Farming | 5 | 6.9 | 0 | 0.0 | 0 | 0 | 1 | 7.14 |
| Labourer land dealer | 3 | 4.2 | 0 | 0 | 0 | 0 | 0 | 0 |
| Artisan Farming | 18 | 25 | 0 | 0 | 3 | 30 | 4 | 29 |
| Trading Artisan | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| Unemployed | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 72 | 100 | 15 | 100 | 10 | 100 | 14 | 100 |

It must be stressed here that almost every member of these communities do some farming except those in full time white colour jobs. The results of the survey indicate that most of the respondents engage in subsistence farming as their secondary occupation.

There are also skilled labourers such as artisans, carpenters, masons, auto mechanics and drivers etc who will be very useful for this project.

3.2.6 Local Organization and Fund Raising Activities

(a) Local organization

There are well-organized groups in the communities that can be used for community mobilization and dissemination of information. These groups include unit committees, church groups, occupational associations, resident associations (as in case of Oyibi Quarters), school committees and PTA (where applicable).

Out of the four communities, only Old Saasabi has a youth association resident in Tema which contributes to development projects through cash donations. However, there are also some individuals in the four communities who contribute cash and building materials towards development projects. Meanwhile in the communities where there are no resident groups outside, members undertake all developmental projects mainly through the contributions of residents in the communities.

(b) Fund Raising Activity

(i) Fund Raising & Communal Labour

The communities have the requisite organizational capacity to undertake development projects. Funds are raised through community work, levies and proceeds from Traditional Council Loyalties (at Oyibi where the levy system does not work). Some individuals who hail from the communities also contribute funds towards local developmental projects.

Communal labour is usually organized on Sundays and Tuesdays for Oyibi, Fridays in Adigon and Kpone Seduase, and Saturdays only for Old Saasabi to provide essential services needed in the communities.

Most of the community members are active and have acquired some experience in community development projects such as the construction of schools, water projects and are contributing toward grid electricity connection. They are therefore willing to participate in the project.

(ii) WATSAN Committees

There are WATSAN Committees in all the communities. These committees are very active and much concerned about their water problems. Members are very enthusiastic and have expressed their interest and acceptance of the mechanization of the high yielding boreholes into pipe system.

3.2.7 Willingness and Ability to Pay

3.2.7.1 Indicators of willingness to pay

The willingness and the ability of people to pay for water was determined by the following factors:

- Income and expenditure levels
- Respondents view on the need to contribute financially to project
- Respondents view on the benefits of scheme

(a) Income and Expenditure levels

The main economic activities in these communities are farming (which also include rearing of animals in Adigon) and trading. The bulk of the income for farmers is realised in the harvesting period, which is usually on annual basis. Animal rearing community like Adigon also stores its wealth in herds of cattle and sheep. This situation will greatly affect their contribution towards the water scheme. Thus, their water demand during the time between growing new crops and harvesting could reduce.

However, most traders though also farm and harvest annually, also buy from others to sell. And since there is no particular one period for harvesting all crops, they are likely to maintain their volume of sales though it may fluctuate occasionally. The trend of the income and expenditure levels of the communities is presented below. This implies that traders may not have any problem in relation to the regularity of inflow of income and hence their ability to pay for water. Therefore their demand for water is not likely to reduce.

The income and the expenditure analysis are based on the **median income level analysis** and its distribution in the communities is as follows:

Table 7: Income and Expenditure Distributions

| Community | Median Income/month (c) | Median Expenditure/month (c) |
|---------------|-------------------------|------------------------------|
| Oyibi | 825.000 | 565.000 |
| Old Saasabi | 420.000 | 330.000 |
| Kpone Seduase | 519.000 | 355.000 |
| Adigon | 450.000 | 385.000 |

The median household monthly income for Old Saasabi and Adigon are c420.000 and c450.000. Kpone Seduase c519.000 while that of Oyibi is c825.000, which is about twice that of its cluster communities. The differences between the values of income at Oyibi and the other communities may be due to the fact that most of the people at Oyibi earn fix incomes and could easily determine it, which was not possible in the farming communities. Oyibi is the busiest and the center of activity in the area hence its high-income level is not a surprise. The occupations, which serves as the source of the peoples income have been compiled and presented in Annex 1.

The expenditure levels however vary with income: the higher the income, the higher the expenditure levels. The range is between c565.000- c330.000. The low level of expenditure compared to income could be due to the fact that household income is mainly spent on the accompaniments which are not too costly. Others like dough and vegetables

are taken from the farm on which little is spent. The next item of expenditure identified, which is school fees is low at Adigon, Old Saasabi, Kpone Seduase and Oyibi main community. However the story is different in the Oyibi Quarters where some people send their children to schools outside the town and pay higher school fees. Some however have their children in tertiary institutions and pay high fees. (Refer to Annex 1 for detailed breakdown of their expenditure).

From the studies conducted, it was realized that, with the exception of Adigon, which still depends on dams, three other communities depend on boreholes for potable water supply in the area. The borehole water is sold at Oyibi and Kpone Seduase for c100 per 18-liter bucket. There are always queues at the borehole sites since the water sources (thus one working borehole in each community) are not enough for the population. The Oyibi quarters is connected to the Ghana Water Company main line from Kpong. However, the water does not flow regularly and has stopped flowing for the past 6 months. Residents buy water from Dodowa and occasionally depend on the borehole at Oyibi.

Old Saasabi residents fetch the borehole water free of charge hence at Old Saasabi and Adigon records could not be taken on the expenditure on water. In Adigon the inability to take record of expenditure on water is due to the fact that most of the community members depend on unwholesome water from a dam on which they pay no money.

The people have therefore indicated that water is a high felt need and will be willing to pay for it. Based on the studies, an average of 6.3% of their income will be spent on water which is encouraging (refer to table 8).

The percentages of income the people are willing to pay on water in the various communities are presented in Table 8 below.

Table 8: Distribution of Percentage of Income to be spent on Water

| Community | % Average income to be spent on Water |
|------------------|--|
| Oyibi | 5 |
| Old Saasabi | 6 |
| Kpone Seduase | 6.5 |
| Adigon | 7.5 |
| Average | 6.3 |

(b) View on Why Contribute Financially towards Project

A large proportion of the respondents, about 42% in the household interviews indicate that there is a need to contribute financially towards the proposed project for maintenance purposes. There was also a very popular statement as "ke noko fitee esane asa": meaning when part of the system is broken down, it would have to be repaired. Consequently, about 53% indicated that money must be contributed toward repair and procurements of spare parts.

In addition, about 5% also identified the fact that the initial capital for water projects are huge and the government alone cannot afford it, so there is a need for community members to contribute in cash towards the initial investment. There is therefore the need to pay some money for water consumed. It is therefore obvious that the people appreciate the scheme and are willing to contribute towards the success of the project.

(c) Benefits of scheme

Among the benefits mentioned by the beneficiaries are as follows: good health, save of time and reduction in energy input. About 39% of the respondents stated good health. Others, 14% stated that the new system would help save the long hours used in search of water for other productive ventures. In the view of the second group, it will help reduce the burden of walking long distances to fetch water for domestic upkeep, regarded as women's responsibility. The third group 55% stated reduction in energy required in

the high prices they pay for tanker services and the long distances the people have to travel to fetch water. the women and children especially use long hours of their day in meeting their water requirements. In addition to the need expressed above, the project is technically feasible and the communities are willing and have the capacity to pay for the provision of potable water.

The communities' concerns also stem from the fact that, they believe it is only when they are healthy, that they can work towards the development of their families and the communities as a whole.

It can therefore be concluded that, the people of the communities in the Oyibi/Amrahia Rural Water Supply area see the provision of potable water as one of their highly felt needs and are also willing to contribute both human and material resources towards the achievement of this goal. This situation justifies the communities to be beneficiaries of the GAR-CWS Rural Water Supply Programme.

The implication is that provision of potable water to the communities will reduce the high incidence of water related diseases, loss of time for productive agricultural and school hours used in fetching water and bring about improved community health and increased productivity. The communities are therefore eager to contribute towards the provision of potable water. This, they said will save them the time and money spent in the treatment of water related diseases.

4 TECHNICAL FEASIBILITY

4.1 EXISTING WATER SUPPLY SITUATION

Prior to the point source water supply intervention under the Danida funded programme there was no safe and regular water supply facility in the Oyibi Supply area. The main sources of water are:

- ◆ Oyibi – 1 abandoned borehole(salinity problem), standpipe with occasional water flow(last water flow was 6 months ago), and the new borehole constructed as part of the Danida funded programme
- ◆ Old Saasabi – 1 seasonal pond which is very turbid and the new borehole constructed under the Danida funded programme
- ◆ Adigon – 1 dam which is very turbid and also shared with livestock.

4.2 Sustainable Yield Estimate for Oyibi Borehole & Old Saasabi Boreholes

4.2.1 Theoretical background

The sustainable yields of the Borehole No. BH1 has been estimated using the approach outlined in the CWSA "Guidelines for Mechanised Boreholes" developed by the Volta Region Community Water Supply Programme. The spreadsheet as used in this analysis has been modified by the Greater Accra Region CWSA Small Town Hydrogeology Team. Considerations such as seasonal water level decline, sensitivity to storativity values and well efficiency have been included in the analysis.

The method uses the Modified Nonequilibrium Equation (Cooper & Jakob, 1946) to estimate the maximum sustainable yield that each well can be pumped in order to develop a pumping water level that does not exceed the maximum allowable drawdown in the well after 300 days of pumping. It is assumed that recharge occurs during the remaining 65 days of the hydrological year.

The maximum sustainable yield at different intermittent pumping rates is estimated by applying the Modified Nonequilibrium Equation to two imaginary wells that simulate the effect of different pumping cycles.

The method is highly theoretical, and suffers from a number of weaknesses including:

- The well efficiency can be only roughly estimated from the step pumping test: calculations based on theoretical drawdown compared to actual drawdown require storativity and effective well radius estimates that can lead to large errors.
- In order to estimate the maximum allowable drawdown it is necessary to know the maximum allowable pumping level as well as the seasonal water level decline. The latter requires detailed groundwater monitoring data of the area, which is not easily available.
- The effective well radius of a pumping well can exceed the actual well radius and is difficult to quantify. Even small changes to this distance can have big impacts on the maximum sustainable yield. The effective well radius was assumed to be equal to the drilled radius of the borehole.
- The storativity can only be determined from pumping tests with observation well data, which were not available in this analysis. Reported minimum and maximum values of 0.005 and 0.03 respectively have been used to evaluate different scenarios.

The values of respective sustainable yields are rough estimates. Every borehole should be monitored in shorter recurrences (e.g. on a monthly basis) in the first few years of scheme operation to verify the accuracy and/or reliability of the determined

values. In the event that future monitoring reveals over or under-estimation of the values appropriate adjustments should be done accordingly. Against a backdrop of realistically variable parameters like effective well radii (especially in fracture aquifers), relatively conservative values of sustainable yields have been chosen.

In arriving at the final choice of sustainable yields for different boreholes, caution has been taken not to exceed constant test discharge rates. Well efficiencies decrease with increase in discharge rates, and it is possible to encounter massive drawdowns, which were hitherto unknown. In the event of dewatering of fracture or water ingress zones, sharp water level decline may result and reflect a less productive groundwater regime.

In the evaluation of constant discharge pumping tests, late data has been given higher credence, as this is more reliable for interpolation to determine future aquifer responses. Sight should not be lost of that fact that the key reason for long term pumping test is to determine probable occurrences of barrier or recharge boundaries that reflect different groundwater regimes which could be lost on short term tests and give rise to erroneous predictions. Basing evaluation of constant discharge pumping tests on mid-term data may yield erroneous well efficiencies as well as sustainable yields.

4.2.2 Efficiency & Sustainable Yield Status of the Boreholes

Well efficiency estimates from the step test as compared to a ratio of calculated to measured drawdown show significant disparity (70%, 20% and 18% respectively). The low efficiency values have been used to determine sustainable yields (this would give the most conservative estimate).

Efficiencies compare favourably and consequently show similar sustainable yields.

Table 11. 1 Summary of Step Pumping Test Results

| Step | Parameter | Oyibi BH1 | Old Saasabi BH1 | Kpone Seduase BH1 |
|---|------------------------------|-----------|-----------------|-------------------|
| 1 | Discharge (m ³ d) | 216.0 | 158.4 | 172.8 |
| | Drawdown (m) | 19.5 | 3.6 | 7.5 |
| | Well Losses (%) | 24.08 | 47.35 | 42.86 |
| 2 | Discharge (m ³ d) | 259.2 | 201.6 | 216 |
| | Drawdown (m) | 24.3 | 5.4 | 10.4 |
| | Well Losses (%) | 27.57 | 53.37 | 48.39 |
| 3 | Discharge (m ³ d) | 288 | 259.2 | 316.8 |
| | Drawdown (m) | 27.8 | 8.10 | 18.6 |
| | Well Losses (%) | 29.72 | 59.54 | 57.89 |
| 4 | Discharge (m ³ d) | 316.8 | 316.8 | |
| | Drawdown (m) | 31.5 | 11.2 | |
| | Well Losses (%) | 31.75 | 64.27 | |
| Estimated Transmissivity (m ² d). Logan (1964) | | 18.0 | 18.0 | 49.2 |
| Efficiency for constant discharges | | 0.70 | 0.70 | |

Table 11.2 Summary of Input Data for Sustainable Yield Calculations

| Parameter Description | Oyibi | Old Saasabi | Kpone Seduase |
|-------------------------------------|--------|-------------|---------------|
| Borehole ID | BH1 | BH1 | BH1 |
| Depth(m) | 71 | 45 | 54 |
| Well Diameter (inch) | 8.5 | 6.5 | 8.5 |
| Discharge Rate(l/min) | 200 | 220 | 180 |
| SWL(m) | 20.31 | 13.4 | 5.32 |
| Duration of Pumping(min) | 4320 | 2880 | 2880 |
| Drawdown at end of test | 29.83 | 29.79 | 15.26 |
| Drawdown per log cycle | 0.8186 | 0.4158 | 0.5241 |
| Maximum pumping water level(m) | 54 | 29.0 | 37 |
| Transmissivity(m ² /day) | 64.39 | 139.42 | 90.5 |
| Pumping setting(m) | 60 | 33 | 44 |

Table 11.3 Summary of Sustainable Borehole Yield Estimates

| Parameter | Oyibi BH 1 | | Old Saasabi BH 1 | | Kpone Seduase BH 1 | |
|--|-------------------|-------------------|-------------------|-------------------|--------------------|-------------------|
| | m ³ /h | m ³ /d | m ³ /h | M ³ /d | m ³ /h | M ³ /d |
| Estimated Sustainable Yield at continuous 24 hours pumping per day | 9.4 | 225.6 | 12.4 | 297.6 | 14.9 | 357.6 |
| Estimated Sustainable Yield at intermittent 12 hours pumping per day | 10.8 | 129.6 | 12.5 | 150.0 | 10.0 | 120.0 |
| Constant discharge rate | 12 | 288 | 13.2 | 316.8 | 10.8 | 230 |

4.3 WATER QUALITY ASSESSMENT

4.3.1 Results of Laboratory Analyses

This assessment of water quality results is based upon the new production boreholes at Oyibi, Old Saasabi and Kpone Seduase. All the physico-chemical results for all the water sample are presented in Annex 3.

(a) Physical parameters

The borehole sources showed pH values of 5.7-6.9. The Old Saasabi borehole source has a pH value which falls within the acceptable guideline range whereas the Oyibi and Kpone Seduase boreholes show a lower pH. The conductivity values were also 1850 μ S/cm for the Oyibi BH1, 1006 μ S/cm for the Old Saasabi BH1 and 609 μ S/cm for Kpone Seduase BH1.

The boreholes also showed low turbidity values well below the guideline value. The apparent colour, total suspended solids and total dissolved solids values were lower than the WHO (1993) recommended guideline values and therefore very acceptable.

(b) Chemical parameters

The chemical quality of the borehole source is generally acceptable for potable purposes. The chloride concentrations of the borehole sources are Oyibi BH1(240mg/l), Old Saasabi BH1(98.6mg/l) and Kpone Seduase(99.3mg/l); the chloride value for the Oyibi BH1 is close to the guideline limit of 250mg/l indicating a potential for increasing salinity with long-term pumping. On the other hand, the chloride level in the other boreholes is very promising.

(c) Nutrients

The nitrate levels of 9.8mg/l(Oyibi BH1), 0.02mg/l(Old Saasabi BH1) and 0.01(Kpone Seduase BH1) far below the WHO (1993) recommended guideline limit of 50 mg/l for drinking water.

(d) Trace metals

The iron and manganese levels in the boreholes was were well below the respective guideline values.

(e) Remarks

The physical and chemical quality of the borehole sources is generally acceptable for potable purposes. However the Oyibi borehole showed a potential for increasing salinity and may not be very suitable as a mechanized borehole to serve the supply area. The Old Saasabi and Kpone Seduase boreholes showed quality parameters that were very promising and can be considered for use as mechanized boreholes to serve the supply area.

(b) **View on the Cost, Time and Energy used in Drawing Water**

On cost, time and energy required to draw the available water, members took into consideration the expenses incurred to get potable water, number of hours spend in queues waiting for their turn, the long distance they have to travel to get water and the energy to be exerted in fetching. Below is the collation on their views.

Table 12.2: Views on Cost, Time and Energy used in Drawing Water

| Sources Available | Oyibi | | Old Saasabi | | Adigon | | Kpone Seduase | | Malejor | | Amrahia | |
|-------------------|-------|---|-------------|---|--------|--|---------------|---|---------|---|---------|---|
| | No | Energy/Time Spent | No | Status | No | Status | No | Status | No | Status | No | Status |
| Pond Dugouts | 3 | Outside the Comm. Carry water from long distances | 2 | Outside the Comm. Carry water from long distances | - | - | 1 | Outside the Comm/ Carry water from relatively long distances | - | - | - | - |
| Dam | - | - | - | - | 1 | Outside the Comm Carry water from long distances | - | - | 1 | Outside the Comm/ Carry water from long distances | 1 | Outside the Comm. Carry water from long distances |
| Tanker Service | - | - | - | - | - | - | - | - | 1 | Very expensive. Wait sometimes for days for water | 1 | Very expensive Wait sometimes for days for water |
| Pipe | 1 | Located in houses (quarters) but now drive long distance to Dodowa to fetch water | - | - | - | - | - | - | - | - | - | - |
| Borehole | 1 | Within Community difficult to pump-energy intensive waste time in long queue | 2 | Within Community difficult to pump-energy intensive | 2 | All Not in use | 2 | Only one working- Within Community / difficult to pump-energy intensive/ waste time in long queue | - | - | - | - |

4.3.3 Acceptability of Borehole Sources for Mechanization

(a) Community Stand Point

In the survey carried out on the acceptability of the community people on mechanization of borehole water into a pipe system to serve them, the people made the following decisions:

Based on the views presented above, all the WATSAN committees and about 98% of members selected in the three communities have perceived the borehole water as the most reliable and free from germs compared to the others currently available. They also indicated that since the borehole is the most reliable and purest source of water but requires a lot of energy to draw, they would be very grateful if the programme could go ahead and mechanize it. This they stressed would make the safe water easily accessible to the young and especially elderly in the communities who cannot go through the strenuous process of pumping.

However, 2% (mostly from Oyibi) of all those sampled complained about the salty nature of their borehole water and suggested that the water for the pipe system be drawn from another source or from the Volta Lake to enable them also enjoy the pleasant taste those in the cities enjoy.

(b) Water Quality Stand Point

From the stand point of water quality results the borehole source has been assessed to be suitable for potable use by the communities. All the major quality parameters showed values that were below the WHO guideline values except the chloride and conductivity values for the Oyibi BHI: the Oyibi borehole may be prone to salt water encroachment during long term pumping as part of a piped water supply scheme. The Kpone Seduase and Old Saasabi boreholes show very promising water quality results and can therefore be considered as the main sources for the proposed water supply scheme.

4.4 WATER NEED ASSESSMENTS: OYIBI –AMRAHIA AREA

Oyibi-Amrahia supply constitutes communities around two productive boreholes located at Kpone Seduase and Old Saasabi proposed for mechanisation. The assessments of the water need of the communities are based on per capita consumption of 20lpd and the existing water system facility in the communities. The communities within the acceptable radius of the two borehole sources forming the Oyibi-Amrahia water supply scheme is presented below;

- Old Saasabi
- Oyibi/Oyibi Estate
- Kpone Seduase
- Good News Seminary
- Valley View University
- Malejor
- Amrahia

The location of the communities is presented in figure 1 below.




Figure 1: Location Map of Proposed Communities for Borehole Mechanisation

The selected communities for this study are all located in Tema district. Kpone Seduase community is 1.5 km from the main Accra Dodowa road. Oyibi, Good News Seminary, Valley View University, Malejor and Amrahia are all located about (0.5km) along the Accra-Dodowa road.

Adigon, which is the furthest (6.5km), is a settler and animal-rearing community with houses widely dispersed from each other and is relatively closer to Appolonia. The distance from Adigon to Appolonia is estimated to be 500m. Appolonia is connected to GWCL pipeline and therefore the possibility of connecting Adigon to Appolonia water distribution network will be more cost effective than the Oyibi-Amrahia proposed mechanisation provided the human factors and technical factors indicate success.

Mensah Bar and Kpone Bawleshie are connected to GWCL pipeline from Dodowa with adequate public standpipes located within the communities. Adombre is located in the Eastern Region and therefore does not form part of this scope.

4.4.1 Population Forecast.

The population estimation of the study area was carried out during the feasibility study stage. The breakdown of the projected 10-year forecast is presented as **Table 13.1**. The average growth rate of 2.8 % was adopted for the supply area.

This stem from the fact that the average inter-censal annual growth rates recorded over the periods for the communities in the region ranges from 1.1% to 11.5% (refer to Unihydro baseline studies, 1999 and Keseve Extension Water supply Design Report, 2003)

Over the same period the Greater Accra Region recorded an average annual growth rate of 4.4%. The average annual growth rates of the supply area over the two census periods and that of the average Regional growth rate therefore vary significantly. This has been reported to be largely due to the very high growth rates recorded by the fishing communities and urban migration.

To provide a more realistic population forecast over the design period therefore, a most likely annual growth rate of 2.8% estimated as the mean of the community's average annual growth rate over the period from 1970 to 2000 and that recorded for the Region, have been adopted for the

supply area. The recorded population of each of the communities in year 2000 has therefore been projected.

The population forecasts have been carried out for 5year time horizons, ie for years 2002, 2007, and 2012 results is presented in Table 13.1 below;

Table 13.1 Population Forecast for Oyibi –Amrahia Area

| SUPPLY AREA | Community | Present Population 2002 | Avg. Growth Rate | Regional Growth Rate % | Population Forecast | | |
|--------------|------------------------|-------------------------|------------------|------------------------|---------------------|---------------------|----------------------|
| | | | | | 2002 P ₀ | 2007 P ₅ | 2012 P ₁₀ |
| Oyibi Area | Old Saasabi | 463 | 2.8 | 4.4 | 463 | 532 | 610 |
| | Oyibi/Estate | 2400 | 2.8 | 4.4 | 2400 | 2755 | 3163 |
| | Kpone Seduase | 463 | 2.8 | 4.4 | 463 | 532 | 610 |
| Amrahia Area | Good News Seminary | 60 | 2.8 | 4.4 | 60 | 69 | 79 |
| | Valley View University | 960 | 2.8 | 4.4 | 960 | 1102 | 1265 |
| | Malejor | 150 | 2.8 | 4.4 | 150 | 172 | 198 |
| | Amrahia | 1130 | 2.8 | 4.4 | 1130 | 1297 | 1489 |
| | TOTAL | | | | 5,626 | 6459 | 7415 |

4.4.2 Water Demand Computation

The water demand is calculated as,

$$\text{Water Demand (Q)} = P_0 (1 + b)^n * q * (1 + L_L) \dots\dots\dots(1)$$

Where;

P₀ = Present population

b = Population growth rate = 2.8%

n = design period = 10 years

q = a per capita water demand = 20lpd

L_L = Provision for physical losses (due to leakage) = 20%

Present Water Demand

For the present situation, n = 0

Present Water Demand $Q_p = P_o * q * (1 + L_L)$(2)

$Q_p = P_o * 20 * (1 + 20\%)$.

$Q_p = P_o * 20 * (1.2)$

$Q_p = 24 P_o$.

Projected Water Demand

$Q_T = P_o (1 + b)^n * q * (1 + L_L)$ (3)

$Q_T = P_o (1 + 0.028)^{10} * 20 * (1 + 0.2)$.

$Q_T = P_o * (1.3) * 20 * 1.2$

$Q_T = 31.63 P_o \equiv \text{say } (32 P_o)$

This describes CWSA criteria for design of water supply systems in small communities that is a community whose population is less than 5000 people. It also presents the basic service maximum distance of 500m and one standpipe serving 600 people.

4.4.3 Existing Facilities in Supply Area

The existing facilities in the supply area were recorded during the feasibility studies. The summary is presented as Table 13.2 below.

Table 13.2 Existing Facilities:- Institutions and Water Sources

| No | Description | Calculation | Old Saasabi | Oyibi and Estate | Kpone Seduase | Good News Seminary | Valley View Univ. | Malejor | Amrahia |
|----|-----------------------------------|---------------|---|-----------------------|--|--------------------|-------------------|-----------------|-----------------------|
| 1 | No. of Institution in supply area | Schools | Nil | 3 but on one compound | 1 | Nil | Nil | Nil | 2 but on one compound |
| | | Health Centre | Nil | Nil | Nil | Nil | Nil | Nil | Nil |
| 2 | Water Source | Boreholes | 1 fitted with Hand Pump- (proposed for mechanisation) | 1 bh but salty | 1 HP broken down 1 proposed for mechanisation | Nil | Nil | 1 BH turn salty | Nil |
| | | Dam | Nil | Nil | Nil | Nil | Nil | Dam | Nil |
| | | Ponds | Dries up/turbid | Dries up/ Turbid | Yes | Nil | Nil | Nil | Nil |
| | | Pipe | Stopped flowing for 6 months | Nil | Nil | Tanker services | Tanker Services | Tanker Services | Tanker services |

4.4.4 Computation of Water Demand

The computation of the water need of the beneficiary communities is based on the following service levels and criteria;

1. per capita (present population) consumption = 24 litres /person/day
2. per capita (Projected population) consumption = 32 litres /person/day
3. Maximum No. of users (present population) per borehole = 300
4. Maximum walking distance to a water point = 500m
5. Design life for the water supply (n) = 10 years
6. Population growth rate = 2.8%
7. Number of Water Users per standpipe = 600

The water need is calculated as follows;

1. Daily Present Water Demand (DPWD) , $Q_p = 24 P_o$
2. Daily Total Water Demand (DTWD) , $Q_T = 32 P_o$
3. Daily Residual Water Demand (DRWD) , $Q_R = (P_o - P_s) * 32 \text{ lpd}$

Where P_s is the population served by existing boreholes fitted with hand pumps

Disadvantages

- ◆ Boreholes fitted with hand pumps are expensive to construct and operate
- ◆ The India MK 2 pump can only be repaired by a hand pump mechanic who would have to be paid for his or her service.
- ◆ If the hand pump fails no water can be drawn from the borehole until it is repaired .
- ◆ Water from boreholes may contain minerals, which may give an unacceptable taste.

Maintenance requirement

Two caretakers preferably a male and a female for each borehole will have to be chosen from among the community to carry out the following routine inspection and Maintenance.

1. Make/sure drainage is adequate with no stagnant water around the borehole.
2. To repair/plaster the cement apron or drain when cracks or other damages occurs.
3. Keep the surrounding area free of overgrown vegetation.
4. Check pumps regularly for wear or failure of pump parts, particular when the flow of water decreases or stops.
5. **Nira AF-85 pump**; Replace worn out parts and keep bolts tight.

India MK 2 pump; Keep pump chain well greased and all nuts and bolts tight.

Most of the repairs can only be carried out by hand pump mechanic.

To prevent misuse of the pump, particularly by children;

Keep record of repairs and report problems and breakdowns to the WATSAN Committee and collect user fees, (if the community decides to do this)

4.4.7.2 Subsidy Threshold for Boreholes Fitted with Hand Pumps

The subsidy Threshold is the lifetime cost of the borehole /handpump option of water supply which would be required to provide a basic service level in the community.

The purpose of the Subsidy Threshold calculation is to determine the amount of subsidy that a community can receive under the CWSA Rural Water Supply Programme. The Program guideline is as follows:

- The community shall contribute 5% of the approved project cost if it is not more than the calculated Subsidy Threshold.
- If the project cost is more than the Subsidy Threshold the community will pay 5% of the cost equivalent to the subsidy threshold and 50% of the excess cost above the Subsidy Threshold.

4.4.7.3 Cost Estimation for Boreholes installed with Handpump Option

The estimate for the cost of borehole construction is presented as Table 13.5 below;

Table 13.5 Cost Estimation for Boreholes

| Assumptions | |
|---|--|
| Basic Service Level | 1 Borehole fitted with Hand Pump for 300 Users |
| O&M Cost Estimate | 10 Years Projection |
| Average Borehole Depth | 45 Meters |
| Success Rate | 67 Percent (%) |
| Unsuccessful Rate | 33 Percent (%) |
| Construction Cost for Successful Borehole | \$100.00 |
| Construction Cost for Unsuccessful Borehole | \$75.00 |
| CONSTRUCTION COST OF A NEW BOREHOLE | AMOUNT (\$) |
| Construction of 45m Depth (45*100) | 4,500.00 |
| Construction of a Platform including Material Transport | 950.00 |
| Installation of Ghana Modified India Mark 2 Pump | 2,500.00 |
| Allowance for abandoned Borehole (45*75*0.33/0.67) | 1,665.00 |
| Maintenance for 10 years @ \$160.00/year | 1,600.00 |
| TOTAL (THRESHOLD per BOREHOLE) | 11,215.00 |

- Above assumptions are based on regional average depth of Boreholes and success rates.
- However districts specific conditions could be taken into consideration.

Table 13.6 Subsidy Threshold Calculation

| Cost Item | Calculation | Value |
|--|--|-----------------------------|
| Present Population | P_p | 5626 |
| Ten years design population | P_{10} | 7415 |
| Max. Users per Hand pump | 300 | 300 |
| No. of Hand pumps to be provided | $((P_{10}) / 300) = \frac{7415}{300}$ | 24.7 (25) |
| Additional HP for Institutions | A | 3 |
| Existing Borehole with Hand pump | E | 3 |
| Total Hand pump to be provided | $(P_{10}) / 300 + (A-E)$ | 25 |
| Standard cost of new Borehole with Hand pump | C | \$11,215 |
| Standard cost of rehabilitation of Borehole | D | \$3,000 |
| Subsidy Threshold | $(([(P_{10} / 300) + (A-E)] \times C) + [D \times E])$ | \$289,375 €2,488,625,000 |

US \$ = € 8600 (May. 2003)

The estimated subsidy threshold based on sufficient water points (boreholes with hand pumps) for the supply area is **US\$289,375**

In order to meet the 10-year projected demand supply deficit of **84%** it would be necessary to construct additional **25 boreholes** installed with hand pumps. It will be difficult to obtain sufficient sites for the drilling of all these boreholes. In addition, due to the concentration of boreholes the risk of pollution from latrines and toilets will increase greatly.

Costs of Boreholes with Handpump

1. Capital Cost

Construction Cost of 25 Boreholes with Hand pumps at \$ 11,215 = \$ 280,375

2. Annual Maintenance Cost for 25 Boreholes with Handpump at \$160 = \$ 4,000

4.4.7.4 Financing of Project- Boreholes fitted with Hand pumps

The cost of construction of the water supply shall be subsidized to 95% by Programme funding, while the beneficiary communities will pay 5%. The cost sharing is as follows:

| | |
|-------------------------------|-------------------|
| Community Contribution(5%) | \$14,019 |
| Project Subsidy (95%) | \$ 266,356 |
| TOTAL CAPITAL COST(\$) | \$ 280,375 |

The community contribution was analyzed on pro-rata according to the beneficiary population

The results is presented in Table 13.7 below.

Table 13.7: Sharing of Community Contribution towards Boreholes with Handpump construction

| Community | Present Population (P.) | COMMUNITY CONTRIBUTION | |
|--------------------|-------------------------|------------------------|--------------------|
| | | US\$ | GH(¢) |
| OLD SASAABI | 463 | 1,154 | 9,921,767 |
| OYIBI | 2,400 | 5,980 | 51,430,323 |
| KPONE SEDUASE | 463 | 1,154 | 9,921,767 |
| GOOD NEWS SEMINARY | 60 | 150 | 1,285,758 |
| VALLEY VIEW | 960 | 2,392 | 20,572,129 |
| MALEJOR | 150 | 374 | 3,214,395 |
| AMRAHIA | 1,130 | 2,816 | 24,215,111 |
| Total | 5,741 | 14,019 | 120,561,250 |

The project subsidy will not be provided unless the community has paid their 5% contribution before tendering and draw up a Facility Management Plan showing how they will organise and pay this maintenance. The project would like to discuss this plan with the community before constructions start.

4.4.8.1 Technology Option B: Piped System based on Mechanized Boreholes

The second option for the proposed water supply scheme is a piped scheme with standpipes based on mechanized boreholes. This option is considered most feasible for water supply to the Oyibi-Amrahia area. The supply scheme option consists of a transmission network fed by the two mechanized boreholes, service reservoirs serving the various communities and distribution networks in the various communities terminating at public standpipes.

Considering the physical setting of the project area and after preliminary study the fill and draw supply mode using dedicated transmission mains was found to have significant technical and cost advantages over the use of a floating supply mode. The design of the scheme was therefore based on the fill and draw mode with dedicated transmission mains.

4.4.8.2 Hydraulic Analysis.

Details of hydraulic analysis carried out to establish the feasibility of the design is presented as (Annex 2).

The analysis was carried out with the aid of the Micro Computer Programs for improved Planning and Design of water Supply Systems with the main objectives of determining the:

- Appropriate pipe sizes of transmission and distribution mains to carry the estimated flows.
- Required hydraulic characteristics of the borehole submersible pumps
- Adequacy of the available head at the selected tank site to provide good residual heads at the service points in the communities.
- The available head at the selected tapping points and its adequacy for feeding the tanks.

The analysis was carried out with the;

- Estimated Water demand for Year 2012.
- The peak daily water demand = 1.5x Average water demand
- Maximum hourly draw-off condition in the network (Peak Factor of 2.4-4.8)
- Minimum water level in the tank.

The following parameters were adopted:

- | | | | |
|----|---------------------------------|---|--|
| 1. | System | = | Pumped System |
| 2. | Estimated Avg. demand | = | as per each community in the supply area |
| 3. | Min. water level in tank | = | 10m above ground level |
| 4. | Ground levels at facility sites | = | As per elevation at the site(m) |
| 5. | Peak factors | = | 2.4 -4.8 |
| 6. | Hazen Williams C for uPVC pipes | = | 130 |

4.4.8.3 Service Reservoir

Estimation of service storage required for effective operation of the system was carried out with the following objectives:

- (a) Ensuring equalization of pressures in the distribution network.
- (b) Stabilization of heads on the pumps.
- (c) Providing emergency reserve against interruptions.
- (d) Compensating for fluctuations in water consumption during the day.

The size and pattern of variation of water consumption during the day and the duration of pumping are the key parameters required for the estimation of the capacity of the tank.

Service reservoirs sized according to the population of the communities and mode of distribution will be the supply of water to the local standpipes by gravity. These reservoirs are sized to provide half-day storage (50% of daily demand) in accordance with CWSA criteria. Standard reservoir sizes are selected. The reservoirs are sited above and as close as possible to the community and to be operated on the basis of "fill and draw". The volumes of reservoir proposed for the various communities are presented in Table 13.9 below;


Storage in the form of polytanks on concrete supports is proposed for capacities up to 10m³ and reinforced concrete tanks for capacities above 10m³.

Table 13.9 Computation of Service Reservoir

| No. | Description | Calculation | Old Saasabi | Oyibi/ Estate | Kpone Seduase | Good News Seminary | Valley View Univ | Malejo r | Amrahia |
|------------------|---|-------------------------------------|-----------------------------------|---------------|---------------|--------------------|------------------|----------|---------|
| P _o | Present population, P _o) | | 463 | 2400 | 463 | 60 | 960 | 150 | 1130 |
| N _b | No of existing Bh. Fitted with handpumps, N _b | | 1 | Nil | 1 | Nil | Nil | Nil | Nil |
| P _s | Population served by existing borehole (P _s) | N _b * 300 | 300 But BH will be used for mech. | 0 | 300 | 0 | 0 | 0 | 0 |
| P _D | Design population | (P _o - P _s) | 463 | 2400 | 163 | 60 | 960 | 150 | 1130 |
| V _D | Design Volume of Reservoir (m ³) (Standard Design) | $\frac{(P_D * 32 * 0.5)}{1000}$ | 7.41 | 38.4 | 2.60 | 0.96 | 15.36 | 2.4 | 18.08 |
| V _{Rec} | Recommended Volume of Reservoir (m ³) | | 10 | 40 | 5 | 5 | 25 | 5 | 25 |
| | | | 10 | 40 | 5 | 5 | 25 | 5 | 25 |

From the results, Old Saasabi, Kpone Seduase, Good News University, and Malejor requires a polytanks on concrete support whiles that of Oyibi/Estate, Valley View University and Amrahia storage will be in the form of reinforced concrete tanks.

A model of an elevated service reservoir is presented as picture 1 below



Picture 1: A Model of an Elevated Service Reservoir

4.4.8.4 Standpipes

The number of public standpipes to be provided is calculated using the 10-year population so as to provide one standpipe for every **600 people** with additional standpipe for each school or clinic.


The number of standpipes required is computed as follows:

$$\text{Number of standpipes} = \frac{(P_{10} - P_s)}{600}$$

Table 13.10 Computation of Standpipes

| No. | Description | Calculation | Old Saasabi | Oyibi | Kpone Seduase | Good News Seminary | Valley View Univ | Malejor | Amrahia |
|-----------------|--|------------------------------|---|----------|---------------|--------------------|------------------|-----------|-----------|
| P ₀ | Present population, (P ₀) | | 463 | 2400 | 463 | 60 | 960 | 150 | 1130 |
| P ₁₀ | Prejected population, (P ₁₀) | P ₁₀ | 610 | 3163 | 10 | 91 | 1453 | 227 | 1710 |
| N _s | No of persons served by a standpipe | | 600 | 600 | 600 | 600 | 600 | 600 | 600 |
| N _b | No of existing Bh. Fitted with handpumps (N _b) | | 1 | Nil | 1 | Nil | Nil | Nil | Nil |
| P _s | Population served by existing borehole (P _s) | N _b * 300 | <small>300 But BH will be used for mechanisati on</small> | 0 | 300 | 0 | 0 | 0 | 0 |
| SP _N | No. of Standpipes required (Round up) | $\frac{(P_{10} - P_s)}{600}$ | 1.06 2 | 5.3 6 | 0.51 1 | 0.1 1 | 2.42 3 | 0.38 1 | 2.85 3 |
| SP _B | Extra standpipes for Institutions (Clinic, Schools etc) | | Nil | | 1 | Nil | Nil | Nil | 1 |
| SP _T | Total No. of Standpipes | 20 | 2 | 7 | 2 | 1 | 3 | 1 | 4 |

A total of 20 public standpipes are recommended for Oyibi –Amrahia supply area. Since Oyibi estate is developing, it is recommended that provision for household connection is considered. The connections cost should be borne by the inhabitants and the pipelines metered with KENT meters. A model of proposed standpipe is presented as picture 2 below



Picture 2: A model of a public standpipe

The summary of the preliminary design parameters is presented in Table 13.11 below

Table 13.11: Summary of Preliminary Design Parameters

| Supply Area | Community | Present Population | 10 Year Demand (m ³ /day) | Service Reservoir (m ³) | Standard Reservoir Size (m ³) | No. of Standpipes |
|---------------------|------------------------|--------------------|--------------------------------------|-------------------------------------|---|-------------------|
| OYIBI Area | Old Saasabi | 463 | 14.8 | 7.41 | 10 | 2 |
| | Oyibi | 2400 | 76.8 | 38.4 | 40 | 7 |
| | Oyibi Estate | | | | | |
| | Kpone Seduase | 463 | 5.2 | 2.60 | 5 | 2 |
| Amrahia Area | Good News Seminary | 60 | 1.9 | 0.96 | 5 | 1 |
| | Valley View University | 960 | 30.7 | 15.36 | 25 | 3 |
| | Malejor | 150 | 4.8 | 2.4 | 5 | 1 |
| | Amrahia | 1130 | 36.16 | 18.08 | 25 | 4 |
| TOTAL | | 5626 | 170.4 | | | 20 |

Due to non-availability of good sources of water, supply to the 7 communities has been planned as one big scheme. The proposed water supply will be based on borehole sources located at Old Saasabi and Kpone Seduase. The estimated number of standpipes is 20, which are made up of 17 standpipes for the communities and 3 standpipes for the various institutions.

Pipe routes and reservoir location should be carried out with the collaboration from Assemblymen/woman, Youth, Watsan and Opinion leaders in the community. The reservoir and standpipe locations are to be confirmed before tendering to avoid any land dispute.

4.5 CONCEPTUAL DESIGN

4.5.1 Piped System based on Mechanised Boreholes

Considering the population of the project area and their water demand, electrical pumped water supply is found to be the most feasible option for the community.

Due to non-availability of good sources of water, supply to the 7 proposed communities has to be planned as one big scheme. The layout of the water supply scheme is presented as **Figure 2**

The proposed water supply scheme involves the use of two submersible pumps to lift the water from the two productive borehole sources located at Old Saasabi and Kpone Seduase to feed seven (7) proposed elevated service reservoirs located at Kpone Seduase, Old Saasabi, Oyibi, Good News Seminary, Valley View University, Malejor and Amrahia supply areas.

The distribution to the communities will be by gravity system terminating at standpipes located in close proximity to the users within the community.

4.5.2 Cost Estimate for Pipe Scheme

A provisional cost analysis of the scheme was carried out. The three main areas considered were;

- ◆ Provisional Capital Investment Cost
- ◆ Operation and Maintenance cost
- ◆ The water Tariff as per bucket of 18 litres water.

4.5.2.1 Provisional Capital Investment Cost

The provisional Capital Investment Cost of the scheme is estimated on the major items of the scheme; ie pump installations, standpipes, delivery and distribution pipelines and service reservoirs.

The estimate however includes excavation, backfill, testing and fitting.

Table 14.1 Cost Estimate for Pipe Scheme

| No. | Description | Unit | Quantity | Rate (USD) | Amount (USD) |
|-----|---|------|----------|------------|-------------------|
| 1 | GENERAL ITEM (10% of Civil Works) | No | | | 3,130.64 |
| 2 | DRILLING OF ADDITIONAL BOREHOLE | No. | | | |
| 3 | PUMP INSTALLATION | | | | |
| 3.1 | Supply and Installation of submersible | | | | |
| 3.2 | Pump and accessories (3000+0.5*Q*H) | No. | 1 | 10,712 | 10,711.50 |
| 3.3 | Pump and accessories (3000+0.5*Q*H) | No. | 1 | 7,200 | 7,200.00 |
| 3.4 | Pump House | No. | 2 | 2,000 | 4,000.00 |
| 3.5 | Electricity Connection | Km | 3 | 7,000 | 17,500.00 |
| | Sub Total | | | | 39,411.50 |
| 4 | PIPELINES (DELIVERY) | | | | |
| 4.1 | Pipeline uPVC ≥ 75 mm Diameter | m | 13,630 | 10 | 136,300.00 |
| 4.2 | Pipeline uPVC ≤ 75 mm Diameter | m | 500 | 8 | 4,000.00 |
| 4.3 | Valve Fittings and Chamber | No | 11 | 500 | 5,500.00 |
| 4.4 | Pipework extras 5% of pipework (4.1+4.2)) | | 707 | 8 | 5,652.00 |
| | Sub Total | | | | 151,452.00 |
| | Old Saasabi | | | | |
| 5 | PIPELINES (DISTRIBUTION) | | | | |
| 5.1 | Pipeline uPVC ≤ 75 mm Diameter | m | 600 | 8 | 4,800.00 |
| 5.2 | Valve Fittings and Chamber | No. | 2 | 500 | 1,000.00 |
| 5.3 | Pipework extras 5% of pipework (5.1) | m | 30 | 8 | 240.00 |
| 5.4 | High Level Tank (10m3) | m3 | 1 | 5,200 | 5,200.00 |
| 5.5 | Standpipes | No | 2 | 800 | 1,600.00 |
| | Sub Total | | | | 12,840.00 |

| No. | Description | Unit | Quantity | Rate (USD) | Amount (USD) |
|-----|--------------------------------------|------|----------|------------|------------------|
| | Oyibi | | | | |
| 6 | PIPELINES (DISTRIBUTION) | | | | |
| 6.1 | Pipeline uPVC ≤ 75 mm Diameter | m | 1,200 | 8 | 9,600.00 |
| 6.2 | Valve Fittings and Chamber | No | 8 | 500 | 4,000.00 |
| 6.3 | Pipework extras 5% of pipework (6.1) | m | 60 | 8 | 480.00 |
| 6.4 | High Level Tank (40m3) | m3 | 1 | 11,100 | 11,100.00 |
| 6.5 | Standpipes | No | 7 | 800 | 5,600.00 |
| | Sub Total | | | | 30,780.00 |
| | Kpone Seduase | | | | |
| 7 | PIPELINES (DISTRIBUTION) | | | | |
| 7.1 | Pipeline uPVC ≤ 75 mm Diameter | m | 600 | 8 | 4,800.00 |
| 7.2 | Valve Fittings and Chamber | No | 3 | 500 | 1,500.00 |
| 7.3 | ipework extras 5% of pipework (7.1) | m | 30 | 8 | 240.00 |
| 7.4 | High Level Tank (5m3) | m3 | 1 | 5,200 | 5,200.00 |
| 7.5 | Standpipes | No | 2 | 800 | 1,600.00 |
| | Sub Total | | | | 13,340.00 |
| | Good News Seminary | | | | |
| 8 | PIPELINES (DISTRIBUTION) | | | | |
| 8.1 | Pipeline uPVC ≤ 75 mm Diameter | m | 500 | 8 | 4,000.00 |
| 8.2 | Valve Fittings and Chamber | No | 2 | 500 | 1,000.00 |
| 8.3 | Pipework extras 5% of pipework (8.1) | m | 25 | 8 | 200.00 |
| 8.4 | High Level Tank (5m3) | m3 | 1 | 5,200 | 5,200.00 |
| 8.5 | Standpipes | No | 1 | 800 | 800.00 |
| | Sub Total | | | | 11,200.00 |

TABLE 14.2 CALCULATION OF ELECTRICITY TARIFF FOR 2 PUMPS

| Item | Description | Unit | Quantity | Total units |
|------|---|---------------|------------------|------------------|
| 1 | Pumping hours a day | Hr | 12 | |
| 2 | Pump motor rated power | KW | 6 | |
| 3 | No. of Days per month | Day | 30 | |
| 4 | Units of electricity consumed | | 12*6*30 | 2,160 |
| | Monthly Tariff charges | Charge | Unit(KWH) | Amount(¢) |
| 5 | First 300 units | 800 | 300 | 240,000 |
| 6 | Other additional units | 980 | 1,860 | 1,822,800 |
| 7 | Service Charge | 1 | 5,000 | 5,000 |
| | Sub Total | | | 2,067,800 |
| 8 | VAT | % | 12.5 | 258,475 |
| 9 | Gov't Levy and Street light | 2,160 | 2.2 | 4,752 |
| | TOTOL MONTHLY ELECTRICITY CHARGE | | | 2,331,027 |
| | Total Monthly Electricity Charge (2 PUMPS) | | | 4,662,054 |
| | Annual cost in GH Cedis(¢) | | | 55,944,648 |
| | Annual cost in USD Rate(1\$= ¢8600) | | | 6,505 |
| | Monthly cost in USD Rate(1\$= ¢8600) | | | 542.10 |

The monthly electricity tariff is estimated as \$542.10 (¢4,662,054)

4.5.3 Annual Operation and Maintenance Cost

To provide an assessment of the feasibility of the design, the estimated annual operation and maintenance costs of the facilities in the proposed scheme are presented as **Table 14.3** below.

The operation and maintenance at this stage is anticipated to cover the entire project area. The recovery of cost of O&M and management will be derived from water sales. The analysis of O&M is presented below;

Table 14.4 Cost Recovery Estimation

| Description | Value | Amount (\$) |
|---|---|-------------|
| Present water demand (m3/ day) | 170.4 | |
| O& M Cost of present demand 170.4m3 per day | (Monthly O&M in USD) { 30 days} | 52.29 |
| O & M cost of 1 m3 (55.55 No. size of 34 bucket) | {O&M cost per day} { present demand} | 0.31 |
| O& M Cost of 1 size 34 Bucket | (O&M cost of 1 m3) (55.55 No 34 bucket) | 0.0055 |
| (Current rate , 1\$= ₵8600), May 2003 | Equivalent in Ghanaian cedis | ₵48 |

The Public utility and Regulatory Commission (PURC) tariff released on March 5th, 2003 cost a bucket of water from public standpipe as ₵64.

It may be recommended that the cost of one size 34-bucket of 18 litres be fixed between ₵ 64 to ₵ 200 to cover the full operation and maintenance cost of the system. The prevailing cost of water in some of the communities is between ₵ 200.00 and ₵ 1,000.00. This decision is however the responsibility of the WATSAN Board and the people of the communities.

4.5.5 Financing of Project- Boreholes Mechanization

The cost of construction of the water supply shall be subsidized to 95% by Programme funding, while the beneficiary communities will pay 5%. The cost sharing is presented as Table 12 below:

Table 14.5: Provisional Investment Cost Sharing

| Project Funding | Amount (\$) | Amount (GH₵) |
|-------------------------|-------------------|-------------------------|
| Community Contribution | 15,653.18 | 134,617,305.00 |
| Programme funding (95%) | 297,410.33 | 2,557,728,795.00 |
| TOTAL | 313,063.50 | 2,692,346,100.00 |

Exchange rate 1\$= ₵8600 May, 2003

The community contribution is shared among the present population based on a pro-rata. The sharing presented in Table 14.6 below.

The community contribution is to be paid before tendering commences

Table 14.6: Sharing of Community Contribution

| Community | Present Population(Po) | Pro-rata | Comm. Contribution (\$) | Comm. Contribution (GH ₵) |
|------------------------|------------------------|---------------|-------------------------|---------------------------|
| Old Saasabi | 463 | 0.0823 | 1,288.20 | 11,078,530.43 |
| Oyibi | 2400 | 0.4266 | 6,677.50 | 57,426,507.64 |
| Kpone Seduase | 463 | 0.0823 | 1,288.20 | 11,078,530.43 |
| Good News Seminary | 60 | 0.0107 | 166.94 | 1,435,662.69 |
| Valley View University | 960 | 0.1706 | 2,671.00 | 22,970,603.06 |
| Malejor | 150 | 0.0267 | 417.34 | 3,589,156.73 |
| Amrahia | 1130 | 0.2009 | 3,143.99 | 27,038,314.02 |
| Total | 5626 | 1.0000 | 15,653.18 | 134,617,305.00 |

The construction cost of the scheme per head is calculated as follows;

| | |
|-------------------------------------|---------------------|
| Present population | 5,626 |
| Provisional Capital Investment Cost | \$313,063.50 |
| Per capita cost | \$55.65 |

The cost per head is high considering CWSA guideline for per capita cost (\$40). This is due to the long transmission network and the mechanization of 2 boreholes. This estimate may come down when the real quantities for the detailed design have been carried out.

4.5.6 The Summary of Cost of Technology Options

The cost of the proposed technology option for the supply of water requirement of Oyibi – Amrahia area is presented as Table 14.6 below;

4.5.7 MANAGEMENT OPTIONS

After facilitating the establishment of WSDBs we will proceed to organise management-training programmes for the members. Prior to the training programme, we will have to advise them on the type of management system to institute. The training will be dependent on the type of management system chosen.

4.5.7.1 The Possible Management Options

According to the existing institutional framework of Ghana, (Mainly the Local Government Act No. 462 (1993) and the more recent "Draft Small Towns Water and Sanitation Policy" territorial communities (DAs) own the assets. A Water and Sanitation Development Board (WSDB) can be created within each territorial community. The DA may delegate to the WSDB (among other bodies) the responsibility to provide water and sanitation services in a small town.

Different management models for the water service can be set up. Each WSDB, with the support of CWSA and DAs, if necessary must decide on the management model that seems best suited for the condition of the territorial community.

The three main options are:

- Community Management
- Delegation to a Private Entity
- Contractual Management (Relationship)

4.5.7.2 Community Management

In the community management model, the beneficiary community and the users are wholly responsible for managing the service, and can outsource certain tasks to private service providers with the exception of financial and commercial management.

The WSDB decides to implement a team consisting of users responsible for the operation and day-to-day management of the small-scale network. This structure is called the WATSAN. In this case, the WSDB assumes all the responsibilities, makes all the decisions, sets the price of the water and establishes the specifications and job profiles for the WATSAN. Note that in practice the relations between the various members are rarely specified in a written document.

The members of a WATSAN ensure the financial management and operation functions of the small-scale networks. The options within the WATSAN must be defined by the WSDB (secretary, accountant, village repairman, etc) and a job profile must be established on the basis of the role entrusted to them. The committee members are indemnified with salaries that are either fixed or proportional to the takings.

4.5.7.3 Delegation to a Private Entity

Recent Studies (for instance: PPIAF CWSA study on private sector participation in Small towns water supply, September, 2001) have outlined the interest of increasing private sector participation (PSP) in the management of water and sanitation services in small towns to ensure a good level of sustainability in the next year and also to raise more funds to invest in the improvement of services.

Hence the related issues for the project implementation are:

- To analyze the perception of the private management option by local actors (representatives in the District Assemblies, members of the WSDB, existing WATSAN teams, community leaders, etc.), because delegation must be a voluntary process;
- To help the local authorities and the WSDB to choose the best option and to define precisely which functions will be delegated to a private entity; in other words the objective is, when the principle of delegation is accepted, to propose the "aim's length";
- To identify the strengths and weakness of the institutional framework to increase the PSP for the management of water and sanitation services in small towns; and to prosee in total agreement with CWSA, slight adaptations if necessary;
- To assist local authorities interested in the delegation option to identify potential operators, to choose the way of selecting them and to give any assistance (on legal, financial and technical issues) during the contract negotiation between the selected bidder and the WSDB;
- Capacity building of the WSDB to give them adapted tools to supervise the quality of services provided by the management operator and ensure the financial follow-up of the delegated contract in order to protect the interest of the final users;
- To elaborate specific proposal to address the pro-poor issue: innovative solutions will be proposed to WSDB in order to improve the access of the poorest to the water services (stand posts with low tariff, subsidised house connections, etc.).

4.5.7.4 Problems to be tackled in the Case of Community Management System.

Players should bear in mind the problems encountered in the operation of networks based on a community management system. In effect, although the analysis of the operating conditions of these small rural networks have sometimes given very promising results, it has more frequently highlighted a number of factors hindering efficient and durable management of the facilities, including in particular:

- Insufficient professional and rigorous financial and technical management.
- Confusion of the user's representation and service monitoring functions with the operating functions; the same bodies (WATSANs) or individuals often find themselves to be both the judges and the parties involved.
- The dilution of responsibilities and the low level of individual acceptance of responsibility by the members of existing committees.

In certain cases this has led to:

- The appropriation of the facilities by few people, under conditions with poor transparency that do not guarantee the long-term durability of the service.
- Poor coverage of costs and collection of debts.
- Misappropriation of funds, either directly (cash flow) or indirectly (over charging certain expenses);
- The postponing of decisions to incur expenses for maintenance or equipment renewal, or the making of non-appropriated investments.

Another factor that can penalize the management of the facilities is the isolation and weaknesses of the bank network. The bank network in places situated far from the large urban is particularly weak and it is difficult to protect the funds. In such cases the facility managers are obliged to make long and costly trips, whether to deposit funds or to get fuel or spare parts.

4.5.7.5 Advantages and Disadvantages of Private Management System

Given that the private management system is new, it is difficult to evaluate its advantages and disadvantages in the long term.

However, what is already coming to the fore in villages where this management system is implemented is the need to give good quality capacity building to the various players involved in management, that is to say the WSDB and the operator.

We also can take profit of other successful African experiences and of the lessons recently learnt in other countries, for example Mauritania (more than 200 schemes in small towns operating under a lease contract by a private operator) or Uganda (which is experimenting management contracts for a dozen of communities since 2001).

Another essential consideration is to ensure that all the players fully understand the specifications, and to negotiate amendments where necessary.

The animator will therefore stress the importance of having a vigorous structure with such a management system. They will explain the various advantages of this management system to the members of the WSDB.

4.5.7.6 Contractual Management

Under this management system the community (represented by WATSAN) and the District Assembly contracts the services of a private organisation or an individual and then monitor the operations. This implies collaboration between a community management and that of a private entity. Below are the implications of a contractual relationship.

4.5.7.6.1 The Advantages Concerning the contractual Relations

The system complies with the framework authorized by the different texts concerning the water sector, the territorial communities and regulations of associations, and fits into the dynamic currents aiming at promoting centralization and rendering basic services to the communities.

More specifically, it establishes the role of the DWST /DA as the guarantor of the good management of the service. As it is not involved in the day-to-day management of the service, it can take the necessary step back and concentrate on supervision and questions of arbitration (and have the legitimacy to do so with respect to the two other proximity players).

In addition, it allows some of the advantages of community management to be kept, especially the participation of the users in the monitoring of the service, without involving them in "operational" functions for which they have difficulty in mobilizing the skills internally.

Moreover, being a professional in whose interest lies the good functioning of the small town

network, the operator will be encouraged to adapt the level of services to the solvent demand of the users. Lastly, this system aims at using the responsiveness to the demand of the users/customers specific to the private sector (especially when it is competitive) and the fact that it is in the operator's interest to ensure the long-term durability of his working resources.

4.5.7.7 Advantages Concerning the Sharing of Responsibilities.

- ❖ The specifications set the conditions for delegating management to a private sector, and define precisely the task and responsibilities of each party involved so as to limit the risk of conflicts.
- ❖ The specifications must be established and negotiated in detail for each District. They must be supplemented, amended, modified by the WSDB and RWST /DA so that they meet their interest and ensure smooth functioning of the service, while at the same time respecting satisfying the interest of the operator.
- ❖ The contract provides for extension and cancellation of clauses, and conditions for revising and negotiating the duties. In effect, in a context where with new facilities a few unknown still remain, particularly concerning solvent demand, it is preferable to have the possibility of reviewing the amounts of the duties or the sale price per cubic meter after a few months, in the interest of everyone involved.
- ❖ The proposed financial arrangement must maximize protection of the funds. As rules can always be skirted, it is recommended rather to emphasize the interest each party has in fulfilling its tasks correctly and to limit disputes, by instituting check procedures among other things.
- ❖ As concerns the operational aspect, by giving responsibility to a manager, the risk of misappropriations are limited as since the operator has virtually no interest in dodging this.

4.5.7.8 Advantages Concerning the Financial Management and Protection of the Funds

Regarding Finance, it is proposed that there be a renewal and extensions funds deposited on an account opened by the WSDB, from which money can only be withdrawn with the double signature of the manager.

The setting up of three separate parts in the price of water service will enable financial flow to be controlled. These may include;

- I. A part for the functioning of the WSDB,
- II. A part for the renewal and extensions fund.
- III. A part for Auditing by an independent body.

4.5.7.9 Management Training

Based on the results of the analysis of the identified institutions (CWSA, DWST and the District Environmental Health Officers) and the recommendations in the pre-feasibility study on institutional development and capacity building, trainers should be contracted who intend must consult CWSA on the various activities to be undertaken.

The trainer(s) specifically should facilitate and coordinate with CWSA:

- The procurement of needed equipment for strengthening the institutions,
- Arrange for training course (relevant for institutional development) in identified institutions.

Some of the training courses could be conducted at the following institutions: Institute of Local Government Studies; Ghana Institute of Management and Public Administration; Management Development and Productivity Institute; School of Hygiene (Accra), and MDPI (Accra).

Placement of personnel in a particular training programme in a training institution would be based on the identified training needs and the capacity of the training institution to meet the demand.

4.5.8 Recommendation on Management Options

Three different categories have been identified as possible management options for the piped water system being constructed for the people in the Tema and Ga district of the greater Accra region. Based on the background information available and the community's choice which were based on prior information on the advantages and disadvantages of each option, we recommend the following option for each community.

| Name of Community | Community Choice of Management option | Recommended Option based on Background Information | Comments |
|----------------------|---|---|--|
| Kpone Seduase | Community Management | Community Management (Bulk Supply to Community) | The WATSAN is very organized and currently manage & sell water from the borehole |
| Oyibi main Community | Has not made any choice due to indecision | Contractual Management (Private Person + Watsan Board +District Assembly) | The WATSAN committee Is inactive & community difficult when it come to organisation and fund raising. Have no experience in community sale of water. |
| Oyibi Estates | Has not made any choice due to indecision | Contractual Management (Private Person + Watsan Board +District Assembly) | No WATSAN-Already use to billing from private manager (GWCL) |
| Old Saasabi | Community Management | Community Management(Bulk Supply to Community) | WATSAN active and Capable, although does not currently sell water: well organized |
| Maledjor | Community Management | Community Management (Bulk Supply to Community) | Organised: currently WATSAN manages & sell tanker water |
| Amrahia | No choice due to indecision | Contractual Management (Private Person + Watsan Board +District Assembly) | No WATSAN-community very difficult to organise. Currently people sell tanker water privately |
| Good News College | Institutional Management | Bulk supply to Institution | The institution: will be responsible for repairs |
| Valley View Univ. | Institutional Management | Bulk supply to Institution | The institution: will be responsible for repairs |

Gross Revenue generated should be shared in the proportion 70:20:10 to the following entities;

- 70% to Private Person for Operation and Maintenance
- 20% to Water Boards for administration expenses
- 10% to District Assembly for Major repairs and expansion

5 FINDINGS AND RECOMMENDATIONS

From the feasibility studies carried out and the analysis of all data collected the following findings were made:

5.1 Socio-economic Feasibility

The 5 communities and 2 institutions forming the proposed supply area have a combined population of 5,626. The highest population centre is Oyibi with a total population of 2000.

Based on the household survey, the average age in the area ranges between 33 and 38 years. The male to female population ratio is approximately 49:51 in all the communities.

The main occupations in the project area are farming and petty trading.

The median monthly household income for the communities ranges from ₦420,000 to ₦519,000 whilst expenditure levels ranges from ₦330,000 to ₦385,000. The main items of expenditure are food and school fees.

5.2 Technical Feasibility

The main source of potable in the area is the two new production boreholes (Kpone Sedause BH1 and Old Saasabi BH1) constructed as part of the Danida funded programme. The boreholes have been temporarily equipped with hand pumps and are being used by the communities.

The Oyibi BH1 has relatively high conductivity and chloride level, and may be prone to salt water encroachment when subjected to long term pumping as in a water supply.

The Kpone Seduase and Old Saasabi boreholes have been identified as the most promising water sources for the proposed rural piped water scheme in the area.

The actual water supply coverage in the supply area is about 16%, leaving a large deficit of 84%. The total water demand (daily average) in the area is estimated as 170.4m³ /day. The peak daily demand is also estimated to be 255.6m³ /day and this can be safely supplied from the Kpone Seduase and Old Saasabi boreholes which have a combined safe yield of 270m³ /day for a 12 hour pumping schedule.

The estimated subsidy threshold based on sufficient water points (boreholes with hand pumps) for the supply area is US\$289,375.

A feasible piped water scheme can be constructed at a total capital cost of US\$313,063.50; this cost is only a provisional estimate and may be reduced after detailed design.

The system would comprise 2 mechanized boreholes feeding water to 7 service reservoirs and 20 public standpipes.

Annual operation and maintenance cost were estimated to be US\$21,673.67.

The per capita cost of the scheme would be US\$55.65; the high per capita cost can be attributable to the long delivery pipe length from Kpone Seduase to Amrahia.

5.3 Recommendations

The socio-economic survey and water needs assessment confirm that there is a good potential for developing a piped water supplies for the Oyibi-Amrahia supply area.

However, the proposed production boreholes are adequate to serve 5 communities and 2 institutions based on the safe yield analysis.

It is therefore recommended that a new piped water supply system be constructed for the supply area. The proposed piped system involve the mechanization of two production boreholes located at Old Saasabi and Kpone Seduase to supply water to the beneficiary communities by "fill and draw" basis terminating at public standpipes and in residential area, house connection area to be metered

In order to address the prevailing water and sanitation issues outlined by the feasibility study, the following further recommendations are made:

- ◆ Extension work to mobilise the 5 communities and the two institutions shall be carried out in line with the guideline of CWSA, Rural water Programme. All necessary milestones would be followed to achieve the project goal.
- ◆ A team, made up of the DWST, Watsan Committees from the beneficiary communities, the Consultant and the GAR/CWSA Water Supply Engineer, should hold negotiations with the Chiefs and Elders of the beneficiary community to obtain a parcel of land for the pump house and reservoir sites.

- ◆ Design of the Facility Management Plan (FMP) would consider different management scenarios including WATSAN Committee cum WATSAN Board Management, a mixed management team of WATSAN Committee and Private Company, and lastly a wholly Private Company management with the WATSAN Board serving as an overall supervisory and regulatory board.
- ◆ The project subsidy will not be provided unless the community is able to draw up Facility Management Plan (FMP) showing how they will be able to organize and pay for this maintenance. The project will like to discuss this plan with the community before construction starts.
- ◆ Residents of the beneficiary community should be encouraged to construct household toilet units and provide suitable facilities or sites for garbage disposal.
- ◆ Institutional KVIPs are needed to solve the sanitation needs of existing educational institutions in the project area.

- ◆ It is recommended that the cost of one size of 34 bucket of water (18 litres) be fixed between ₦80 to ₦200 to cover the full operation and maintenance cost of the system. This decision is however the responsibility of the WASAN Board and the people of the community.

LIST OF FIGURE

OYIBI-AMRAHIA WATER DELIVERY NETWORK




FIG. 2

KPONE SEDUASE

| No. | Age | Sex | No. p/hs | Occupation | Income | | | Expenditure | | | | Suplus | Willingness to Pay for Water | | | |
|----------------|-------------|-----|------------|----------------------|-----------|-----------|-------------------|-------------|---------|---------|------------------|------------------|------------------------------|--------------|----------------|------------|
| | | | | | Main wk | Ext Acti | Total | Food | Educatn | Others | Total | | No. of bkt | amt/bket | Amt/ mth | %of income |
| 1 | 29 | M | 3 | Carpenter/Farming | 800,000 | 200,000 | 1,000,000 | 200,000 | 440,000 | 0 | 640,000 | 360,000 | 10 | 100 | 30000 | 3 |
| 2 | 22 | F | 3 | Petty Trading | 200,000 | 49,000 | 249,000 | 180,000 | 45,000 | 0 | 225,000 | 24,000 | 7 | 100 | 21000 | 8.43373494 |
| 3 | 25 | F | 2 | Hair Dresser | 40,000 | 150,000 | 190,000 | 150,000 | 0 | 0 | 150,000 | 40,000 | 3 | 100 | 9000 | 4.73684211 |
| 4 | 41 | M | 6 | Farming/Trading | 700,000 | 2,800,000 | 3,500,000 | 840,000 | 500,000 | 0 | 1,340,000 | 2,160,000 | 10 | 200 | 60000 | 1.71428571 |
| 5 | 32 | M | 4 | Carpentary/Farming | 50,000 | 84,000 | 134,000 | 40,000 | 50,000 | 0 | 90,000 | 44,000 | 4 | 100 | 12000 | 8.95522388 |
| 6 | 55 | M | 7 | Driving/Farming | 1,500,000 | 500,000 | 2,000,000 | 200,000 | 400,000 | 350,000 | 950,000 | 1,050,000 | 10 | 500 | 150000 | 7.5 |
| 7 | 42 | F | 6 | Petty Trading/Farmid | 300,000 | 0 | 300,000 | 140,000 | 60,000 | 0 | 200,000 | 100,000 | 12 | 100 | 36000 | 12 |
| 8 | 28 | M | 4 | Farming | 1,000,000 | 0 | 1,000,000 | 280,000 | 200,000 | 0 | 480,000 | 520,000 | 10 | 200 | 60000 | 6 |
| 9 | 40 | F | 3 | Farming/Trading | 640,000 | 50,000 | 690,000 | 250,000 | 300,000 | 20,000 | 570,000 | 120,000 | 6 | 200 | 36000 | 5.2173913 |
| 10 | 46 | F | 3 | Trading | 140,000 | 105,000 | 245,000 | 115,000 | 80,000 | 0 | 195,000 | 50,000 | 5 | 100 | 15000 | 6.12244898 |
| 11 | 24 | F | 4 | Trading | 650,000 | 40,000 | 690,000 | 580,000 | 60,000 | 0 | 640,000 | 50,000 | 8 | 100 | 24000 | 3.47826087 |
| 12 | 28 | M | 3 | Farming/Mechanic | 40,000 | 168,000 | 208,000 | 120,000 | 20,000 | 0 | 140,000 | 68,000 | 6 | 100 | 18000 | 8.65384615 |
| 13 | 39 | M | 6 | Farming | 188,000 | 400,000 | 588,000 | 380,000 | 70,000 | 0 | 450,000 | 138,000 | 10 | 200 | 60000 | 10.2040816 |
| 14 | 43 | M | 5 | Trading | 410,000 | 40,000 | 450,000 | 210,000 | 50,000 | 0 | 260,000 | 190,000 | 8 | 100 | 24000 | 5.33333333 |
| Total | 494 | | 59 | | | | 11,244,000 | | | | 6,330,000 | 4,914,000 | 109 | 2,200 | 555,000 | 91 |
| Average | 35.3 | | 4.2 | | | | 803142.86 | | | | 452142.9 | 351000.0 | 7.8 | 157.1 | 39642.9 | 6.5 |
| Median | 35.5 | | 4 | | | | 519,000 | | | | 355,000 | 110,000 | 8 | 100 | 27,000 | 6.1 |

OLD SAASABI

| No. | Age | Sex | No. p/hs | Occupation | Income | | | Expenditure | | | | Suplus | Willingness to Pay for Water | | | |
|----------------|-------------|-----|------------|--------------------|-----------|----------|------------------|-------------|---------|--------|------------------|------------------|------------------------------|--------------|----------------|------------|
| | | | | | Main wk | Ext Acti | Total | Food | Educatn | Others | Total | | No. of bkt | amt/bket | Amt/ mth | %of Income |
| 1 | 35 | M | 3 | Farming | 300,000 | 0 | 300,000 | 200,000 | 30,000 | 0 | 230,000 | 70,000 | 5 | 100 | 15000 | 5 |
| 2 | 32 | F | 6 | Farming/Trading | 60,000 | 350,000 | 410,000 | 120,000 | 140,000 | 0 | 260,000 | 150,000 | 10 | 100 | 30000 | 7.31707317 |
| 3 | 33 | F | 5 | Trading/Farming | 40,000 | 160,000 | 200,000 | 160,000 | 10,000 | 0 | 170,000 | 30,000 | 4 | 100 | 12000 | 6 |
| 4 | 40 | M | 4 | Farming/Charcoal B | 800,000 | 500,000 | 1,300,000 | 150,000 | 210,000 | 0 | 360,000 | 940,000 | 5 | 200 | 30000 | 2.30769231 |
| 5 | 52 | F | 6 | Farming/Trading | 1,200,000 | 120,000 | 1,320,000 | 120,000 | 480,000 | 0 | 600,000 | 720,000 | 10 | 200 | 60000 | 4.54545455 |
| 6 | 40 | F | 6 | Trading/Charcoal B | 180,000 | 240,000 | 420,000 | 150,000 | 150,000 | 30,000 | 330,000 | 90,000 | 10 | 100 | 30000 | 7.14285714 |
| 7 | 30 | F | 5 | Farming | 160,000 | 310,000 | 470,000 | 90,000 | 160,000 | 40,000 | 290,000 | 180,000 | 8 | 200 | 48000 | 10.212766 |
| 8 | 28 | M | 3 | Farming | 120,000 | 50,000 | 170,000 | 100,000 | 10,000 | 0 | 110,000 | 60,000 | 4 | 100 | 12000 | 7.05882353 |
| 9 | 39 | M | 5 | Farming/Trading | 500,000 | 260,000 | 760,000 | 400,000 | 220,000 | 20,000 | 640,000 | 120,000 | 7 | 200 | 42000 | 5.52631579 |
| 10 | 25 | F | 5 | Trading | 450,000 | 20,000 | 470,000 | 110,000 | 305,000 | 0 | 415,000 | 55,000 | 6 | 100 | 18000 | 3.82973723 |
| 11 | 32 | M | 4 | Trading/Charcoal B | 200,000 | 40,000 | 240,000 | 80,000 | 105,000 | 0 | 185,000 | 55,000 | 6 | 100 | 18000 | 7.5 |
| 12 | 29 | F | 2 | Farming/Trading | 260,000 | 80,000 | 340,000 | 285,000 | 50,000 | 0 | 335,000 | 5,000 | 6 | 100 | 18000 | 5.29411765 |
| 13 | 30 | M | 5 | Farming | 160,000 | 150,000 | 310,000 | 140,000 | 94,000 | 0 | 234,000 | 76,000 | 7 | 100 | 21000 | 6.77419355 |
| 14 | 40 | F | 4 | Trading | 850,000 | 175,000 | 1,025,000 | 360,000 | 480,000 | 0 | 840,000 | 185,000 | 8 | 100 | 24000 | 2.34146341 |
| 15 | 44 | F | 5 | Farming/Trading | 605,000 | 47,000 | 652,000 | 400,000 | 150,000 | 0 | 550,000 | 102,000 | 10 | 200 | 60000 | 9.20245399 |
| Total | 528 | | 88 | | | | 8,387,000 | | | | 5,549,000 | 2,838,000 | 106 | 2,000 | 438,000 | 90 |
| Average | 35.3 | | 4.5 | | | | 659133.3 | | | | 369933.3 | 189200.0 | 7.1 | 133.3 | 29200.0 | 6.0 |
| Median | 33 | | 5 | | | | 420,000 | | | | 330,000 | 90,000 | 7 | 100 | 24,000 | 6 |

OYIBI

| No. | Age | Sex | No. p/hs | Occupation | Income | | | Expenditure | | | | Suplus | Willingness to Pay for Water | | | |
|-----|-----|-----|----------|----------------------|-----------|-----------|-----------|-------------|---------|---------|-----------|-----------|------------------------------|----------|----------|-------------|
| | | | | | Main wk | Ext Actl | Total | Food | Educatr | Others | Total | | No. of bkt | amt/bket | Amt/ mth | %of Inco.ne |
| 1 | 33 | M | 5 | Farming/Masonry | 1,600,000 | 1,400,000 | 3,000,000 | 900,000 | 30,000 | 110,000 | 1,040,000 | 1,960,000 | 3 | 200 | 18000 | 0.6 |
| 2 | 42 | M | 1 | Carpenter/Assemmn | 150,000 | 100,000 | 250,000 | 150,000 | 50,000 | 0 | 200,000 | 50,000 | 2 | 300 | 18000 | 7.2 |
| 3 | 32 | M | 5 | Farmer | 450,000 | 0 | 450,000 | 200,000 | 150,000 | 0 | 350,000 | 100,000 | 5 | 200 | 30000 | 6.6666667 |
| 4 | 25 | M | 5 | Masonry | 1,600,000 | 0 | 1,600,000 | 420,000 | 160,000 | 0 | 580,000 | 1,020,000 | 6 | 100 | 18000 | 1.125 |
| 5 | 69 | F | 2 | Petty Trading | 120,000 | 60,000 | 180,000 | 80,000 | 50,000 | 0 | 130,000 | 50,000 | 5 | 100 | 15000 | 8.33333333 |
| 6 | 35 | F | 4 | Trading/Dress Makg | 100,000 | 20,000 | 120,000 | 60,000 | 40,000 | 0 | 100,000 | 20,000 | 5 | 100 | 15000 | 12.5 |
| 7 | 32 | F | 6 | Trading/Caretaker(E | 180,000 | 50,000 | 230,000 | 90,000 | 90,000 | 0 | 180,000 | 50,000 | 5 | 100 | 15000 | 6.52173913 |
| 8 | 32 | F | 3 | Petty Trading | 150,000 | 160,000 | 310,000 | 50,000 | 120,000 | 0 | 170,000 | 140,000 | 10 | 100 | 30000 | 9.67741935 |
| 9 | 49 | M | 8 | B Contractor/Trading | 6,500,000 | 250,000 | 6,750,000 | 5,000,000 | 600,000 | 800,000 | 6,400,000 | 350,000 | 12 | 200 | 72000 | 1.06666667 |
| 10 | 49 | F | 3 | Farming/Dress Mak | 200,000 | 120,000 | 320,000 | 100,000 | 160,000 | 0 | 260,000 | 60,000 | 4 | 100 | 12000 | 3.75 |
| 11 | 55 | M | 5 | Business/Farming | 600,000 | 800,000 | 1,400,000 | 420,000 | 325,000 | 0 | 745,000 | 655,000 | 12 | 100 | 36000 | 2.57142857 |
| 12 | 24 | F | 2 | Trading | 700,000 | 200,000 | 900,000 | 400,000 | 120,000 | 40,000 | 560,000 | 340,000 | 8 | 100 | 24000 | 2.66666667 |
| 13 | 37 | M | 6 | Businessman | 900,000 | 500,000 | 1,400,000 | 500,000 | 300,000 | 350,000 | 1,150,000 | 250,000 | 10 | 200 | 60000 | 4.28571429 |
| 14 | 23 | F | 4 | Dressmaker | 100,000 | 250,000 | 350,000 | 180,000 | 90,000 | 10,000 | 280,000 | 70,000 | 6 | 100 | 18000 | 5.14285714 |
| 15 | 50 | M | 6 | Farming | 500,000 | 50,000 | 550,000 | 300,000 | 120,000 | 80,000 | 500,000 | 50,000 | 12 | 100 | 36000 | 6.54545455 |
| 16 | 45 | M | 4 | Farming/Mechanics | 500,000 | 120,000 | 620,000 | 350,000 | 80,000 | 90,000 | 520,000 | 100,000 | 8 | 200 | 48000 | 7.74193548 |
| 17 | 29 | F | 6 | Trading | 520,000 | 120,000 | 640,000 | 340,000 | 120,000 | 100,000 | 560,000 | 80,000 | 10 | 100 | 30000 | 4.6875 |
| 18 | 33 | M | 4 | Masonry | 1,200,000 | 100,000 | 1,300,000 | 800,000 | 150,000 | 50,000 | 1,000,000 | 300,000 | 8 | 200 | 48000 | 3.69230769 |
| 19 | 51 | M | 3 | Farming | 160,000 | 100,000 | 260,000 | 100,000 | 80,000 | 0 | 180,000 | 80,000 | 6 | 100 | 18000 | 6.92307692 |
| 20 | 45 | F | 4 | Petty Trading | 800,000 | 105,000 | 905,000 | 550,000 | 150,000 | 120,000 | 820,000 | 85,000 | 7 | 200 | 42000 | 4.64088398 |
| 21 | 22 | F | 3 | Petty Trading | 200,000 | 49,000 | 249,000 | 180,000 | 45,000 | 0 | 225,000 | 24,000 | 7 | 100 | 21000 | 8.43373494 |
| 22 | 25 | F | 2 | Hair Dresser | 40,000 | 150,000 | 190,000 | 150,000 | 0 | 0 | 150,000 | 40,000 | 3 | 100 | 9000 | 4.73684211 |
| 23 | 41 | M | 6 | Farming/Trading | 700,000 | 600,000 | 1,300,000 | 550,000 | 500,000 | 0 | 1,050,000 | 250,000 | 10 | 200 | 60000 | 4.61538462 |
| 24 | 32 | M | 4 | Carpentary/Farming | 50,000 | 84,000 | 134,000 | 40,000 | 50,000 | 0 | 90,000 | 44,000 | 4 | 100 | 12000 | 8.95522388 |
| 25 | 55 | M | 7 | Driving/Farming | 1,500,000 | 500,000 | 2,000,000 | 200,000 | 400,000 | 350,000 | 950,000 | 1,050,000 | 10 | 500 | 150000 | 7.5 |
| 26 | 42 | F | 6 | Petty Trading/Farmis | 300,000 | 0 | 300,000 | 140,000 | 60,000 | 0 | 200,000 | 100,000 | 12 | 100 | 36000 | 12 |
| 27 | 28 | F | 3 | Trading | 550,000 | 100,000 | 650,000 | 210,000 | 100,000 | 50,000 | 360,000 | 290,000 | 6 | 200 | 36000 | 5.53846154 |
| 28 | 32 | M | 5 | Petty Trading/Farmis | 480,000 | 120,000 | 600,000 | 200,000 | 150,000 | 110,000 | 460,000 | 140,000 | 6 | 100 | 18000 | 3 |
| 29 | 40 | M | 4 | Foreman/Farming | 670,000 | 100,000 | 770,000 | 450,000 | 150,000 | 80,000 | 680,000 | 90,000 | 8 | 100 | 24000 | 3.11688312 |
| 30 | 36 | F | 5 | Petty Trading | 200,000 | 160,000 | 360,000 | 150,000 | 100,000 | 0 | 250,000 | 110,000 | 10 | 100 | 30000 | 8.33333333 |
| 31 | 41 | F | 7 | Building Technician | 1,500,000 | 0 | 1,500,000 | 800,000 | 440,000 | 110,000 | 1,150,000 | 350,000 | 14 | 200 | 84000 | 5.6 |
| 32 | 38 | M | 5 | Farming/Masonry | 850,000 | 50,000 | 900,000 | 550,000 | 200,000 | 0 | 750,000 | 150,000 | 8 | 100 | 24000 | 2.66666667 |
| 33 | 39 | M | 6 | Businessman | 2,000,000 | 250,000 | 2,250,000 | 850,000 | 700,000 | 480,000 | 2,030,000 | 220,000 | 12 | 200 | 72000 | 3.2 |
| 34 | 43 | F | 4 | Secretary | 450,000 | 120,000 | 570,000 | 300,000 | 120,000 | 0 | 420,000 | 150,000 | 6 | 100 | 18000 | 3.15789474 |
| 35 | 45 | F | 2 | Trading | 150,000 | 120,000 | 270,000 | 120,000 | 100,000 | 0 | 220,000 | 50,000 | 4 | 100 | 12000 | 4.44444444 |
| 36 | 30 | M | 3 | Farmer | 320,000 | 60,000 | 380,000 | 200,000 | 160,000 | 0 | 360,000 | 20,000 | 5 | 100 | 15000 | 3.94736842 |
| 37 | 29 | F | 4 | Farming/Masonry | 850,000 | 0 | 850,000 | 380,000 | 120,000 | 150,000 | 650,000 | 200,000 | 7 | 100 | 21000 | 2.47053824 |
| 38 | 47 | M | 8 | Land Consultant | 1,700,000 | 0 | 1,700,000 | 700,000 | 420,000 | 200,000 | 1,320,000 | 380,000 | 12 | 200 | 72000 | 4.23529412 |
| 39 | 34 | M | 2 | Tailoring | 90,000 | 100,000 | 190,000 | 100,000 | 50,000 | 0 | 150,000 | 40,000 | 4 | 100 | 12000 | 6.31578947 |
| 40 | 30 | F | 7 | Teaching | 630,000 | 250,000 | 880,000 | 380,000 | 190,000 | 110,000 | 680,000 | 200,000 | 12 | 100 | 36000 | 4.09090909 |
| 41 | 27 | M | 3 | Land Cons/Farming | 1,200,000 | 150,000 | 1,350,000 | 700,000 | 330,000 | 150,000 | 1,180,000 | 170,000 | 6 | 100 | 18000 | 1.33333333 |
| 42 | 52 | F | 7 | Farming/Dress Mak | 200,000 | 100,000 | 300,000 | 110,000 | 50,000 | 0 | 160,000 | 140,000 | 12 | 100 | 36000 | 12 |
| 43 | 38 | M | 4 | Farming/Trading | 200,000 | 150,000 | 350,000 | 160,000 | 100,000 | 50,000 | 310,000 | 40,000 | 6 | 100 | 18000 | 5.14285714 |

| | | | | | | | | | | | | | | | | |
|---------|-------|---|------|-----------------------|-----------|-----------|------------|-----------|---------|---------|------------|------------|-----|--------|-----------|------------|
| 44 | 44 | M | 4 | Business/Farming | 350,000 | 50,000 | 400,000 | 290,000 | 80,000 | 0 | 370,000 | 30,000 | 5 | 100 | 15000 | 3.75 |
| 45 | 40 | F | 5 | Masonry | 800,000 | 180,000 | 980,000 | 420,000 | 280,000 | 90,000 | 790,000 | 190,000 | 8 | 100 | 24000 | 2.44897959 |
| 46 | 25 | M | 4 | Land Consultant | 1,500,000 | 0 | 1,500,000 | 420,000 | 240,000 | 120,000 | 780,000 | 720,000 | 8 | 200 | 48000 | 5.2 |
| 47 | 22 | F | 3 | Trading/Farming | 750,000 | 350,000 | 1,100,000 | 800,000 | 150,000 | 50,000 | 1,000,000 | 100,000 | 8 | 200 | 48000 | 4.36363636 |
| 48 | 50 | F | 4 | Farming | 200,000 | 100,000 | 300,000 | 100,000 | 80,000 | 0 | 180,000 | 120,000 | 6 | 100 | 18000 | 6 |
| 49 | 41 | M | 5 | Building Foreman | 890,000 | 150,000 | 1,040,000 | 550,000 | 150,000 | 120,000 | 820,000 | 220,000 | 7 | 200 | 42000 | 4.03846154 |
| 50 | 26 | F | 4 | Petty Trading | 310,000 | 250,000 | 560,000 | 180,000 | 45,000 | 0 | 225,000 | 335,000 | 7 | 100 | 21000 | 3.75 |
| 51 | 49 | M | 6 | Teaching | 710,000 | 140,000 | 850,000 | 150,000 | 0 | 0 | 150,000 | 700,000 | 3 | 100 | 9000 | 1.05882353 |
| 52 | 29 | F | 4 | Farming/Trading | 210,000 | 400,000 | 610,000 | 380,000 | 210,000 | 0 | 590,000 | 20,000 | 10 | 200 | 60000 | 9.83806557 |
| 53 | 33 | F | 5 | Petty Trading | 450,000 | 150,000 | 600,000 | 40,000 | 50,000 | 0 | 90,000 | 510,000 | 4 | 100 | 12000 | 2 |
| 54 | 39 | M | 5 | Driving/Farming | 150,000 | 500,000 | 650,000 | 200,000 | 270,000 | 100,000 | 570,000 | 80,000 | 10 | 500 | 150000 | 23.0769231 |
| 55 | 43 | M | 5 | Petty Trading/Farming | 180,000 | 400,000 | 580,000 | 140,000 | 60,000 | 0 | 200,000 | 380,000 | 12 | 100 | 36000 | 6.20689655 |
| 56 | 26 | F | 4 | Farming/Trading | 450,000 | 50,000 | 500,000 | 280,000 | 200,000 | 0 | 480,000 | 20,000 | 10 | 200 | 60000 | 12 |
| 57 | 35 | M | 5 | Building Contractor | 1,800,000 | 450,000 | 2,250,000 | 60,000 | 40,000 | 0 | 100,000 | 2,150,000 | 5 | 100 | 15000 | 0.66666667 |
| 58 | 41 | F | 6 | Trading/Hair Dresse | 200,000 | 50,000 | 250,000 | 90,000 | 90,000 | 0 | 180,000 | 70,000 | 5 | 100 | 15000 | 6 |
| 59 | 37 | M | 4 | Farming/Masonry | 150,000 | 800,000 | 950,000 | 50,000 | 120,000 | 0 | 170,000 | 780,000 | 10 | 100 | 30000 | 3.15789474 |
| 60 | 42 | F | 6 | Foreman/Farming | 970,000 | 100,000 | 1,070,000 | 500,000 | 400,000 | 120,000 | 1,020,000 | 50,000 | 12 | 200 | 72000 | 6.72897196 |
| 61 | 52 | M | 6 | Farming/Masonry | 1,500,000 | 0 | 1,500,000 | 600,000 | 420,000 | 120,000 | 1,140,000 | 360,000 | 20 | 50 | 30000 | 2 |
| 62 | 49 | M | 6 | Clerk | 800,000 | 0 | 800,000 | 200,000 | 450,000 | 0 | 650,000 | 150,000 | 16 | 200 | 96000 | 12 |
| 63 | 32 | F | 4 | Secretary | 720,000 | 300,000 | 1,020,000 | 410,000 | 350,000 | 100,000 | 860,000 | 160,000 | 10 | 100 | 30000 | 2.94117647 |
| 64 | 29 | F | 5 | Trading | 250,000 | 1,200,000 | 1,450,000 | 650,000 | 400,000 | 210,000 | 1,260,000 | 190,000 | 10 | 200 | 60000 | 4.13793103 |
| 65 | 40 | M | 3 | Administrator | 1,200,000 | 500,000 | 1,700,000 | 600,000 | 250,000 | 170,000 | 1,020,000 | 680,000 | 20 | 200 | 120000 | 7.05882353 |
| 66 | 35 | F | 5 | Clerk | 900,000 | 550,000 | 1,450,000 | 700,000 | 400,000 | 250,000 | 1,350,000 | 100,000 | 12 | 200 | 72000 | 4.96551724 |
| 67 | 41 | M | 6 | Businessman | 2,000,000 | 0 | 2,000,000 | 1,000,000 | 500,000 | 300,000 | 1,800,000 | 200,000 | 20 | 200 | 120000 | 6 |
| 68 | 39 | F | 4 | Administrator | 750,000 | 600,000 | 1,350,000 | 700,000 | 350,000 | 150,000 | 1,200,000 | 150,000 | 12 | 200 | 72000 | 5.33333333 |
| 69 | 27 | M | 3 | Engineer | 1,700,000 | 0 | 1,700,000 | 500,000 | 450,000 | 400,000 | 1,350,000 | 350,000 | 14 | 100 | 42000 | 2.47058824 |
| 70 | 38 | F | 4 | Teaching | 1,020,000 | 200,000 | 1,220,000 | 550,000 | 300,000 | 200,000 | 1,050,000 | 170,000 | 10 | 100 | 30000 | 2.45901639 |
| 71 | 54 | F | 3 | Trading | 200,000 | 800,000 | 1,000,000 | 850,000 | 150,000 | 100,000 | 900,000 | 100,000 | 12 | 100 | 36000 | 3.6 |
| 72 | 42 | M | 4 | Teaching | 980,000 | 200,000 | 1,180,000 | 450,000 | 300,000 | 280,000 | 1,030,000 | 150,000 | 10 | 200 | 60000 | 5.08474576 |
| Total | 2737 | | 325 | | | | 70,138,000 | | | | 50,845,000 | 19,293,000 | 624 | 10,650 | 2,980,000 | 388 |
| Average | 38.01 | | 4.51 | | | | 974,139 | | | | 706,181 | 267,958 | 9 | 148 | 40,000 | 5 |
| Median | 38 | | 4 | | | | 825,000 | | | | 565,000 | 150,000 | 8 | 100 | 30,000 | 4.5 |

ADIGON

| No. | Age | Sex | No. p/hs | Occupation | Income | | | Expenditure | | | | Suplus | Willingness to Pay for Water | | | |
|----------------|-------------|-----|-------------|-------------------|---------|----------|------------------|-------------|---------|---------|------------------|----------------|------------------------------|--------------|----------------|------------|
| | | | | | Main wk | Ext Acti | Total | Food | Educatn | Others | Total | | No. of bkt | amt/bket | Amt/ mth | %of income |
| 1 | 40 | M | 1 | Farming | 500,000 | 20,000 | 520,000 | 300,000 | 0 | 150,000 | 450,000 | 70,000 | 8 | 200 | 48000 | 9.23076923 |
| 2 | 52 | M | 4 | Farming/Painting | 250,000 | 200,000 | 450,000 | 300,000 | 100,000 | 0 | 400,000 | 50,000 | 3 | 200 | 18000 | 4 |
| 3 | 43 | M | 5 | Farming/Mechanics | 800,000 | 100,000 | 900,000 | 600,000 | 150,000 | 80,000 | 830,000 | 70,000 | 6 | 200 | 36000 | 4 |
| 4 | 24 | F | 4 | Teaching/Farming | 60,000 | 75,000 | 135,000 | 50,000 | 20,000 | 0 | 70,000 | 65,000 | 6 | 100 | 18000 | 13.3333333 |
| 5 | 38 | F | 6 | Farming | 440,000 | 240,000 | 680,000 | 280,000 | 225,000 | 70,000 | 575,000 | 105,000 | 10 | 200 | 60000 | 8.82352941 |
| 6 | 39 | M | 5 | Farming | 240,000 | 220,000 | 460,000 | 300,000 | 100,000 | 0 | 400,000 | 60,000 | 3 | 200 | 18000 | 3.91304348 |
| 7 | 24 | F | 2 | Trading | 250,000 | 50,000 | 300,000 | 150,000 | 0 | 100,000 | 250,000 | 50,000 | 5 | 100 | 15000 | 5 |
| 8 | 52 | F | 5 | Trading/Farming | 120,000 | 100,000 | 220,000 | 110,000 | 50,000 | 10,000 | 170,000 | 50,000 | 5 | 100 | 15000 | 6.81818182 |
| 9 | 43 | M | 4 | Farming/Masonry | 400,000 | 50,000 | 450,000 | 200,000 | 120,000 | 50,000 | 370,000 | 80,000 | 5 | 200 | 30000 | 6.66666667 |
| 10 | 24 | F | 5 | Trading/Farming | 80,000 | 100,000 | 180,000 | 50,000 | 20,000 | 0 | 70,000 | 110,000 | 8 | 100 | 24000 | 13.3333333 |
| Total | 379 | | 41 | | | | 4,295,000 | | | | 3,585,000 | 710,000 | 59 | 1,600 | 282,000 | 75 |
| Average | 37.9 | | 4.1 | | | | 429500 | | | | 358500 | 71000 | 5.9 | 160 | 28200 | 7.5 |
| Median | 39.5 | | 4.5 | | | | 450,000 | | | | 385,000 | 67,500 | 5.5 | 200 | 21,000 | 6.7 |

QUESTIONNAIRE FOR SOCIO-ECONOMIC STUDIES ON TEMA / GA DISTRICT
COMMUNITIES

Section A: Demographic Characteristics of Respondents

1. Age:
2. Sex: Male (1) Female (2)
3. Marital Status: Married (1) Separated (2) Divorced (3) Widowed (4)
4. Number of children being Fostered:
5. Level of Education: No education(1) Primary(2)
Middle/TSS(3)Sec/Tech/Voc(4)
TT/Nursing (5) Poly/Univ(6) Other-specify(7).....
6. Current main Occupation:
7. Any other supplementary activity?:

Section B: Income and Expenditure

8. How much money do you get from your occupation per month? c.....
9. About how much do you get as remittances from children/spouse/relatives?
10. How much do you get from other sources?.....
11. About how much do you spend in a month on food? c.....
12. How much do you spend on other expenses in a month other than food? c.....
13. Do you own any facility that brings you income like commill, car etc: Yes No
14. About how much do you get from this source in a month?
c.....

Section C: Capacity and Willingness to Pay for Water

15. Are you satisfied with current water conditions? Why?:
16. How many bucket of water do you need per day?
17. How much can you afford to pay per a bucket of water?
18. Will you pay the amount you have indicated?
19. Why will you pay some money for the water you fetch?
20. How will you get the money to pay?
21. What benefits would you derive from this scheme?

Section D: Assessment of Perception and Acceptability of Borehole Water for Mechanization.

- 21. What are your present sources of water?.....
- 22. Do you have a borehole in your community? Yes No
- 23. Do you like the borehole water Yes No
- 24. Give reasons for your answer above:.....
.....
.....
- 25. Would you agree for the borehole water to be mechanized into a pipe system? Yes No
- 26. Provide reasons for your answer in 25 above:.....
.....
.....

ANNEX 2



Kpone Seduase 062/H/06/BH-1

Project : RWST
 District : Ga
 Community : Kpone Seduase
 Name of Well : 062/H/06/BH-1
 Borehole Depth : 54 m
 Pump Setting : 44 m
 Measured by : VENT-3 Ltd
 Interpreted by : ENDD

Length of Each Step : 60 min
 Number of Steps : 3
 Reference point : Top of PVC
 Height above ground : 0.8m m
 Depth to Static Water Level : 5.32 m
 Pump on : 07/09/2002 11:40 AM
 Pump off : 07/09/2002 11:40 AM

| Bierschenk Wilson Step Test Analysis | | | | | | |
|--|-------------------------|-------------|--------|----------|----------------|----------------|
| Step | Discharge | Measured Sw | Sw/Q | Calc. Sw | Well Loss (m)* | Well Loss (%)* |
| Step 1 | 172.8 m ³ /d | 7.4 m | 0.0428 | 7.5 | 3.21 | 42.86% |
| Step 2 | 216.0 m ³ /d | 10.5 m | 0.0488 | 10.4 | 5.02 | 48.39% |
| Step 3 | 316.8 m ³ /d | 18.6 m | 0.0586 | 18.6 | 10.79 | 57.89% |
| Step 4 | | | | | | |
| Well Drawdown Equation at 60 min pumping : $sw = 0.0247743162817277Q + 0.000107528234765085Q(2)$ | | | | | | |
| Estimated Transmissivity (Logan 1964) : 49.2 m ² /d | | | | | | |

* Note that well losses includes turbulent flow losses within the aquifer



Kpone Seduase 062/H/06/BH-1


Project : RWST
 District : Ga
 Community : Kpone Seduase
 Name of Well : 062/H/06/BH-1
 Borehole Depth : 54 m
 Pump Setting : 44 m
 Measured by : VENT-3 Ltd
 Interpreted by : ENDD

Length of Each Step : 60 min
 Number of Steps : 3
 Reference point : Top of PVC
 Height above ground : 0.8m
 Depth to Static Water Level : 5.32 m
 Pump on : 07/09/2002 11:40 AM
 Pump off : 07/09/2002 11:40 AM

D:\EDWIN\Unihydro pumping test\unihydro pumpingtest-2\STEP TEST KPONE SEDUASE.xls\Plot

| Step 1 | | | Step 2 | | | Step 3 | | | Step 4 | | | Recovery | | |
|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|------------|-----------------|--------------|
| Q : 172.8 m3/d | | | Q : 216.0 m3/d | | | Q : 316.8 m3/d | | | Q : 316.8 m3/d | | | | | |
| Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Recovery (m) |
| 1 | 8.86 | 3.54 | 61 | 13.15 | 7.83 | 121 | 16.89 | 11.57 | 181 | | | 241 | | |
| 2 | 9.91 | 4.59 | 62 | 14.43 | 9.11 | 122 | 18.64 | 13.32 | 182 | | | 242 | | |
| 3 | 10.13 | 4.81 | 63 | 14.64 | 9.32 | 123 | 19.14 | 13.82 | 183 | | | 243 | | |
| 4 | 10.20 | 4.88 | 64 | 14.80 | 9.48 | 124 | 19.72 | 14.40 | 184 | | | 244 | | |
| 5 | 10.47 | 5.15 | 65 | 14.91 | 9.59 | 125 | 20.41 | 15.09 | 185 | | | 245 | | |
| 6 | 10.65 | 5.33 | 66 | 14.99 | 9.67 | 126 | 20.93 | 15.61 | 186 | | | 246 | | |
| 7 | 10.78 | 5.46 | 67 | 15.08 | 9.76 | 127 | 21.47 | 16.15 | 187 | | | 247 | | |
| 8 | 10.90 | 5.58 | 68 | 15.18 | 9.86 | 128 | 21.89 | 16.57 | 188 | | | 248 | | |
| 9 | 10.99 | 5.67 | 69 | 15.23 | 9.91 | 129 | 22.37 | 17.05 | 189 | | | 249 | | |
| 10 | 11.07 | 5.75 | 70 | 15.53 | 10.21 | 130 | 22.79 | 17.47 | 190 | | | 250 | | |
| 15 | 11.45 | 6.13 | 75 | 15.74 | 10.42 | 135 | 23.10 | 17.78 | 195 | | | 255 | | |
| 20 | 11.71 | 6.39 | 80 | 15.88 | 10.56 | 140 | 24.62 | 19.30 | 200 | | | 260 | | |
| 25 | 11.92 | 6.60 | 85 | 16.03 | 10.71 | 145 | 25.80 | 20.48 | 205 | | | 265 | | |
| 30 | 12.11 | 6.79 | 90 | 16.12 | 10.80 | 150 | 27.03 | 21.71 | 210 | | | 270 | | |
| 35 | 12.22 | 6.90 | 95 | 16.22 | 10.90 | 155 | 28.27 | 22.95 | 215 | | | 275 | | |
| 40 | 12.34 | 7.02 | 100 | 16.29 | 10.97 | 160 | 29.08 | 23.76 | 220 | | | 280 | | |
| 45 | 12.44 | 7.12 | 105 | 16.36 | 11.04 | 165 | 30.20 | 24.88 | 225 | | | 285 | | |
| 50 | 12.52 | 7.20 | 110 | 16.43 | 11.11 | 170 | 31.41 | 26.09 | 230 | | | 290 | | |
| 55 | 12.61 | 7.29 | 115 | 16.48 | 11.16 | 175 | 31.98 | 26.66 | 235 | | | 295 | | |
| 60 | 12.68 | 7.36 | 120 | 16.50 | 11.18 | 180 | 32.37 | 27.05 | 240 | | | 300 | | |
| 75 | | | | | | | | | | | | 315 | | |
| 90 | | | | | | | | | | | | 330 | | |
| 105 | | | | | | | | | | | | 345 | | |
| 120 | | | | | | | | | | | | 360 | | |
| 135 | | | | | | | | | | | | 375 | | |
| 150 | | | | | | | | | | | | 390 | | |
| 165 | | | | | | | | | | | | 405 | | |
| 180 | | | | | | | | | | | | 420 | | |
| 195 | | | | | | | | | | | | 435 | | |
| 210 | | | | | | | | | | | | 450 | | |
| 225 | | | | | | | | | | | | 465 | | |
| 240 | | | | | | | | | | | | 480 | | |
| 255 | | | | | | | | | | | | 495 | | |
| 270 | | | | | | | | | | | | 510 | | |

Chart of Step Test Data



Kpone Seduase 062/H/06/BH-1 Constant Rate Test


Project : CWSA
 District : Ga
 Community : Kpone Seduase
 Pumping Well : 062/H/06/BH-1
 Observation Well : 062/H/06/BH-1
 Borehole Depth : 54m
 Pump Setting : 44m
 Height of datum : 0.8m amgl

Distance to Pumping Well : 0.1 m
 Pumping rate : 259.2 m³/d
 Static Water level : 5.34 m
 Measurement Datum : Top of PVC
 Pump on : 08/02/2003 6:00:00 PM
 Pump off : 10/02/2003 6:00:00 PM
 Measured by : VENT-3
 Interpreted by : ENDD

Transmissivity : 90.50 m²/d

Mean Fitting Error : 675.43 %
 Drawdown over 1 log cycle : 0.5241 m

Straight Line Pumping Test Analysis (Cooper & Jakob, 1946)
 Note that this method does not apply to data when $u > 0.05$, to the left of the dotted line
 and that Storativity cannot be calculated without observation wells




Kpone Seduase 062/H/06/BH-1 Constant Rate Test

Project : CWSA
District : Ga
Community : Kpone Seduase
Pumping Well : 062/H/06/BH-1
Observation Well : 062/H/06/BH-1
Borehole Depth : 54m
Pump Setting : 44m
Height of datum : 0.8m amgl

Distance to Pumping Well : 0.1 m
Pumping rate : 259.2 m3/d
Static Water level : 5.34 m
Measurement Datum : Top of PVC
Pump on : 08/02/2003 6:00:00 PM
Pump off : 10/02/2003 6:00:00 PM
Measured by : VENT-3
Interpreted by : ENDD

#N/A

| Data # | Time (GMT) | Time (min) | Water level (meters) | Discharge (l/min) | Cond. (µS/cm) | Drawdown (meters) | Calculated Drawdown | Error % | Included in analysis |
|--------|------------|------------|----------------------|-------------------|---------------|-------------------|---------------------|---------|----------------------|
| 1 | 18:01 | 1.0 | 10.72 | 180.0 | | 5.38 | 13.41 | 149.2 | yes |
| 2 | 18:03 | 2.0 | 13.55 | 180.0 | | 8.21 | 13.56 | 65.2 | yes |
| 3 | 18:04 | 3.0 | 15.65 | 180.0 | | 10.31 | 13.66 | 32.4 | yes |
| 4 | 18:05 | 4.0 | 16.74 | 180.0 | | 11.40 | 13.72 | 20.4 | yes |
| 5 | 18:06 | 5.0 | 17.82 | 180.0 | | 12.48 | 13.77 | 10.4 | yes |
| 6 | 18:07 | 6.0 | 18.18 | 180.0 | | 12.84 | 13.81 | 7.6 | yes |
| 7 | 18:08 | 7.0 | 18.54 | 180.0 | | 13.20 | 13.85 | 4.9 | yes |
| 8 | 18:09 | 8.0 | 18.88 | 180.0 | | 13.54 | 13.88 | 2.5 | yes |
| 9 | 18:10 | 9.0 | 19.13 | 180.0 | | 13.79 | 13.91 | 0.8 | yes |
| 10 | 18:11 | 10.0 | 19.22 | 180.0 | | 13.88 | 13.93 | 0.4 | yes |
| 11 | 18:16 | 15.0 | 19.31 | 180.0 | | 13.97 | 14.02 | 0.4 | yes |
| 12 | 18:21 | 20.0 | 19.39 | 180.0 | | 14.05 | 14.09 | 0.3 | yes |
| 13 | 18:26 | 25.0 | 19.46 | 180.0 | | 14.12 | 14.14 | 0.1 | yes |
| 14 | 18:31 | 30.0 | 19.48 | 180.0 | | 14.14 | 14.18 | 0.3 | yes |
| 15 | 18:36 | 35.0 | 19.50 | 180.0 | | 14.16 | 14.21 | 0.4 | yes |
| 16 | 18:41 | 40.0 | 19.52 | 180.0 | | 14.18 | 14.25 | 0.5 | yes |
| 17 | 18:46 | 45.0 | 19.54 | 180.0 | | 14.20 | 14.27 | 0.5 | yes |
| 18 | 18:51 | 50.0 | 19.56 | 180.0 | | 14.22 | 14.30 | 0.5 | yes |
| 19 | 18:56 | 55.0 | 19.58 | 180.0 | | 14.24 | 14.32 | 0.5 | yes |
| 20 | 19:01 | 60.0 | 19.60 | 180.0 | | 14.26 | 14.34 | 0.5 | yes |
| 21 | 19:16 | 75.0 | 19.62 | 180.0 | | 14.28 | 14.39 | 0.8 | yes |
| 22 | 19:31 | 90.0 | 19.62 | 180.0 | | 14.28 | 14.43 | 1.0 | yes |
| 23 | 19:46 | 105.0 | 19.69 | 180.0 | | 14.35 | 14.46 | 0.8 | yes |
| 24 | 20:01 | 120.0 | 19.79 | 180.0 | | 14.45 | 14.50 | 0.3 | yes |
| 25 | 20:16 | 135.0 | 19.81 | 180.0 | | 14.47 | 14.52 | 0.4 | yes |
| 26 | 20:31 | 150.0 | 19.84 | 180.0 | | 14.50 | 14.55 | 0.3 | yes |
| 27 | 20:46 | 165.0 | 19.87 | 180.0 | | 14.53 | 14.57 | 0.3 | yes |
| 28 | 21:01 | 180.0 | 19.90 | 180.0 | | 14.56 | 14.59 | 0.2 | yes |
| 29 | 21:31 | 210.0 | 19.91 | 180.0 | | 14.57 | 14.62 | 0.4 | yes |
| 30 | 22:01 | 240.0 | 19.96 | 180.0 | | 14.62 | 14.65 | 0.2 | yes |
| 31 | 22:31 | 270.0 | 20.01 | 180.0 | | 14.67 | 14.68 | 0.1 | yes |
| 32 | 23:01 | 300.0 | 20.05 | 180.0 | | 14.71 | 14.70 | 0.0 | yes |
| 33 | 23:31 | 330.0 | 20.07 | 180.0 | | 14.73 | 14.73 | 0.0 | yes |
| 34 | 00:01 | 360.0 | 20.10 | 180.0 | | 14.76 | 14.75 | 0.1 | yes |
| 35 | 01:01 | 420.0 | 20.11 | 180.0 | | 14.77 | 14.78 | 0.1 | yes |
| 36 | 01:31 | 450.0 | 20.15 | 180.0 | | 14.81 | 14.80 | 0.1 | yes |
| 37 | 02:01 | 480.0 | 20.20 | 180.0 | | 14.86 | 14.81 | 0.3 | yes |
| 38 | 02:31 | 510.0 | 20.24 | 180.0 | | 14.90 | 14.82 | 0.5 | yes |
| 39 | 03:01 | 540.0 | 20.29 | 180.0 | | 14.95 | 14.84 | 0.8 | yes |
| 40 | 03:31 | 570.0 | 20.32 | 180.0 | | 14.98 | 14.85 | 0.9 | yes |
| 41 | 04:01 | 600.0 | 20.36 | 180.0 | | 15.02 | 14.86 | 1.1 | yes |
| 42 | 04:31 | 630.0 | 20.36 | 180.0 | | 15.02 | 14.87 | 1.0 | yes |
| 43 | 05:01 | 660.0 | 20.37 | 180.0 | | 15.03 | 14.88 | 1.0 | yes |
| 44 | 05:31 | 690.0 | 20.38 | 180.0 | | 15.04 | 14.89 | 1.0 | yes |
| 45 | 06:01 | 720.0 | 20.39 | 180.0 | | 15.05 | 14.90 | 1.0 | yes |
| 46 | 07:01 | 780.0 | 20.39 | 180.0 | | 15.05 | 14.92 | 0.9 | yes |
| 47 | 08:01 | 840.0 | 20.40 | 180.0 | | 15.06 | 14.94 | 0.8 | yes |
| 48 | 09:01 | 900.0 | 20.41 | 180.0 | | 15.07 | 14.95 | 0.8 | yes |
| 49 | 10:01 | 960.0 | 20.42 | 180.0 | | 15.08 | 14.97 | 0.7 | yes |
| 50 | 11:01 | 1,020.0 | 20.43 | 180.0 | | 15.09 | 14.98 | 0.7 | yes |
| 51 | 12:01 | 1,080.0 | 20.43 | 180.0 | | 15.09 | 15.00 | 0.6 | yes |
| 52 | 13:01 | 1,140.0 | 20.44 | 180.0 | | 15.10 | 15.01 | 0.6 | yes |
| 53 | 14:01 | 1,200.0 | 20.44 | 180.0 | | 15.10 | 15.02 | 0.5 | yes |
| 54 | 15:01 | 1,260.0 | 20.45 | 180.0 | | 15.11 | 15.03 | 0.5 | yes |
| 55 | 16:01 | 1,320.0 | 20.45 | 180.0 | | 15.11 | 15.04 | 0.5 | yes |



Kpone Seduase 062/H/06/BH-1 Constant Rate Test

Project : CWSA
District : Ga
Community : Kpone Seduase
Pumping Well : 062/H/06/BH-1
Observation Well : 062/H/06/BH-1
Borehole Depth : 54m
Pump Setting : 44m
Height of datum : 0.8m amgl

Distance to Pumping Well : 0.1 m
Pumping rate : 259.2 m³/d
Static Water level : 5.34 m
Measurement Datum : Top of PVC
Pump on : 08/02/2003 6:00:00 PM
Pump off : 10/02/2003 6:00:00 PM
Measured by : VENT-3
Interpreted by : ENDD

#N/A

| Data # | Time (GMT) | Time (min) | Water level (meters) | Discharge (l/min) | Cond. (µS/cm) | Drawdown (meters) | Calculated Drawdown | Error % | Included in analysis |
|--------|------------|------------|----------------------|-------------------|---------------|-------------------|---------------------|---------|----------------------|
| 56 | 17:01 | 1,380.0 | 20.46 | 180.0 | | 15.12 | 15.05 | 0.5 | yes |
| 57 | 18:01 | 1,440.0 | 20.47 | 180.0 | | 15.13 | 15.06 | 0.5 | yes |
| 58 | 20:01 | 1,560.0 | 20.48 | 180.0 | | 15.14 | 15.08 | 0.4 | yes |
| 59 | 22:01 | 1,680.0 | 20.49 | 180.0 | | 15.15 | 15.10 | 0.4 | yes |
| 60 | 00:01 | 1,800.0 | 20.51 | 180.0 | | 15.17 | 15.11 | 0.4 | yes |
| 61 | 02:01 | 1,920.0 | 20.52 | 180.0 | | 15.18 | 15.13 | 0.4 | yes |
| 62 | 04:01 | 2,040.0 | 20.52 | 180.0 | | 15.18 | 15.14 | 0.3 | yes |
| 63 | 06:01 | 2,160.0 | 20.53 | 180.0 | | 15.19 | 15.15 | 0.2 | yes |
| 64 | 08:01 | 2,280.0 | 20.54 | 180.0 | | 15.20 | 15.17 | 0.2 | yes |
| 65 | 10:01 | 2,400.0 | 20.55 | 180.0 | | 15.21 | 15.18 | 0.2 | yes |
| 66 | 12:01 | 2,520.0 | 20.57 | 180.0 | | 15.23 | 15.19 | 0.3 | yes |
| 67 | 14:01 | 2,640.0 | 20.57 | 180.0 | | 15.23 | 15.20 | 0.2 | yes |
| 68 | 16:01 | 2,760.0 | 20.58 | 180.0 | | 15.24 | 15.21 | 0.2 | yes |
| 69 | 18:01 | 2,880.0 | 20.60 | 180.0 | | 15.26 | 15.22 | 0.3 | yes |
| 70 | 18:02 | 2,881.0 | 14.38 | RECOVERY | | 9.04 | 15.22 | 68.3 | yes |
| 71 | 18:03 | 2,882.0 | 11.55 | | | 6.21 | 15.22 | 145.1 | yes |
| 72 | 18:04 | 2,883.0 | 9.66 | | | 4.32 | 15.22 | 252.3 | yes |
| 73 | 18:05 | 2,884.0 | 8.70 | | | 3.36 | 15.22 | 352.9 | yes |
| 74 | 18:06 | 2,885.0 | 7.98 | | | 2.64 | 15.22 | 476.5 | yes |
| 75 | 18:07 | 2,886.0 | 7.52 | | | 2.18 | 15.22 | 598.1 | yes |
| 76 | 18:08 | 2,887.0 | 7.21 | | | 1.87 | 15.22 | 713.9 | yes |
| 77 | 18:09 | 2,888.0 | 7.02 | | | 1.68 | 15.22 | 805.9 | yes |
| 78 | 18:10 | 2,889.0 | 6.92 | | | 1.58 | 15.22 | 863.2 | yes |
| 79 | 18:11 | 2,890.0 | 6.83 | | | 1.49 | 15.22 | 921.4 | yes |
| 80 | 18:16 | 2,895.0 | 6.65 | | | 1.31 | 15.22 | 1061.8 | yes |
| 81 | 18:21 | 2,900.0 | 6.56 | | | 1.22 | 15.22 | 1147.6 | yes |
| 82 | 18:26 | 2,905.0 | 6.49 | | | 1.15 | 15.22 | 1223.5 | yes |
| 83 | 18:31 | 2,910.0 | 6.44 | | | 1.10 | 15.22 | 1283.7 | yes |
| 84 | 18:36 | 2,915.0 | 6.38 | | | 1.04 | 15.22 | 1363.6 | yes |
| 85 | 18:41 | 2,920.0 | 6.37 | | | 1.03 | 15.22 | 1377.8 | yes |
| 86 | 18:46 | 2,925.0 | 6.35 | | | 1.01 | 15.22 | 1407.1 | yes |
| 87 | 18:51 | 2,930.0 | 6.32 | | | 0.98 | 15.22 | 1453.3 | yes |
| 88 | 18:56 | 2,935.0 | 6.30 | | | 0.96 | 15.22 | 1485.7 | yes |
| 89 | 19:01 | 2,940.0 | 6.28 | | | 0.94 | 15.22 | 1519.5 | yes |
| 90 | 19:16 | 2,955.0 | 6.22 | | | 0.88 | 15.22 | 1630.0 | yes |
| 91 | 19:31 | 2,970.0 | 6.18 | | | 0.84 | 15.23 | 1712.6 | yes |
| 92 | 19:46 | 2,985.0 | 6.14 | | | 0.80 | 15.23 | 1803.3 | yes |
| 93 | 20:01 | 3,000.0 | 6.12 | | | 0.78 | 15.22 | 1852.3 | yes |
| 94 | 20:16 | 3,015.0 | 6.09 | | | 0.75 | 15.23 | 1930.5 | yes |
| 95 | 20:31 | 3,030.0 | 6.07 | | | 0.73 | 15.23 | 1986.3 | yes |
| 96 | 20:46 | 3,045.0 | 6.05 | | | 0.71 | 15.23 | 2045.2 | yes |
| 97 | 21:01 | 3,060.0 | 6.03 | | | 0.69 | 15.23 | 2107.6 | yes |
| 98 | 21:31 | 3,090.0 | 5.99 | | | 0.65 | 15.23 | 2243.8 | yes |
| 99 | 22:01 | 3,120.0 | 5.95 | | | 0.61 | 15.24 | 2397.8 | yes |
| 100 | 22:31 | 3,150.0 | 5.95 | | | 0.61 | 15.24 | 2398.2 | yes |
| 101 | 23:01 | 3,180.0 | 5.92 | | | 0.58 | 15.24 | 2527.8 | yes |
| 102 | 23:31 | 3,210.0 | 5.91 | | | 0.57 | 15.24 | 2574.3 | yes |
| 103 | 00:01 | 3,240.0 | 5.91 | | | 0.57 | 15.25 | 2574.6 | yes |
| 104 | 00:31 | 3,270.0 | 5.89 | | | 0.55 | 15.25 | 2672.3 | yes |
| 105 | 01:01 | 3,300.0 | 5.86 | | | 0.52 | 15.25 | 2832.6 | yes |
| 106 | 01:31 | 3,330.0 | 5.85 | | | 0.51 | 15.25 | 2890.5 | yes |
| 107 | 02:01 | 3,360.0 | 5.84 | | | 0.50 | 15.25 | 2950.7 | yes |
| 108 | 02:31 | 3,390.0 | 5.83 | | | 0.49 | 15.26 | 3013.4 | yes |
| 109 | 03:01 | 3,420.0 | 5.82 | | | 0.48 | 15.26 | 3078.7 | yes |
| 110 | 03:31 | 3,450.0 | 5.81 | | | 0.47 | 15.26 | 3146.7 | yes |

Kpone Seduase BH-1

Estimated Maximum Sustainable Well Yield Calculation

| Pumping Test & Borehole Parameters | | | |
|------------------------------------|---------|-------------------|---|
| Q | 180 | l/min | Constant rate pumping test yield |
| | 10.8 | m ³ /h | |
| | 259.2 | m ³ /d | |
| t _{pump test} | 2,880 | minutes | Pumping test duration |
| | 2 | days | |
| r | 8.5 | inch | Effective well diameter |
| | 0.10795 | m | Effective well radius |
| swl | 5.32 | m | Static water level below datum before pumping test |
| s | 15.26 | m | Drawdown at end of pumping test |
| Δs | 0.5241 | m | Change in drawdown over one log cycle of time |
| pwl _{max} | 37 | m | Maximum allowable pumping water level below datum |
| Δs _{seasonal} | 3 | m | Estimated seasonal water level decline |
| s _{max} | 28.68 | m | Maximum allowable drawdown |
| T | 90.5 | m ² /d | Transmissivity calculated from pumping test data |
| s _{min} | 0.005 | | Minimum likely storativity |
| s _{max} | 0.03 | | Maximum likely storativity |
| E _{step test} | 0.36 | | Well efficiency estimated from step test |
| E _{min} | 0.24 | | Well efficiency estimated from Transmissivity & minimum likely Storativity |
| E _{max} | 0.21 | | Well efficiency estimated from Transmissivity & maximum likely Storativity |
| E _{min} | 0.24 | | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| E _{max} | 0.21 | | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| t | 300 | d | Length of hydrological year without recharge - the time between two rainy seasons |


$$Q_{max} = \frac{E \cdot s_{max} \cdot T}{0.183 \log(2.25 Tt / r^2 S)}$$

The sustainable yield formula is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946)

| Estimated Maximum Sustainable Well Yield at Continuous 24/24 Hour Pumping | | | | | | | | | | |
|---|-----------------------|-------------------|-----------------------|-------------------|-----------------------|-------------------|-----------------------|-------------------|-------------------------|-------------------|
| Q _{max} | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.005 | | 0.03 | | 0.005 | | 0.03 | | 0.03 | |
| E | 0.36 | | 0.36 | | 0.24 | | 0.21 | | 0.208356219 | |
| 24/24 h Pumping Cycle | 566 | 23.6 | 619 | 25.8 | 370 | 15.4 | 359 | 14.9 | 359 | 14.9 |
| | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Predicted Drawdown at Estimated Maximum Sustainable Yield



Kpone Seduase BH-1 Estimated Maximum Sustainable Well Yield Calculation


$$Q_{max} = \frac{E \cdot 0.228 \cdot S_{max} \cdot T}{t_1 \log(t_2 - 1 + t_1 / t_1) + \log(2.25 T t_1 / (r^2 S))}$$

The sustainable yield formula for intermittent pumping is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946) and the imaginary well procedure outlined in "Groundwater & Wells" Driscoll, 1986.

| Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates | | | | | | | | | | |
|---|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|---------------------------------|
| | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.005 | | 0.03 | | 0.005 | | 0.03 | | - | |
| E | 0.36 | | 0.36 | | 0.24 | | 0.21 | | - | |
| Daily Pumping Cycle (hrs) | Q _{max} (1a) m ³ /h | Volume (1a) m ³ /d | Q _{max} (1b) m ³ /h | Volume (1b) m ³ /d | Q _{max} (2a) m ³ /h | Volume (2a) m ³ /d | Q _{max} (2b) m ³ /h | Volume (2b) m ³ /d | Lowest Q _{max} m ³ /h | Lowest Volume m ³ /d |
| 8 | 30.2 | 242 | 34.0 | 272 | 19.7 | 168 | 19.7 | 157 | 19.7 | 157 |
| 9 | 29.6 | 266 | 33.1 | 298 | 19.3 | 174 | 19.2 | 173 | 19.2 | 173 |
| 10 | 29.0 | 290 | 32.4 | 324 | 18.9 | 189 | 18.8 | 188 | 18.8 | 188 |
| 11 | 28.4 | 313 | 31.7 | 349 | 18.6 | 204 | 18.4 | 202 | 18.4 | 202 |
| 12 | 27.9 | 335 | 31.1 | 373 | 18.2 | 219 | 18.0 | 216 | 18.0 | 216 |
| 13 | 27.4 | 357 | 30.6 | 397 | 17.9 | 233 | 17.7 | 229 | 17.7 | 229 |
| 14 | 27.0 | 378 | 30.0 | 419 | 17.6 | 247 | 17.3 | 243 | 17.3 | 243 |
| 15 | 26.6 | 399 | 29.4 | 442 | 17.4 | 260 | 17.0 | 256 | 17.0 | 256 |
| 16 | 26.2 | 419 | 29.0 | 463 | 17.1 | 274 | 16.8 | 268 | 16.8 | 268 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly. It is unwise to select a pumping rate that exceeds those used during the pumping tests, without further tests.

Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates



Kpone Seduase BH-1 Estimated Maximum Sustainable Well Yield Calculation


$$s = \frac{0.183 Q}{E \cdot T} [t_1 \log ((t_2 - 1 + t_1) / t_1) + \log (2.25 T t_1 / (r^2 S))]$$

The formula for estimated drawdown due to intermittent pumping is based on the imaginary well procedure outlined in "Groundwater & Wells", Driscoll, 1986.

| Estimated Drawdown at Intermittent Pumping Rates | | | | | | |
|--|---------------------------|------------------------------------|---|---|---|---|
| Scenario | | | 1a | 1b | 2a | 2b |
| Storativity (S) | | | 0.005 | 0.03 | 0.005 | 0.03 |
| Well Efficiency (E) | | | 0.36 | 0.36 | 0.24 | 0.21 |
| Water Demand (m ³ /d) | Daily Pumping Cycle (hrs) | Q _{abs} m ³ /h | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season |
| 120.0 | 8 | 15.0 | 14.3 | 12.7 | 21.8 | 21.9 |
| | 9 | 13.3 | 13.0 | 11.6 | 19.8 | 20.0 |
| | 10 | 12.0 | 11.9 | 10.6 | 18.2 | 18.4 |
| | 11 | 10.9 | 11.0 | 9.9 | 16.9 | 17.1 |
| | 12 | 10.0 | 10.3 | 9.2 | 15.8 | 16.0 |
| | 13 | 9.2 | 9.7 | 8.7 | 14.8 | 15.0 |
| | 14 | 8.6 | 9.1 | 8.2 | 14.0 | 14.2 |
| | 15 | 8.0 | 8.6 | 7.8 | 13.2 | 13.5 |
| | 16 | 7.5 | 8.2 | 7.4 | 12.6 | 12.9 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Estimated Drawdown at the End of the Dry Season at Various Pumping Cycles



Water Demand = 120 m³/d

Note that drawdown cannot exceed the maximum allowable drawdown, S_{max}

Oyibi B01



Project : CWSA GAR
 District : Tema
 Community : Oyibi
 Name of Well : B01
 Eastings : E 00° 00' 00.0"
 Northings : N 00° 00' 00.0"
 Measured by : Vent-3 Ltd
 Interpreted by : UniHydro

Length of Each Step : 60 min
 Number of Steps : 4
 Reference point : Top of casing
 Height above ground : 1 m
 Depth to Static Water Level : 20.27 m
 Pump on : 18/10/2002 4:00 PM
 Pump off : 18/10/2002 8:00 PM

| Bierschenk Wilson Step Test Analysis | | | | | | |
|--------------------------------------|------------|-------------|--------|----------|----------------|----------------|
| Step | Discharge | Measured Sw | Sw/Q | Calc. Sw | Well Loss (m)* | Well Loss (%)* |
| Step 1 | 216.0 m3/d | 19.1 m | 0.0883 | 19.3 | 4.65 | 24.08% |
| Step 2 | 259.2 m3/d | 24.7 m | 0.0951 | 24.3 | 6.70 | 27.57% |
| Step 3 | 288.0 m3/d | 28.2 m | 0.0981 | 27.8 | 8.27 | 29.72% |
| Step 4 | 316.8 m3/d | 31.0 m | 0.0979 | 31.5 | 10.01 | 31.75% |

Well Drawdown Equation at 60 min pumping : $sw = 0.0679267923573392Q + 9.97585941773415E-05Q(2)$
 Estimated Transmissivity (Logan 1964) : 18.0 m2/d

* Note that well losses includes turbulent flow losses within the aquifer




Oyibi B01

Project : CWSA GAR
 District : Tema
 Community : Oyibi
 Name of Well : B01
 Eastings : E 00° 00' 00.0"
 Northings : N 00° 00' 00.0"
 Measured by : Vent-3 Ltd
 Interpreted by : UniHydro

Length of Each Step : 60 min
 Number of Steps : 4
 Reference point : Top of casing
 Height above ground : 1.00 m
 Depth to Static Water Level : 20.27 m
 Pump on : 18/10/2002 4:00 PM
 Pump off : 18/10/2002 8:00 PM

D:\EDWIN\UniHydro pumping test\unihydro pumpingtest-2\STEP TEST OYIBI.xls\Plot

| Step 1 | | | Step 2 | | | Step 3 | | | Step 4 | | | Recovery | | |
|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|------------|-----------------|--------------|
| Q : 216.0 m3/d | | | Q : 259.2 m3/d | | | Q : 288.0 m3/d | | | Q : 316.8 m3/d | | | | | |
| Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Recovery (m) |
| 1 | 28.64 | 8.37 | 61 | 40.89 | 20.62 | 121 | 45.84 | 25.57 | 181 | 49.39 | 29.12 | 241 | | |
| 2 | 29.94 | 9.67 | 62 | 41.90 | 21.63 | 122 | 46.37 | 26.10 | 182 | 49.51 | 29.24 | 242 | | |
| 3 | 31.22 | 10.95 | 63 | 42.79 | 22.52 | 123 | 46.70 | 26.43 | 183 | 49.60 | 29.33 | 243 | | |
| 4 | 32.47 | 12.20 | 64 | 43.59 | 23.32 | 124 | 47.00 | 26.73 | 184 | 49.66 | 29.39 | 244 | | |
| 5 | 33.51 | 13.24 | 65 | 44.34 | 24.07 | 125 | 47.22 | 26.95 | 185 | 49.69 | 29.42 | 245 | | |
| 6 | 34.21 | 13.94 | 66 | 44.73 | 24.46 | 126 | 47.41 | 27.14 | 186 | 49.73 | 29.46 | 246 | | |
| 7 | 34.89 | 14.62 | 67 | 44.79 | 24.52 | 127 | 47.58 | 27.31 | 187 | 49.78 | 29.51 | 247 | | |
| 8 | 35.31 | 15.04 | 68 | 44.83 | 24.56 | 128 | 47.72 | 27.45 | 188 | 49.84 | 29.57 | 248 | | |
| 9 | 35.77 | 15.50 | 69 | 44.85 | 24.58 | 129 | 47.83 | 27.56 | 189 | 49.88 | 29.61 | 249 | | |
| 10 | 36.08 | 15.81 | 70 | 44.87 | 24.60 | 130 | 47.91 | 27.64 | 190 | 49.91 | 29.64 | 250 | | |
| 15 | 38.07 | 17.80 | 75 | 44.94 | 24.67 | 135 | 48.09 | 27.82 | 195 | 50.03 | 29.76 | 255 | | |
| 20 | 39.00 | 18.73 | 80 | 44.99 | 24.72 | 140 | 48.26 | 27.99 | 200 | 50.84 | 30.57 | 260 | | |
| 25 | 39.07 | 18.80 | 85 | 45.04 | 24.77 | 145 | 48.38 | 28.11 | 205 | 51.42 | 31.15 | 265 | | |
| 30 | 39.13 | 18.86 | 90 | 45.08 | 24.81 | 150 | 48.51 | 28.24 | 210 | 51.63 | 31.36 | 270 | | |
| 35 | 39.22 | 18.95 | 95 | 45.11 | 24.84 | 155 | 48.57 | 28.30 | 215 | 51.77 | 31.50 | 275 | | |
| 40 | 39.29 | 19.02 | 100 | 45.13 | 24.86 | 160 | 48.63 | 28.36 | 220 | 51.89 | 31.62 | 280 | | |
| 45 | 39.34 | 19.07 | 105 | 45.15 | 24.88 | 165 | 48.67 | 28.40 | 225 | 52.00 | 31.73 | 285 | | |
| 50 | 39.37 | 19.10 | 110 | 45.18 | 24.91 | 170 | 48.70 | 28.43 | 230 | 52.09 | 31.82 | 290 | | |
| 55 | 39.39 | 19.12 | 115 | 45.20 | 24.93 | 175 | 48.71 | 28.44 | 235 | 52.17 | 31.90 | 295 | | |
| 60 | 39.39 | 19.12 | 120 | 45.21 | 24.94 | 180 | 48.73 | 28.46 | 240 | 52.23 | 31.96 | 300 | | |
| 70 | | | | | | | | | | | | 310 | | |
| 80 | | | | | | | | | | | | 320 | | |
| 90 | | | | | | | | | | | | 330 | | |
| 100 | | | | | | | | | | | | 340 | | |
| 110 | | | | | | | | | | | | 350 | | |
| 120 | | | | | | | | | | | | 360 | | |
| 130 | | | | | | | | | | | | 370 | | |
| 140 | | | | | | | | | | | | 380 | | |
| 150 | | | | | | | | | | | | 390 | | |
| 160 | | | | | | | | | | | | 400 | | |
| 170 | | | | | | | | | | | | 410 | | |
| 180 | | | | | | | | | | | | 420 | | |
| 190 | | | | | | | | | | | | 430 | | |
| 200 | | | | | | | | | | | | 440 | | |



Oyibi BO1 Constant Rate Test

Project : CWSA
 District : Ga
 Community : Oyibi
 Pumping Well : BO1
 Observation Well : BO1
 Borehole Depth : 71m
 Pump Setting : 60m
 Height of datum : 0.8m amgl

Distance to Pumping Well : 0.1 m
 Pumping rate : 288.0 m3/d
 Static Water level : 20.31 m
 Measurement Datum : Top of PVC
 Pump on : 08/02/2003 6:00:00 PM
 Pump off : 10/02/2003 6:00:00 PM
 Measured by : VENT-3
 Interpreted by : ENDD

D:\EDWIN\Hydro pumping test\hydro pumping test-2\OYIBI BH-1-2 Cooper-Jakob XL V1.xls\Print

| Data # | Time (GMT) | Time (min) | Water level (meters) | Discharge (l/min) | Cond. (µS/cm) | Drawdown (meters) | Calculated Drawdown | Error % | Included in analysis |
|--------|------------|------------|----------------------|-------------------|---------------|-------------------|---------------------|---------|----------------------|
| 1 | 18:01 | 1.0 | 34.84 | 200.0 | | 14.53 | 26.61 | 83.1 | yes |
| 2 | 18:03 | 2.0 | 39.93 | | | 19.62 | 26.85 | 36.9 | yes |
| 3 | 18:04 | 3.0 | 42.15 | | | 21.84 | 27.00 | 23.6 | yes |
| 4 | 18:05 | 4.0 | 43.74 | | | 23.43 | 27.10 | 15.7 | yes |
| 5 | 18:06 | 5.0 | 44.08 | 200.0 | | 23.77 | 27.18 | 14.3 | yes |
| 6 | 18:07 | 6.0 | 44.26 | | | 23.95 | 27.25 | 13.8 | yes |
| 7 | 18:08 | 7.0 | 44.38 | | | 24.07 | 27.30 | 13.4 | yes |
| 8 | 18:09 | 8.0 | 44.47 | | | 24.16 | 27.35 | 13.2 | yes |
| 9 | 18:10 | 9.0 | 44.56 | | | 24.25 | 27.39 | 12.9 | yes |
| 10 | 18:11 | 10.0 | 44.62 | | | 24.31 | 27.43 | 12.8 | yes |
| 11 | 18:16 | 15.0 | 44.86 | | | 24.55 | 27.57 | 12.3 | yes |
| 12 | 18:21 | 20.0 | 44.99 | | | 24.68 | 27.67 | 12.1 | yes |
| 13 | 18:26 | 25.0 | 45.11 | | | 24.80 | 27.75 | 11.9 | yes |
| 14 | 18:31 | 30.0 | 45.19 | 200.0 | | 24.88 | 27.82 | 11.8 | yes |
| 15 | 18:36 | 35.0 | 45.30 | | | 24.99 | 27.87 | 11.5 | yes |
| 16 | 18:41 | 40.0 | 45.38 | | | 25.07 | 27.92 | 11.4 | yes |
| 17 | 18:46 | 45.0 | 45.45 | | | 25.14 | 27.96 | 11.2 | yes |
| 18 | 18:51 | 50.0 | 45.53 | | | 25.22 | 28.00 | 11.0 | yes |
| 19 | 18:56 | 55.0 | 45.59 | | | 25.28 | 28.03 | 10.9 | yes |
| 20 | 19:01 | 60.0 | 45.66 | 200.0 | | 25.35 | 28.06 | 10.7 | yes |
| 21 | 19:16 | 75.0 | 45.82 | | | 25.51 | 28.14 | 10.3 | yes |
| 22 | 19:31 | 90.0 | 45.96 | 200.0 | | 25.65 | 28.21 | 10.0 | yes |
| 23 | 19:46 | 105.0 | 46.12 | | | 25.81 | 28.26 | 9.5 | yes |
| 24 | 20:01 | 120.0 | 46.28 | 200.0 | | 25.97 | 28.31 | 9.0 | yes |
| 25 | 20:16 | 135.0 | 46.41 | | | 26.10 | 28.35 | 8.6 | yes |
| 26 | 20:31 | 150.0 | 46.54 | 200.0 | | 26.23 | 28.39 | 8.2 | yes |
| 27 | 20:46 | 165.0 | 46.66 | | | 26.35 | 28.42 | 7.9 | yes |
| 28 | 21:01 | 180.0 | 46.77 | 200.0 | | 26.46 | 28.45 | 7.5 | yes |
| 29 | 21:31 | 210.0 | 47.06 | | | 26.75 | 28.51 | 6.6 | yes |
| 30 | 22:01 | 240.0 | 47.37 | 200.0 | | 27.06 | 28.56 | 5.5 | yes |
| 31 | 22:31 | 270.0 | 47.54 | | | 27.23 | 28.60 | 5.0 | yes |
| 32 | 23:01 | 300.0 | 47.71 | 200.0 | | 27.40 | 28.64 | 4.5 | yes |
| 33 | 23:31 | 330.0 | 47.88 | | | 27.57 | 28.67 | 4.0 | yes |
| 34 | 00:01 | 360.0 | 48.04 | 200.0 | | 27.73 | 28.70 | 3.5 | yes |
| 35 | 00:31 | 390.0 | 48.23 | | | 27.92 | 28.73 | 2.9 | yes |
| 36 | 01:01 | 420.0 | 48.43 | 200.0 | | 28.12 | 28.76 | 2.3 | yes |
| 37 | 01:31 | 450.0 | 48.67 | | | 28.36 | 28.78 | 1.5 | yes |
| 38 | 02:01 | 480.0 | 48.94 | 200.0 | | 28.63 | 28.80 | 0.6 | yes |
| 39 | 02:31 | 510.0 | 49.01 | | | 28.70 | 28.82 | 0.4 | yes |
| 40 | 03:01 | 540.0 | 49.04 | 200.0 | | 28.73 | 28.84 | 0.4 | yes |
| 41 | 03:31 | 570.0 | 49.09 | | | 28.78 | 28.86 | 0.3 | yes |
| 42 | 04:01 | 600.0 | 49.13 | 200.0 | | 28.82 | 28.88 | 0.2 | yes |
| 43 | 04:31 | 630.0 | 49.20 | | | 28.89 | 28.90 | 0.0 | yes |
| 44 | 05:01 | 660.0 | 49.26 | 200.0 | | 28.95 | 28.92 | 0.1 | yes |
| 45 | 05:31 | 690.0 | 49.29 | 200.0 | | 28.98 | 28.93 | 0.2 | yes |
| 46 | 06:01 | 720.0 | 49.33 | 200.0 | | 29.02 | 28.95 | 0.3 | yes |
| 47 | 07:01 | 780.0 | 49.35 | | | 29.04 | 28.98 | 0.2 | yes |
| 48 | 08:01 | 840.0 | 49.38 | | | 29.07 | 29.00 | 0.2 | yes |
| 49 | 09:01 | 900.0 | 49.39 | | | 29.08 | 29.03 | 0.2 | yes |
| 50 | 10:01 | 960.0 | 49.41 | | | 29.10 | 29.05 | 0.2 | yes |
| 51 | 11:01 | 1,020.0 | 49.42 | | | 29.11 | 29.07 | 0.1 | yes |
| 52 | 12:01 | 1,080.0 | 49.42 | | | 29.11 | 29.09 | 0.1 | yes |
| 53 | 13:01 | 1,140.0 | 49.45 | 200.0 | | 29.14 | 29.11 | 0.1 | yes |
| 54 | 14:01 | 1,200.0 | 49.47 | | | 29.16 | 29.13 | 0.1 | yes |
| 55 | 15:01 | 1,260.0 | 49.48 | | | 29.17 | 29.15 | 0.1 | yes |

Oyibi BH-1

Estimated Maximum Sustainable Well Yield Calculation

| Pumping Test & Borehole Parameters | | | |
|------------------------------------|--------|-------------------|---|
| Q | 200 | l/min | Constant rate pumping test yield |
| | 12.0 | m ³ /h | |
| | 288 | m ³ /d | |
| t_{pump test} | 4,320 | minutes | Pumping test duration |
| | 3 | days | |
| r | 6 | inch | Effective well diameter |
| | 0.0762 | m | |
| swl | 20.31 | m | Static water level below datum before pumping test |
| s | 29.83 | m | Drawdown at end of pumping test |
| Δs | 0.8186 | m | Change in drawdown over one log cycle of time |
| pwl_{max} | 54 | m | Maximum allowable pumping water level below datum |
| Δs_{seasonal} | 3 | m | Estimated seasonal water level decline |
| s_{max} | 30.69 | m | Maximum allowable drawdown |
| T | 64.39 | m ² /d | Transmissivity calculated from pumping test data |
| S_{min} | 0.005 | | Minimum likely storativity |
| S_{max} | 0.03 | | Maximum likely storativity |
| E_{step test} | 0.70 | | Well efficiency estimated from step test |
| E_{min} | 0.20 | | Well efficiency estimated from Transmissivity & minimum likely Storativity |
| E_{max} | 0.18 | | Well efficiency estimated from Transmissivity & maximum likely Storativity |
| E_{min} | 0.20 | | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| E_{max} | 0.18 | | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| t | 300 | d | Length of hydrological year without recharge - the time between two rainy seasons |


$$Q_{max} = \frac{E \cdot s_{max} \cdot T}{0.183 \log(2.25 Tt / r^2 S)}$$

The sustainable yield formula is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946)

| Estimated Maximum Sustainable Well Yield at Continuous 24/24 Hour Pumping | | | | | | | | | | |
|---|--------------------------|---------------------------|--------------------------|---------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| Q _{max} | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.005 | | 0.03 | | 0.005 | | 0.03 | | 0.03 | |
| E | 0.70 | | 0.70 | | 0.20 | | 0.18 | | 0.175531243 | |
| 24/24 h Pumping Cycle | 824 m ³ /d | 34.3 m ³ /h | 900 m ³ /d | 37.5 m ³ /h | 232 m ³ /d | 9.7 m ³ /h | 226 m ³ /d | 9.4 m ³ /h | 226 m ³ /d | 9.4 m ³ /h |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Predicted Drawdown at Estimated Maximum Sustainable Yield



Oyibi BH-1

Estimated Maximum Sustainable Well Yield Calculation


$$Q_{max} = \frac{E \cdot 0.228 \cdot s_{max} \cdot T}{t_1 \log(t_2 - 1 + t_1 / t_2) + \log(2.25 T t_1 / (r^2 S))}$$

The sustainable yield formula for intermittent pumping is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946) and the imaginary well procedure outlined in "Groundwater & Wells" Driscoll, 1986.

| Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates | | | | | | | | | | |
|---|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|---------------------------------|
| | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.005 | | 0.03 | | 0.005 | | 0.03 | | - | |
| E | 0.70 | | 0.70 | | 0.20 | | 0.18 | | - | |
| Daily Pumping Cycle (hrs) | Q _{max} (1a) m ³ /h | Volume (1a) m ³ /d | Q _{max} (1b) m ³ /h | Volume (1b) m ³ /d | Q _{max} (2a) m ³ /h | Volume (2a) m ³ /d | Q _{max} (2b) m ³ /h | Volume (2b) m ³ /d | Lowest Q _{max} m ³ /h | Lowest Volume m ³ /d |
| 8 | 43.8 | 350 | 49.1 | 393 | 12.3 | 98 | 12.3 | 98 | 12.3 | 98 |
| 9 | 42.8 | 386 | 47.9 | 431 | 12.1 | 108 | 12.0 | 108 | 12.0 | 108 |
| 10 | 42.0 | 420 | 46.9 | 469 | 11.8 | 118 | 11.8 | 118 | 11.8 | 118 |
| 11 | 41.2 | 454 | 45.9 | 505 | 11.6 | 128 | 11.5 | 127 | 11.5 | 127 |
| 12 | 40.5 | 486 | 45.0 | 540 | 11.4 | 137 | 11.3 | 135 | 11.3 | 135 |
| 13 | 39.8 | 518 | 44.2 | 574 | 11.2 | 146 | 11.1 | 144 | 11.1 | 144 |
| 14 | 39.2 | 549 | 43.4 | 608 | 11.0 | 154 | 10.9 | 152 | 10.9 | 152 |
| 15 | 38.6 | 579 | 42.7 | 640 | 10.9 | 163 | 10.7 | 161 | 10.7 | 161 |
| 16 | 38.0 | 609 | 42.0 | 672 | 10.7 | 171 | 10.5 | 168 | 10.5 | 168 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly. It is unwise to select a pumping rate that exceeds those used during the pumping tests, without further tests.

Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates



Oyibi BH-1

Estimated Maximum Sustainable Well Yield Calculation


$$s = \frac{0.183 Q}{E \cdot T} [t_1 \log ((t_2 - 1 + t_1) / t_1) + \log (2.25 T t_1 / (r^2 S))]$$

The formula for estimated drawdown due to intermittent pumping is based on the imaginary well procedure outlined in "Groundwater & Wells", Driscoll, 1986

| Estimated Drawdown at Intermittent Pumping Rates | | | | | | |
|--|---------------------------|------------------------------------|---|---|---|---|
| Scenario | | | 1a | 1b | 2a | 2b |
| Storativity (S) | | | 0.005 | 0.03 | 0.005 | 0.03 |
| Well Efficiency (E) | | | 0.70 | 0.70 | 0.20 | 0.18 |
| Water Demand (m ³ /d) | Daily Pumping Cycle (hrs) | Q _{obs} m ³ /h | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season |
| 130.0 | 8 | 16.3 | 11.4 | 10.2 | 40.6 | 40.6 |
| | 9 | 14.4 | 10.4 | 9.3 | 36.8 | 36.9 |
| | 10 | 13.0 | 9.5 | 8.5 | 33.8 | 34.0 |
| | 11 | 11.8 | 8.8 | 7.9 | 31.3 | 31.6 |
| | 12 | 10.8 | 8.2 | 7.4 | 29.2 | 29.5 |
| | 13 | 10.0 | 7.7 | 7.0 | 27.4 | 27.7 |
| | 14 | 9.3 | 7.3 | 6.6 | 25.9 | 26.2 |
| | 15 | 8.7 | 6.9 | 6.2 | 24.5 | 24.9 |
| | 16 | 8.1 | 6.6 | 5.9 | 23.3 | 23.7 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Estimated Drawdown at the End of the Dry Season at Various Pumping Cycles



Water Demand = 130 m³/d

Note that drawdown cannot exceed the maximum allowable drawdown of 30.5m

OLD SAASABI

SUSTAINABLE YIELD RESULTS

Old Saasabi 062/H/18/BH-1


Project : RWST
 District : Ga
 Community : Old Saasabi
 Name of Well : 062/H/18/BH-1
 Borehole Depth : 45 m
 Pump Setting : 33 m
 Measured by : VENT-3 Ltd
 Interpreted by : ENDD

Length of Each Step : 60 min
 Number of Steps : 4
 Reference point : Top of PVC
 Height above ground : 0.72m
 Depth to Static Water Level : 13.40 m
 Pump on : 08/02/2003 9:30 PM
 Pump off : 08/02/2003 11:55 PM

D:\EDWIN\Unihydro pumping test\unihydro pumpingtest-2\STEP TEST OLD SAASABI.xls\Plot

| Step 1 | | | Step 2 | | | Step 3 | | | Step 4 | | | Recovery | | |
|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|----------------|-----------------|---------------|------------|-----------------|--------------|
| Q : 158.4 m3/d | | | Q : 201.6 m3/d | | | Q : 259.2 m3/d | | | Q : 316.8 m3/d | | | | | |
| Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Draw-down (m) | Time (min) | Water Level (m) | Recovery (m) |
| 1 | 15.61 | 2.21 | 61 | 18.58 | 5.18 | 121 | 20.24 | 6.84 | 181 | 23.42 | 10.02 | 241 | | |
| 2 | 16.62 | 3.22 | 62 | 18.91 | 5.51 | 122 | 20.56 | 7.16 | 182 | 23.94 | 10.54 | 242 | | |
| 3 | 16.81 | 3.41 | 63 | 18.96 | 5.56 | 123 | 20.79 | 7.39 | 183 | 24.19 | 10.79 | 243 | | |
| 4 | 16.89 | 3.49 | 64 | 19.00 | 5.60 | 124 | 20.86 | 7.46 | 184 | 24.30 | 10.90 | 244 | | |
| 5 | 16.92 | 3.52 | 65 | 19.01 | 5.61 | 125 | 21.20 | 7.80 | 185 | 24.34 | 10.94 | 245 | | |
| 6 | 16.95 | 3.55 | 66 | 19.02 | 5.62 | 126 | 21.27 | 7.87 | 186 | 24.41 | 11.01 | 246 | | |
| 7 | 16.94 | 3.54 | 67 | 19.03 | 5.63 | 127 | 21.32 | 7.92 | 187 | 24.42 | 11.02 | 247 | | |
| 8 | 16.95 | 3.55 | 68 | 19.04 | 5.64 | 128 | 21.35 | 7.95 | 188 | 24.45 | 11.05 | 248 | | |
| 9 | 16.95 | 3.55 | 69 | 19.05 | 5.65 | 129 | 21.38 | 7.98 | 189 | 24.48 | 11.08 | 249 | | |
| 10 | 16.96 | 3.56 | 70 | 19.05 | 5.65 | 130 | 21.43 | 8.03 | 190 | 24.51 | 11.11 | 250 | | |
| 15 | 16.99 | 3.59 | 75 | 19.07 | 5.67 | 135 | 21.45 | 8.05 | 195 | 24.53 | 11.13 | 255 | | |
| 20 | 17.00 | 3.60 | 80 | 19.09 | 5.69 | 140 | 21.48 | 8.08 | 200 | 24.54 | 11.14 | 260 | | |
| 25 | 17.02 | 3.62 | 85 | 19.10 | 5.70 | 145 | 21.49 | 8.09 | 205 | 24.55 | 11.15 | 265 | | |
| 30 | 17.02 | 3.62 | 90 | 19.12 | 5.72 | 150 | 21.49 | 8.09 | 210 | 24.57 | 11.17 | 270 | | |
| 35 | 17.03 | 3.63 | 95 | 19.13 | 5.73 | 155 | 21.48 | 8.08 | 215 | 24.59 | 11.19 | 275 | | |
| 40 | 17.03 | 3.63 | 100 | 19.15 | 5.75 | 160 | 21.48 | 8.08 | 220 | 24.60 | 11.20 | 280 | | |
| 45 | 17.03 | 3.63 | 105 | 19.15 | 5.75 | 165 | 21.49 | 8.09 | 225 | 24.59 | 11.19 | 285 | | |
| 50 | 17.03 | 3.63 | 110 | 19.15 | 5.75 | 170 | 21.50 | 8.10 | 230 | 24.60 | 11.20 | 290 | | |
| 55 | 17.03 | 3.63 | 115 | 19.16 | 5.76 | 175 | 21.50 | 8.10 | 235 | 24.61 | 11.21 | 295 | | |
| 60 | 17.03 | 3.63 | 120 | 19.16 | 5.76 | 180 | 21.51 | 8.11 | 240 | 24.61 | 11.21 | 300 | | |
| 75 | | | | | | | | | | | | 315 | | |
| 90 | | | | | | | | | | | | 330 | | |
| 105 | | | | | | | | | | | | 345 | | |
| 120 | | | | | | | | | | | | 360 | | |
| 135 | | | | | | | | | | | | 375 | | |
| 150 | | | | | | | | | | | | 390 | | |
| 165 | | | | | | | | | | | | 405 | | |
| 180 | | | | | | | | | | | | 420 | | |
| 195 | | | | | | | | | | | | 435 | | |
| 210 | | | | | | | | | | | | 450 | | |
| 225 | | | | | | | | | | | | 465 | | |
| 240 | | | | | | | | | | | | 480 | | |
| 255 | | | | | | | | | | | | 495 | | |
| 270 | | | | | | | | | | | | 510 | | |

Chart of Step Test Data





Old Saasabi 062/H/18/BH-1

Project : RWST
 District : Ga
 Community : Old Saasabi
 Name of Well : 062/H/18/BH-1
 Borehole Depth : 45 m
 Pump Setting : 33 m
 Measured by : VENT-3 Ltd
 Interpreted by : ENDD

Length of Each Step : 60 min
 Number of Steps : 4
 Reference point : Top of PVC
 Height above ground : 0.72m m
 Depth to Static Water Level : 13.4 m
 Pump on : 08/02/2003 9:30 PM
 Pump off : 08/02/2003 11:55 PM

| Bierschenk Wilson Step Test Analysis | | | | | | |
|--|------------|-------------|--------|----------|----------------|----------------|
| Step | Discharge | Measured Sw | Sw/Q | Calc. Sw | Well Loss (m)* | Well Loss (%)* |
| Step 1 | 158.4 m3/d | 3.6 m | 0.0229 | 3.8 | 1.79 | 47.35% |
| Step 2 | 201.6 m3/d | 5.7 m | 0.0284 | 5.4 | 2.91 | 53.37% |
| Step 3 | 259.2 m3/d | 8.0 m | 0.0310 | 8.1 | 4.80 | 59.54% |
| Step 4 | 316.8 m3/d | 11.1 m | 0.0349 | 11.2 | 7.17 | 64.27% |
| Well Drawdown Equation at 60 min pumping : $sw = 0.0125911821340293Q + 7.14814652695305E-05Q(2)$ | | | | | | |
| Estimated Transmissivity (Logan 1964) : 96.9 m2/d | | | | | | |

* Note that well losses includes turbulent flow losses within the aquifer



Old Saasabi 062/H/18/BH-1 Constant Rate Test

Project : CWSA
 District : Ga
 Community : Old Saasabi
 Pumping Well : 062/H/18/BH-1
 Observation Well : 062/H/18/BH-1
 Borehole Depth : 45m
 Pump Setting : 33m
 Height of datum : 0.72m amgl


Distance to Pumping Well : 0.1 m
 Pumping rate : 316.8 m³/d
 Static Water level : 13.4 m
 Measurement Datum : Top of PVC
 Pump on : 08/02/2003 6:00:00 PM
 Pump off : 10/02/2003 6:00:00 PM
 Measured by : VENT-3
 Interpreted by : ENDD

Transmissivity : 139.42 m²/d

Mean Fitting Error : 1,569.10 %
 Drawdown over 1 log cycle : 0.4158 m

Straight Line Pumping Test Analysis (Cooper & Jakob, 1946)

Note that this method does not apply to data when $u > 0.05$, to the left of the dotted line and that Storativity cannot be calculated without observation wells



Old Saasabi 062/H/18/BH-1 Constant Rate Test

Project : CWSA
District : Ga
Community : Old Saasabi
Pumping Well : 062/H/18/BH-1
Observation Well : 062/H/18/BH-1
Borehole Depth : 45m
Pump Setting : 33m
Height of datum : 0.72m amgl

Distance to Pumping Well : 0.1 m
Pumping rate : 316.8 m3/d
Static Water level : 13.40 m
Measurement Datum : Top of PVC
Pump on : 08/02/2003 6:00:00 PM
Pump off : 10/02/2003 6:00:00 PM
Measured by : VENT-3
Interpreted by : ENDD

#N/A

| Data # | Time (GMT) | Time (min) | Water level (meters) | Discharge (l/min) | Cond. (µS/cm) | Drawdown (meters) | Calculated Drawdown | Error % | Included in analysis |
|--------|------------|------------|----------------------|-------------------|---------------|-------------------|---------------------|---------|----------------------|
| 1 | 18:01 | 1.0 | 22.47 | 220.0 | 486 | 9.07 | 10.96 | 20.8 | yes |
| 2 | 18:03 | 2.0 | 23.88 | | | 10.48 | 11.08 | 5.8 | yes |
| 3 | 18:04 | 3.0 | 24.48 | | | 11.08 | 11.16 | 0.7 | yes |
| 4 | 18:05 | 4.0 | 24.71 | | | 11.31 | 11.21 | 0.9 | yes |
| 5 | 18:06 | 5.0 | 24.79 | 220.0 | 482 | 11.39 | 11.25 | 1.2 | yes |
| 6 | 18:07 | 6.0 | 24.84 | | | 11.44 | 11.28 | 1.4 | yes |
| 7 | 18:08 | 7.0 | 24.85 | | | 11.45 | 11.31 | 1.2 | yes |
| 8 | 18:09 | 8.0 | 24.87 | | | 11.47 | 11.33 | 1.2 | yes |
| 9 | 18:10 | 9.0 | 24.89 | | | 11.49 | 11.36 | 1.2 | yes |
| 10 | 18:11 | 10.0 | 24.91 | | 480 | 11.51 | 11.38 | 1.2 | yes |
| 11 | 18:16 | 15.0 | 24.94 | | | 11.54 | 11.45 | 0.8 | yes |
| 12 | 18:21 | 20.0 | 24.97 | | | 11.57 | 11.50 | 0.6 | yes |
| 13 | 18:26 | 25.0 | 25.00 | | | 11.60 | 11.54 | 0.5 | yes |
| 14 | 18:31 | 30.0 | 25.03 | 220.0 | 476 | 11.63 | 11.57 | 0.5 | yes |
| 15 | 18:36 | 35.0 | 25.07 | | | 11.67 | 11.60 | 0.6 | yes |
| 16 | 18:41 | 40.0 | 25.09 | | | 11.69 | 11.63 | 0.6 | yes |
| 17 | 18:46 | 45.0 | 25.10 | | | 11.70 | 11.65 | 0.5 | yes |
| 18 | 18:51 | 50.0 | 25.12 | | | 11.72 | 11.67 | 0.5 | yes |
| 19 | 18:56 | 55.0 | 25.14 | | | 11.74 | 11.68 | 0.5 | yes |
| 20 | 19:01 | 60.0 | 25.17 | 220.0 | 477 | 11.77 | 11.70 | 0.6 | yes |
| 21 | 19:16 | 75.0 | 25.20 | | | 11.80 | 11.74 | 0.5 | yes |
| 22 | 19:31 | 90.0 | 25.21 | 220.0 | 475 | 11.81 | 11.77 | 0.3 | yes |
| 23 | 19:46 | 105.0 | 25.23 | | | 11.83 | 11.80 | 0.3 | yes |
| 24 | 20:01 | 120.0 | 25.24 | 220.0 | 475 | 11.84 | 11.82 | 0.1 | yes |
| 25 | 20:16 | 135.0 | 25.26 | | | 11.86 | 11.85 | 0.1 | yes |
| 26 | 20:31 | 150.0 | 25.27 | | | 11.87 | 11.86 | 0.0 | yes |
| 27 | 20:46 | 165.0 | 25.28 | | | 11.88 | 11.88 | 0.0 | yes |
| 28 | 21:01 | 180.0 | 25.30 | 220.0 | 472 | 11.90 | 11.90 | 0.0 | yes |
| 29 | 21:31 | 210.0 | 25.33 | | | 11.93 | 11.93 | 0.0 | yes |
| 30 | 22:01 | 240.0 | 25.34 | 220.0 | 473 | 11.94 | 11.95 | 0.1 | yes |
| 31 | 22:31 | 270.0 | 25.36 | | | 11.96 | 11.97 | 0.1 | yes |
| 32 | 23:01 | 300.0 | 25.38 | 220.0 | 475 | 11.98 | 11.99 | 0.1 | yes |
| 33 | 23:31 | 330.0 | 25.38 | | | 11.98 | 12.01 | 0.2 | yes |
| 34 | 00:01 | 360.0 | 25.39 | 220.0 | 473 | 11.99 | 12.02 | 0.3 | yes |
| 35 | 01:01 | 420.0 | 25.42 | 220.0 | 470 | 12.02 | 12.05 | 0.3 | yes |
| 36 | 02:01 | 480.0 | 25.42 | 220.0 | 470 | 12.02 | 12.07 | 0.5 | yes |
| 37 | 03:01 | 540.0 | 25.42 | 220.0 | 469 | 12.02 | 12.10 | 0.6 | yes |
| 38 | 04:01 | 600.0 | 25.38 | 220.0 | 470 | 11.98 | 12.11 | 1.1 | yes |
| 39 | 05:01 | 660.0 | 25.38 | 220.0 | 474 | 11.98 | 12.13 | 1.3 | yes |
| 40 | 06:01 | 720.0 | 25.60 | 220.0 | 474 | 12.20 | 12.15 | 0.4 | yes |
| 41 | 07:01 | 780.0 | 25.60 | 220.0 | 467 | 12.20 | 12.16 | 0.3 | yes |
| 42 | 08:01 | 840.0 | 25.60 | 220.0 | 469 | 12.20 | 12.18 | 0.2 | yes |
| 43 | 09:01 | 900.0 | 25.59 | 220.0 | 472 | 12.19 | 12.19 | 0.0 | yes |
| 44 | 10:01 | 960.0 | 25.66 | 220.0 | 469 | 12.26 | 12.20 | 0.5 | yes |
| 45 | 11:01 | 1,020.0 | 25.67 | 220.0 | 470 | 12.27 | 12.21 | 0.5 | yes |
| 46 | 12:01 | 1,080.0 | 25.65 | 220.0 | 471 | 12.25 | 12.22 | 0.2 | yes |
| 47 | 13:01 | 1,140.0 | 25.67 | 220.0 | 472 | 12.27 | 12.23 | 0.3 | yes |
| 48 | 14:01 | 1,200.0 | 25.68 | 220.0 | 469 | 12.28 | 12.24 | 0.3 | yes |
| 49 | 15:01 | 1,260.0 | 25.70 | 220.0 | 469 | 12.30 | 12.25 | 0.4 | yes |
| 50 | 16:01 | 1,320.0 | 25.69 | 220.0 | 468 | 12.29 | 12.26 | 0.3 | yes |
| 51 | 17:01 | 1,380.0 | 25.71 | 220.0 | 473 | 12.31 | 12.27 | 0.4 | yes |
| 52 | 18:01 | 1,440.0 | 25.71 | 220.0 | 472 | 12.31 | 12.27 | 0.3 | yes |
| 53 | 19:01 | 1,500.0 | 25.70 | 220.0 | 474 | 12.30 | 12.28 | 0.2 | yes |
| 54 | 20:01 | 1,560.0 | 25.69 | 220.0 | 470 | 12.29 | 12.29 | 0.0 | yes |
| 55 | 21:01 | 1,620.0 | 25.72 | 220.0 | 470 | 12.32 | 12.29 | 0.2 | yes |

Old Saasabi 062/H/18/BH-1 Constant Rate Test

Project : CWSA
 District : Ga
 Community : Old Saasabi
 Pumping Well : 062/H/18/BH-1
 Observation Well : 062/H/18/BH-1
 Borehole Depth : 45m
 Pump Setting : 33m
 Height of datum : 0.72m amgl

Distance to Pumping Well : 0.1 m
 Pumping rate : 316.8 m3/d
 Static Water level : 13.40 m
 Measurement Datum : Top of PVC
 Pump on : 08/02/2003 6:00:00 PM
 Pump off : 10/02/2003 6:00:00 PM
 Measured by : VENT-3
 Interpreted by : ENDD

#N/A

| Data # | Time (GMT) | Time (min) | Water level (meters) | Discharge (l/min) | Cond. (µS/cm) | Drawdown (meters) | Calculated Drawdown | Error % | Included in analysis |
|--------|------------|------------|----------------------|-------------------|---------------|-------------------|---------------------|---------|----------------------|
| 56 | 22:01 | 1,680.0 | 25.74 | 220.0 | 469 | 12.34 | 12.30 | 0.3 | yes |
| 57 | 23:01 | 1,740.0 | 25.74 | 220.0 | 468 | 12.34 | 12.31 | 0.3 | yes |
| 58 | 00:01 | 1,800.0 | 25.75 | 220.0 | 468 | 12.35 | 12.31 | 0.3 | yes |
| 59 | 01:01 | 1,860.0 | 25.76 | 220.0 | 468 | 12.36 | 12.32 | 0.3 | yes |
| 60 | 02:01 | 1,920.0 | 25.76 | 220.0 | 470 | 12.36 | 12.32 | 0.3 | yes |
| 61 | 03:01 | 1,980.0 | 25.76 | 220.0 | 469 | 12.36 | 12.33 | 0.2 | yes |
| 62 | 04:01 | 2,040.0 | 25.77 | 220.0 | 468 | 12.37 | 12.34 | 0.3 | yes |
| 63 | 05:01 | 2,100.0 | 25.78 | 220.0 | 468 | 12.38 | 12.34 | 0.3 | yes |
| 64 | 06:01 | 2,160.0 | 25.77 | 220.0 | 468 | 12.37 | 12.35 | 0.2 | yes |
| 65 | 07:01 | 2,220.0 | 25.76 | 220.0 | 468 | 12.36 | 12.35 | 0.1 | yes |
| 66 | 08:01 | 2,280.0 | 25.77 | 220.0 | 468 | 12.37 | 12.36 | 0.1 | yes |
| 67 | 09:01 | 2,340.0 | 25.78 | 220.0 | 468 | 12.38 | 12.36 | 0.2 | yes |
| 68 | 10:01 | 2,400.0 | 25.80 | 220.0 | 468 | 12.40 | 12.37 | 0.3 | yes |
| 69 | 11:01 | 2,460.0 | 25.79 | 220.0 | 468 | 12.39 | 12.37 | 0.2 | yes |
| 70 | 12:01 | 2,520.0 | 25.80 | 220.0 | 468 | 12.40 | 12.37 | 0.2 | yes |
| 71 | 13:01 | 2,580.0 | 25.80 | 220.0 | 468 | 12.40 | 12.38 | 0.2 | yes |
| 72 | 14:01 | 2,640.0 | 25.80 | 220.0 | 468 | 12.40 | 12.38 | 0.1 | yes |
| 73 | 15:01 | 2,700.0 | 25.80 | 220.0 | 468 | 12.40 | 12.39 | 0.1 | yes |
| 74 | 16:01 | 2,760.0 | 25.80 | 220.0 | 468 | 12.40 | 12.39 | 0.1 | yes |
| 75 | 17:01 | 2,820.0 | 25.82 | 220.0 | 468 | 12.42 | 12.39 | 0.2 | yes |
| 76 | 18:01 | 2,880.0 | 25.82 | 220.0 | 468 | 12.42 | 12.40 | 0.2 | yes |
| 77 | 18:02 | 2,881.0 | 14.02 | RECOVERY | | 0.62 | 12.40 | 1899.7 | yes |
| 78 | 18:03 | 2,882.0 | 14.01 | | | 0.61 | 12.40 | 1932.5 | yes |
| 79 | 18:04 | 2,883.0 | 13.95 | | | 0.55 | 12.40 | 2154.2 | yes |
| 80 | 18:05 | 2,884.0 | 13.92 | | | 0.52 | 12.40 | 2284.3 | yes |
| 81 | 18:06 | 2,885.0 | 13.89 | | | 0.49 | 12.40 | 2430.3 | yes |
| 82 | 18:07 | 2,886.0 | 13.87 | | | 0.47 | 12.40 | 2537.9 | yes |
| 83 | 18:08 | 2,887.0 | 13.85 | | | 0.45 | 12.40 | 2655.2 | yes |
| 84 | 18:09 | 2,888.0 | 13.84 | | | 0.44 | 12.40 | 2717.8 | yes |
| 85 | 18:10 | 2,889.0 | 13.83 | | | 0.43 | 12.40 | 2783.4 | yes |
| 86 | 18:11 | 2,890.0 | 13.82 | | | 0.42 | 12.40 | 2852.0 | yes |
| 87 | 18:16 | 2,895.0 | 13.78 | | | 0.38 | 12.40 | 3162.9 | yes |
| 88 | 18:21 | 2,900.0 | 13.76 | | | 0.36 | 12.40 | 3344.2 | yes |
| 89 | 18:26 | 2,905.0 | 13.74 | | | 0.34 | 12.40 | 3546.9 | yes |
| 90 | 18:31 | 2,910.0 | 13.72 | | | 0.32 | 12.40 | 3774.9 | yes |
| 91 | 18:36 | 2,915.0 | 13.70 | | | 0.30 | 12.40 | 4033.4 | yes |
| 92 | 18:41 | 2,920.0 | 13.69 | | | 0.29 | 12.40 | 4176.0 | yes |
| 93 | 18:46 | 2,925.0 | 13.68 | | | 0.28 | 12.40 | 4328.8 | yes |
| 94 | 18:51 | 2,930.0 | 13.67 | | | 0.27 | 12.40 | 4493.0 | yes |
| 95 | 18:56 | 2,935.0 | 13.66 | | | 0.26 | 12.40 | 4669.7 | yes |
| 96 | 19:01 | 2,940.0 | 13.66 | | | 0.26 | 12.40 | 4669.9 | yes |
| 97 | 19:16 | 2,955.0 | 13.64 | | | 0.24 | 12.40 | 5067.7 | yes |
| 98 | 19:31 | 2,970.0 | 13.63 | | | 0.23 | 12.40 | 5292.8 | yes |
| 99 | 19:46 | 2,985.0 | 13.62 | | | 0.22 | 12.40 | 5538.4 | yes |
| 100 | 20:01 | 3,000.0 | 13.62 | | | 0.22 | 12.41 | 5538.8 | yes |
| 101 | 20:16 | 3,015.0 | 13.61 | | | 0.21 | 12.41 | 5807.7 | yes |
| 102 | 20:31 | 3,030.0 | 13.61 | | | 0.21 | 12.41 | 5808.1 | yes |
| 103 | 20:46 | 3,045.0 | 13.60 | | | 0.20 | 12.41 | 6104.0 | yes |
| 104 | 21:01 | 3,060.0 | 13.60 | | | 0.20 | 12.41 | 6104.4 | yes |
| 105 | 21:31 | 3,090.0 | 13.58 | | | 0.18 | 12.41 | 6794.8 | yes |
| 106 | 22:01 | 3,120.0 | 13.57 | | | 0.17 | 12.41 | 7201.4 | yes |
| 107 | 22:31 | 3,150.0 | 13.56 | | | 0.16 | 12.41 | 7658.8 | yes |
| 108 | 23:01 | 3,180.0 | 13.56 | | | 0.16 | 12.42 | 7659.9 | yes |
| 109 | 23:31 | 3,210.0 | 13.55 | | | 0.15 | 12.42 | 8178.3 | yes |
| 110 | 00:01 | 3,240.0 | 13.54 | | | 0.14 | 12.42 | 8770.9 | yes |

Old Saasabi 062/H/18/BH-1

Estimated Maximum Sustainable Well Yield Calculation

| Pumping Test & Borehole Parameters | | | |
|------------------------------------|---------|-------------------|---|
| Q | 220 | l/min | Constant rate pumping test yield |
| | 13.2 | m ³ /h | |
| | 316.8 | m ³ /d | |
| t _{pump test} | 2,880 | minutes | Pumping test duration |
| | 2 | days | |
| r | 6.5 | inch | Effective well diameter |
| | 0.08255 | m | |
| swl | 13.4 | m | Static water level below datum before pumping test |
| | 12.42 | m | |
| Δs | 12.42 | m | Drawdown at end of pumping test |
| | 0.4158 | m | |
| pwl _{max} | 32 | m | Maximum allowable pumping water level below datum |
| | 3 | m | |
| Δs _{seasonal} | 3 | m | Estimated seasonal water level decline |
| | 15.6 | m | |
| S _{max} | 139.42 | m ² /d | Transmissivity calculated from pumping test data |
| | 0.005 | m ² /d | |
| S _{min} | 0.005 | m ² /d | Minimum likely storativity |
| | 0.03 | m ² /d | |
| E _{step test} | 0.36 | m ² /d | Well efficiency estimated from step test |
| | 0.24 | m ² /d | |
| E _{min} | 0.24 | m ² /d | Well efficiency estimated from Transmissivity & minimum likely Storativity |
| | 0.22 | m ² /d | |
| E _{max} | 0.22 | m ² /d | Well efficiency estimated from Transmissivity & maximum likely Storativity |
| | 0.24 | m ² /d | |
| E _{min} | 0.24 | m ² /d | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| | 0.22 | m ² /d | |
| E _{max} | 0.22 | m ² /d | Well Efficiency used for calculations. E = 1 if calculated E > 1 |
| | 0.24 | m ² /d | |
| t | 300 | d | Length of hydrological year without recharge - the time between two rainy seasons |
| | 300 | d | |


$$Q_{max} = \frac{E \cdot S_{max} \cdot T}{0.183 \log(2.25 Tt / r^2 S)}$$

The sustainable yield formula is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946)

| Estimated Maximum Sustainable Well Yield at Continuous 24/24 Hour Pumping | | | | | | | | | | |
|---|-----------------------|-------------------|-----------------------|-------------------|-----------------------|-------------------|-----------------------|-------------------|-------------------------|-------------------|
| Q _{max} | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.005 | | 0.03 | | 0.005 | | 0.03 | | 0.03 | |
| E | 0.36 | | 0.36 | | 0.24 | | 0.22 | | 0.217186233 | |
| 24/24 h Pumping Cycle | 453 | 18.9 | 494 | 20.6 | 306 | 12.8 | 298 | 12.4 | 298 | 12.4 |
| | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h | m ³ /d | m ³ /h |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Predicted Drawdown at Estimated Maximum Sustainable Yield



Old Saasabi 062/H/18/BH-1

Estimated Maximum Sustainable Well Yield Calculation


$$Q_{max} = \frac{E \cdot 0.228 \cdot S_{max} \cdot T}{t \cdot \log(t_2 - 1 + t_1/t_2) + \log(2.25 T t_1 / (r^2 S))}$$

The sustainable yield formula for intermittent pumping is based on the Modified Nonequilibrium Equation, Cooper & Jakob (1946) and the imaginary well procedure outlined in "Groundwater & Wells" Driscoll, 1986

| Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates | | | | | | | | | | |
|---|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|-------------------------------|---|---------------------------------|
| | Q _{max} (1a) | | Q _{max} (1b) | | Q _{max} (2a) | | Q _{max} (2b) | | Lowest Q _{max} | |
| S | 0.006 | | 0.03 | | 0.005 | | 0.03 | | - | |
| E | 0.35 | | 0.36 | | 0.24 | | 0.22 | | - | |
| Daily Pumping Cycle (hrs) | Q _{max} (1a) m ³ /h | Volume (1a) m ³ /d | Q _{max} (1b) m ³ /h | Volume (1b) m ³ /d | Q _{max} (2a) m ³ /h | Volume (2a) m ³ /d | Q _{max} (2b) m ³ /h | Volume (2b) m ³ /d | Lowest Q _{max} m ³ /h | Lowest Volume m ³ /d |
| 8 | 23.9 | 191 | 26.7 | 213 | 16.1 | 129 | 16.1 | 129 | 16.1 | 129 |
| 9 | 23.4 | 211 | 26.1 | 235 | 15.8 | 142 | 15.7 | 142 | 15.7 | 142 |
| 10 | 23.0 | 230 | 25.5 | 255 | 15.5 | 155 | 15.4 | 154 | 15.4 | 154 |
| 11 | 22.6 | 248 | 25.0 | 275 | 15.2 | 168 | 15.1 | 166 | 15.1 | 166 |
| 12 | 22.2 | 266 | 24.5 | 295 | 15.0 | 180 | 14.8 | 178 | 14.8 | 178 |
| 13 | 21.8 | 284 | 24.1 | 313 | 14.7 | 192 | 14.5 | 189 | 14.5 | 189 |
| 14 | 21.5 | 301 | 23.7 | 332 | 14.5 | 203 | 14.3 | 200 | 14.3 | 200 |
| 15 | 21.2 | 317 | 23.3 | 350 | 14.3 | 214 | 14.1 | 211 | 14.1 | 211 |
| 16 | 20.9 | 334 | 23.0 | 367 | 14.1 | 226 | 13.8 | 222 | 13.8 | 222 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly. It is unwise to select a pumping rate that exceeds those used during the pumping tests, without further tests.

Estimated Maximum Sustainable Well Yields at Intermittent Pumping Rates



Old Saasabi 062/H/18/BH-1

Estimated Maximum Sustainable Well Yield Calculation


$$s = \frac{0.183 Q}{E \cdot T} [t_1 \log ((t_2 - 1 + t_1) / t_1) + \log (2.25 T t_1 / (r^2 S))]$$

The formula for estimated drawdown due to intermittent pumping is based on the imaginary well procedure outlined in "Groundwater & Wells", Driscoll, 1986

| Estimated Drawdown at Intermittent Pumping Rates | | | | | | |
|--|---------------------------|------------------------------------|---|---|---|---|
| Scenario | | | 1a | 1b | 2a | 2b |
| Storativity (S) | | | 0.005 | 0.03 | 0.005 | 0.03 |
| Well Efficiency (E) | | | 0.36 | 0.36 | 0.24 | 0.22 |
| Water Demand (m ³ /d) | Daily Pumping Cycle (hrs) | Q _{obs} m ³ /h | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season | Estimated Drawdown (m) at end of Dry Season |
| 150.0 | 8 | 18.8 | 12.3 | 11.0 | 18.1 | 18.2 |
| | 9 | 16.7 | 11.1 | 10.0 | 16.5 | 16.6 |
| | 10 | 15.0 | 10.2 | 9.2 | 15.1 | 15.2 |
| | 11 | 13.6 | 9.4 | 8.5 | 14.0 | 14.1 |
| | 12 | 12.5 | 8.8 | 8.0 | 13.0 | 13.2 |
| | 13 | 11.5 | 8.3 | 7.5 | 12.2 | 12.4 |
| | 14 | 10.7 | 7.8 | 7.1 | 11.5 | 11.7 |
| | 15 | 10.0 | 7.4 | 6.7 | 10.9 | 11.1 |
| | 16 | 9.4 | 7.0 | 6.4 | 10.4 | 10.6 |

Note that these estimates are very theoretical and that all production wells should be monitored regularly

Estimated Drawdown at the End of the Dry Season at Various Pumping Cycles



Water Demand = 150 m³/d

Note that drawdown cannot exceed the maximum allowable drawdown S_{max}.

ANNEX 3

WATER RESEARCH INSTITUTE, (CSIR)
RESULTS OF WATER QUALITY ANALYSIS FOR
EASTERN RCWS PROGRAMME

Community: KPONE SEDUASE
 District:
 Source Name:

Location Code:
 Source Ref. No.
 Date: 27/09/02

| Parameter | Units | GWCL Guideline values | Permissible limits | Sample Value |
|---|-------|-----------------------------|--------------------|--------------|
| Turbidity | NTU | 0 - 5 | | 1 |
| Color (Apparent) | Hz | 0 - 15 | 50 | <5 |
| Color (True) | Hz | 0 - 15 | 25 | <5 |
| pH | | 6.5 - 8.5 | > 5.0 | 6 |
| Electrical Conductivity | µS/cm | | | 609 |
| Total Suspended Solids (TSS) | mg/l | 0 | | 0.4 |
| Total Dissolved Solids (TDS) | mg/l | 1000 | | 396 |
| Sodium (Na ⁺) | mg/l | | | 42.3 |
| Potassium (K ⁺) | mg/l | | | 2.5 |
| Calcium (Ca ²⁺) | mg/l | No health related guideline | | 20 |
| Magnesium (Mg) | mg/l | | | 16 |
| Total Iron (Fe) | mg/l | 0 - 0.3 | 1 | 0.09 |
| Manganese (Mn) | mg/l | 0 - 0.1 | 0.5 | 0.07 |
| Ammonia (NH ₃ -N) | mg/l | 0 - 0.5 | | <0.01 |
| Chloride (Cl ⁻) | mg/l | 0 - 250 | 600 | 99.3 |
| Sulphate (SO ₄ ²⁻) | mg/l | 0 - 400 | | 0 |
| Nitrite (NO ₂ -N) | mg/l | 0 - 3.0 | | <0.01 |
| Nitrate (NO ₃ -N) | mg/l | 0 - 10 | 50 | 0.01 |
| Total Alkalinity | mg/l | No health related guideline | | 56 |
| Permanent Hardness | mg/l | | | 50.9 |
| Temporary Hardness | mg/m | | | 50.1 |
| Fluoride (F ⁻) | mg/l | 0 - 1.5 | | 0.14 |
| Bicarbonate | mg/l | | | 68.3 |
| Carbonate | mg/l | | | 0 |
| Ionic Balance | % | | (- 5 to 5) | -3.65 |

| | | | | |
|--------------------------------|--|----------------------|----|------|
| MPN (Total Coliform 10/100ml) | | Untreated suppliers) | | 0.00 |
| MPN (Faecal Coliform 10/100ml) | | 0 | 50 | 0 |

Remarks: The physico-chemical and bacteriological quality of the water sample are satisfactory.
 The water is recommended for potable use.

(Signature)

BOREHOLE RECORD

OLD SAASARI

BH REF No

062-H-18-R01

NALCO

22-08-02

Working
Completed Date

23-08-02

Operator

Operator
OSEI

24.09 m

13.90 m

10.19 m

15-09-02

Submersible

10.8 m³/h

6 h

1.06 m³/h/m

1006 us/cm

0.26 mg/l

0.13 mg/l

0.02 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

0.1 mg/l

Stiff chocolate brown clay

Highly weathered pale yellowish brown acid gneiss

Moderate to slightly weathered acid gneiss

Fresh hard acid gneiss

Upper Grout

Backfill

Lower Grout

Gravel Pack

Bail Plug

8.5
Dwg
Bit

6.5
DTH

0.15
100

WATER RESEARCH INSTITUTE, (CSIR)
RESULTS OF WATER QUALITY ANALYSIS FOR EASTERN
RCWS PROGRAMME

Community: OYIBI (AFTER 48 HRS)
 District:
 Source Name:

Location Code:
 Source Ref. No:
 Date: 20/10/02

| Parameter | Units | GWCL Guideline values | Permissible limits | Sample Value |
|---|-------|-----------------------------|--------------------|--------------|
| Turbidity | NTU | 0 - 5 | | 1.8 |
| Color (True) | Hz | 0 - 5 | 25 | <5 |
| Color (Apparent) | Hz | 0 - 15 | 50 | <5 |
| pH | | 6.5 - 8.5 | > 5.0 | 5.7 |
| Electrical Conductivity | µS/cm | | | 1850 |
| Total Suspended Solids (TSS) | mg/l | 0 | | 0.4 |
| Total Dissolved Solids (TDS) | mg/l | 1000 | | 1036 |
| Sodium (Na ⁺) | mg/l | | | 48.4 |
| Potassium (K ⁺) | mg/l | | | 7.7 |
| Calcium (Ca ²⁺) | mg/l | No health related guideline | | 59.3 |
| Magnesium (Mg) | mg/l | | | 52.4 |
| Total Iron (Fe) | mg/l | 0 - 0.3 | 1 | 0.01 |
| Manganese (Mn) | mg/l | 0 - 0.1 | 1 | 0.04 |
| Ammonia (NH ₃ -N) | mg/l | 0 - 0.5 | | <0.01 |
| Chloride (Cl ⁻) | mg/l | 0 - 250 | 600 | 240 |
| Sulphate (SO ₄ ²⁻) | mg/l | 0 - 400 | | 36.9 |
| Nitrite (NO ₂ -N) | mg/l | 0 - 3.0 | | <0.01 |
| Nitrate (NO ₃ -N) | mg/l | 0 - 10 | 50 | 9.5 |
| Total Alkalinity | mg/l | No health related guideline | | 48 |
| Permanent Hardness | mg/l | | | 216 |
| Temporary Hardness | | | | 1.8 |
| Fluoride (F ⁻) | mg/l | 0 - 1.5 | | 0.12 |
| Bicarbonate | mg/l | | | 58.3 |
| Carbonate | mg/l | | | 1.7 |
| Ionic Balance | | | (-5 to 5) | 8.1 |

REMARKS: The physical, chemical and bacteriological parameters of the water sample were satisfactory.
 The water is not recommended for drinking.

(Signature)

ANNEX 4

T I T L E : G.A.R. Rural W.S. (Trans. Net.)
 NO. OF PIPES : 19
 NO. OF NODES : 20
 PEAK FACTOR : 1
 MAX HEADLOSS/Km : 10
 MAX UNBAL(LPS) : 0

| PIPE NO. | FROM Node | TO Node | LENGTH (M) | DIA (MM) | HWC | FLOW (LPS) | VELOCITY (MPS) | HEADLOSS (M/KM) | (M) |
|----------|-----------|---------|--------------|----------|-----|------------|----------------|-----------------|-------|
| 1 | 101 | 100 | 35.00 | 100 | 130 | 2.80 | 0.36 | 1.83 | 0.06 |
| 2 | 100 | 1 | 100.00 | 150 | 130 | 2.80 | 0.16LO | 0.25 | 0.03 |
| 3 | 1 | 300 | 50.00 | 12 | 130 | 0.15 | 1.33 | 250.28HI | 12.51 |
| 4 | 1 | 2 | 1600.00 | 150 | 130 | 2.65 | 0.15LO | 0.23 | 0.37 |
| 5 | 6 | 2 | 1650.00 | 100 | 130 | 2.79 | 0.36 | 1.82 | 3.01 |
| 6 | 201 | 200 | 45.00 | 100 | 130 | 3.50 | 0.45 | 2.77 | 0.12 |
| 7 | 200 | 6 | 100.00 | 150 | 130 | 3.50 | 0.20LO | 0.38 | 0.04 |
| 8 | 7 | 400 | 100.00 | 20 | 130 | 0.71 | 2.26 | 366.47HI | 36.65 |
| 9 | 6 | 7 | 400.00 | 150 | 130 | 0.71 | 0.04LO | 0.02 | 0.01 |
| 10 | 2 | 10 | 2200.00 | 150 | 130 | 5.44 | 0.31 | 0.87 | 1.91 |
| 11 | 11 | 500 | 100.00 | 150 | 130 | 2.96 | 0.17LO | 0.28 | 0.03 |
| 13 | 10 | 3 | 1250.00 | 150 | 130 | 2.48 | 0.14LO | 0.20 | 0.26 |
| 14 | 3 | 700 | 100.00 | 12 | 130 | 0.08 | 0.72 | 79.76HI | 7.98 |
| 15 | 3 | 4 | 1300.00 | 100 | 130 | 2.40 | 0.31 | 1.38 | 1.80 |
| 16 | 4 | 800 | 100.00 | 40 | 130 | 1.36 | 1.08 | 41.79HI | 4.18 |
| 17 | 4 | 5 | 1100.00 | 100 | 130 | 1.04 | 0.13LO | 0.30 | 0.32 |
| 18 | 5 | 900 | 150.00 | 12 | 130 | 0.07 | 0.61 | 59.03HI | 8.85 |
| 19 | 5 | 901 | 3650.00 | 75 | 130 | 0.97 | 0.22LO | 1.06 | 3.85 |
| 20 | 10 | 11 | 100.00 | 100 | 130 | 2.96 | 0.38 | 2.03 | 0.20 |

| NODE NO. | FLOW (LPS) | ELEVATION (M) | H G L (M) | PRESSURE (M) |
|----------|------------|-----------------|-------------|----------------|
| 1 | 0.000 | 99.91 | 132.51 | 32.60 |
| 2 | 0.000 | 77.41 | 132.15 | 54.74 |
| 3 | 0.000 | 101.60 | 129.98 | 28.38 |
| 4 | 0.000 | 109.10 | 128.18 | 19.08 |
| 5 | 0.000 | 93.20 | 127.85 | 34.65 |
| 6 | 0.000 | 77.50 | 135.16 | 57.66 |
| 7 | 0.000 | 78.50 | 135.15 | 56.65 |
| 10 | 0.000 | 112.40 | 130.23 | 17.83 |
| 11 | 0.000 | 112.00 | 130.03 | 18.03 |
| 100 | 0.000 | 98.50 | 132.54 | 34.04 |
| 101 | 2.800 | 63.50 | 132.60 | 69.10 |
| 200 | 0.000 | 77.50 | 135.19 | 57.69 |
| 201 | 3.500 | 32.50 | 135.32 | 102.82 |
| 300 R | -0.150 | 99.91 | 120.00 | 20.00 |
| 400 R | -0.709 | 79.00 | 98.50 | 19.50 |
| 500 R | -2.957 | 112.00 | 130.00 | 18.00 |
| 700 R | -0.081 | 102.00 | 122.00 | 20.00 |

| NODE NO. | FLOW (LPS) | ELEVATION (M) | H G L (M) | PRESSURE (M) |
|-------------|---------------|--------------------|----------------|-------------------|
| 800 R | -1.360 | 109.00 | 124.00 | 15.00 |
| 900 R | -0.069 | 99.65 | 119.00 | 19.35 |
| 901 R | -0.974 | 103.76 | 124.00 | 20.24 |